

## CAPITAL ELECTRIC COOP

### MENOKEN SUB CCT 3 OUTAGE HISTORY

2009	2010	2011	2012	2013	2014
1	2	0	0	1	0

**CAPITAL ELECTRIC COOPERATIVE**

W/O#:                      Account: 3456902                      SO Nbr: 523532                      Cycle: 1                      Date Needed: 06/03/2013

Srv Map Loc: 452808157

**MISCELLANEOUS REQUEST**

KRISTI D VETTER  
 2248 171ST ST NE  
 MENOKEN, ND 58558

Home Phone: (701)673-3142 Ext.  
 Work Phone: (701)663-6595 Ext. 4304  
 Mobile Phone: NONE LISTED

Electrician: T&M ELECTRIC	Service Desc: SECTION 28	Block:	Lot:
Permit #: 547403	Subdivision:		
Inspection:	Builder:	Builder Ph: None Listed	
<b>TRANSFORMER</b>			
Transformer Loc#: 452808T4155	Sub: 15	Circuit: 4	Line Sect: 452807
Serial #: 91009101262	KVA: 37.5		Phase: C
<b>INSTALLED:</b>			
Serial #: _____	KVA: _____		Phase: _____
<b>METERS</b>			
Serial #: 22954979	TWACS: 4186002	Port: 1	LV Rdg: 6492      L V Rdg Dt: 05/01/2014
Reading: _____	Demand: _____	Mult: 1	Dials: 5      Rate: 023
Serial #: 68497173	TWACS: 82864005	Port: 0	LV Rdg: 9135      L V Rdg Dt: 05/01/2014
Reading: _____	Demand: _____	Mult: 1	Dials: 5      Rate: 045
<b>INSTALLED:</b>			
Serial #: _____	TWACS: _____	Type: _____	Port: _____
Reading: _____	Demand: _____	Mult: _____	Dials: _____

**DESCRIPTION:**

NO POWER REPORTED. C PHASE BREAKER WAS OPEN IN SUB. UNDERGROUND FAULT BETWEEN V4071 AND V1 AT STERLING SUB.

LD MH 6-2-13

**FIELD COMMENTS:**

---



---



---



---

Man Hours: \_\_\_\_\_  
 Unit/Mile: \_\_\_\_\_  
 Time Out: \_\_\_\_\_  
 Time On: \_\_\_\_\_  
 Completed By: \_\_\_\_\_  
 Date: \_\_\_\_\_



Dispatched To: \_\_\_\_\_  
 Job Briefing : \_\_\_\_\_  
 Close Date: 6/20/13  
 Taken By: ln 06/03/2013

**CAPITAL ELECTRIC COOPERATIVE**

W/O#: \_\_\_\_\_ Account: \_\_\_\_\_ SO Nbr: 501160 Cycle: \_\_\_\_\_ Date Needed: 08/30/2010  
 Srv Map Loc: 45-33

**GENERAL MAINT**

Home Phone: NONE LISTED  
 Work Phone: NONE LISTED  
 Mobile Phone: NONE LISTED

Electrician:	Service Desc:	Block:	Lot:
Permit #:	Subdivision:		
Inspection:	Builder:	Builder Ph:	None Listed
<b>TRANSFORMER</b>			
Transformer Loc#:	Sub:	Circuit:	Line Sect:
Serial #:	KVA:		Phase:
<b>INSTALLED:</b>			
Serial #:	KVA:		Phase:
<b>METERS</b>			
Serial #:	TWACS:	Port:	LV Rdg:
Reading:	Demand:	Mult:	L V Rdg Dt:
			Dials: Rate:
<b>INSTALLED:</b>			
Serial #:	TWACS:	Type:	Port:
Reading:	Demand:	Mult:	Dials:

**DESCRIPTION:**

B PHASE BREAKER OPEN IN MENOKEN SUB CCT3. ISOLATED LINE URD FAULT BETWEEN V1 SEC.27 AND V1 SEC.25. CLOSED BREAKER IN SUB AND CLOSED NORMAL OPEN AT 47-30 V1.

JOHN MIKE DALE STEVE K 8-27-10

**FIELD COMMENTS:**

---



---



---



---

Man Hours: \_\_\_\_\_  
 Unit/Mile: \_\_\_\_\_  
 Time Out: \_\_\_\_\_  
 Time On: \_\_\_\_\_  
 Completed By: \_\_\_\_\_  
 Date: \_\_\_\_\_



Dispatched To: \_\_\_\_\_  
 Job Briefing : \_\_\_\_\_  
 Close Date: 9/1/10  
 Taken By: In 08/30/2010

**CAPITAL ELECTRIC COOPERATIVE**

W/O#: \_\_\_\_\_ Account: \_\_\_\_\_ SO Nbr: 500657 Cycle: \_\_\_\_\_ Date Needed: 08/16/2010  
 Srv Map Loc: 45-33

**POWER INTERRUPTION**

Home Phone: NONE LISTED  
 Work Phone: NONE LISTED  
 Mobile Phone: NONE LISTED

Electrician:	Service Desc:	Block:	Lot:
Permit #:	Subdivision:		
Inspection:	Builder:	Builder Ph:	None Listed
<b>TRANSFORMER</b>			
Transformer Loc#:	Sub:	Circuit:	Line Sect:
Serial #:	KVA:		Phase:
<u>INSTALLED:</u>			
Serial #: _____	KVA: _____		Phase: _____
<b>METERS</b>			
Serial #:	TWACS:	Port:	LV Rdg:
Reading: _____	Demand: _____	Mult: _____	L V Rdg Dt:
<u>INSTALLED:</u>			
Serial #: _____	TWACS: _____	Type: _____	Port: _____
Reading: _____	Demand: _____	Mult: _____	Dials: _____

**DESCRIPTION:**

8-16-10 1413 hrs no power was reported. OCR open in menoken sub 15-3-3

FAULT BETWEEN V1 ,AP 46 SEC 26 AND V2 SEC 25 CABLE IS PARKED ON BOTH ENDS. C PHASE

DUG UP FAULT AND SPLICED IT. IT HAD SPLICES, SO WE DUG UP OTHER SPLICE PIT 96FT TO THE WEST OF THIS ONE AND PUT NEW SPLICE ON IT. WE ALSO DUG UP THE THIRD SPLICE PIT 40 FT TO THE WEST OF THE SECOND ONE AND THAT ONE HAD A NEW SPLICE ON IT.

LES SETH BRAD STEVE K 8-16-10

**FIELD COMMENTS:**

---



---



---



---

Man Hours: \_\_\_\_\_  
 Unit/Mile: \_\_\_\_\_  
 Time Out: \_\_\_\_\_  
 Time On: \_\_\_\_\_  
 Completed By: \_\_\_\_\_  
 Date: \_\_\_\_\_



Dispatched To: \_\_\_\_\_  
 Job Briefing : \_\_\_\_\_  
 Close Date: 8/20/10  
 Taken By: lw 08/16/2010

CAPITAL ELECTRIC COOPERATIVE, INC.  
PO Box 730 • Bismarck, ND 58502-0730

No 109409

### OUTAGE AND JOB ORDER

Const. No. \_\_\_\_\_ Retire No. \_\_\_\_\_ Office Ph. \_\_\_\_\_  
Home Ph. \_\_\_\_\_

Name Line Outage  
Address \_\_\_\_\_ Dispatched To \_\_\_\_\_  
City \_\_\_\_\_ State & Zip \_\_\_\_\_  
Area \_\_\_\_\_ Block \_\_\_\_\_ Lot \_\_\_\_\_  
Electrician \_\_\_\_\_ Affidavit No. \_\_\_\_\_ Rate Class \_\_\_\_\_  
Location: Map 45 Section 33 Detail \_\_\_\_\_ Account \_\_\_\_\_  
Time Out 12:00 Am Time Reported \_\_\_\_\_  
Time On 2:00 Am Members Affected 135  
Miles Driven 43 Man-hours Required 9 1/2

Removed	TRANSFORMERS	Installed
Number _____	Number _____	
KVA _____	KVA _____	
	<input type="checkbox"/> AØ	<input type="checkbox"/> BØ <input type="checkbox"/> CØ

**METERS**

Number _____	Number _____
Reading _____	Reading _____
Multiplier _____ Dials _____	Multiplier _____ Dials _____
Demand _____	Demand _____
TWACS Number _____	TWACS Number _____
<input type="checkbox"/> Job Briefing Conducted	TWACS Meter <input type="checkbox"/> 1 port <input type="checkbox"/> 3 port <input type="checkbox"/>

Description: No Power

Field Report: CB OCK open in menoken sub CCT3  
URD Fault between VI Sec. 33 Map 45 And VI  
Sec 30 Map 44

Disconnect: \_\_\_\_\_ Acct No. \_\_\_\_\_

Connect: \_\_\_\_\_ Acct No. \_\_\_\_\_

Received by: SRS Completed by: Brad, Rick, Matt

Date: 6-16-09 Date: 6-16-09

15-3-3