



# Public Service Commission

## State of North Dakota

### COMMISSIONERS

Brian P. Kalk  
Randy Christmann  
Julie Fedorchak

Executive Secretary  
Darrell Nitschke

February 12, 2014

600 East Boulevard, Dept. 408  
Bismarck, North Dakota 58505-0480  
Web: [www.psc.nd.gov](http://www.psc.nd.gov)  
E-mail: [ndpsc@nd.gov](mailto:ndpsc@nd.gov)  
Phone: 701-328-2400  
ND Toll Free: 1-877-245-6685  
Fax: 701-328-2410  
TDD: 800-366-6888 or 711

Mr. Mark Sherman, P.E.  
Manager of Operations & Engineering  
Central Power Electric Cooperative, Inc.  
P.O. Box 1576  
Minot, ND 58702

### **RE: Post Construction Inspections, Case Nos. PU-05-205 Burleigh Wind Transmission Line**

Dear Mr. Sherman:

The North Dakota Public Service Commission retained a third-party vendor to conduct post construction inspections under the authority provided in the above referenced case. Below we provide a weblink to the third-party post construction inspection report for your review and a link to the Commission's order in this proceeding. We also list actions recommended in the post construction inspection report for follow-up by the Company to confirm compliance with the Commission orders.

As per the post construction inspection report, the following information should be provided:

- A wavier for Jeff Spitzer was provided. Central Power needs to provide the Commission a wavier letter for the second landowner with a resident within 500 feet. This resident is in the SW corner of Section 14. (Order Point 7)
- A final correspondence that crash mitigation devices were installed for structures 26 & 27 is required to complete the file. (Order Point 8)
- Central Power should provide a letter to the Commission that the transmission line was constructed and operates in accordance with the National Electric Safety Code Standards (Order Point 9)

The construction report can be found at:

<http://www.psc.nd.gov/database/documents/05-0205/183-010.pdf>

The Commission Order can be found at:

<http://www.psc.nd.gov/database/documents/05-0205/058-001.pdf>


Please forward your response to the recommended Company actions, confirming these activities are complete, and describe actions and timelines for activities that are not complete. Please provide this documentation within 30 days.

---

Page 2  
Mr. Mark Sherman, P.E.  
February 12, 2014

If you have any questions regarding this letter, please contact me at 701-328-1035.

Sincerely,

A handwritten signature in black ink, appearing to read "Jerry Lein". The signature is written in a cursive style with a large, stylized "J" and "L".

Jerry Lein  
Public Utility Analyst