

Langdon Wind, LLC

700 Universe Blvd.
Juno Beach, Florida, 33408-2683

October 23, 2007

Ilona A. Jeffcoat-Sacco, Executive Director
North Dakota Public Service Commission
600 E. Boulevard, Dept.408
Bismarck, ND 58505-0480

Subject: **Langdon Wind, LLC: ND PSC Case No. PU-07-26**

Dear Secretary Jeffcoat-Sacco:


In accordance with the Commission's Order, Langdon Wind, LLC hereby submits the North Dakota Department of Health – Lake Region District Health Unit's Septic Tank and Drainfield Permit. Enclosed are eleven (11) copies of each permit.

Please contact me at (561) 691-7240 or Scott_Scovill@fpl.com with any questions or comments.

Sincerely,



Scott Scovill
Project Director, FPL Energy



LAKE REGION DISTRICT HEALTH UNIT

524 4th Avenue NE Unit 9
Devils Lake, ND 58301-2490
(701) 662-7035

BENSON COUNTY
201 MAIN STREET W. #3
MINNEWAUKAN, ND 58351
(701) 473-5444

EDDY COUNTY
16 S. 5th STREET
NEW ROCKFORD, ND 58356
(701) 947-5311

PIERCE COUNTY
240 SE 2nd STREET
RUGBY, ND 58368
(701) 776-6783

October 18, 2007

Florida Power & Light
Langdon Wind Farm
Langdon, ND

Dear Sirs:


I, Allen McKay, Environmental Health Supervisor with the Lake Region District Health Unit, reviewed Jason Bruce's sewer design for the wind farm. I call Mr. Bruce on 10/18/07 to inquire whether the insulation over the trenches was a good technique in this particular situation, and whether or not the use of plastic drop boxes would be acceptable. Mr. Bruce stated that he agreed in this situation that insulating the trenches would not be a good idea and plastic drop boxes would work fine.

This design with the above mentioned changes meets all current state codes for onsite sewer design. If you have any questions please call me at 701-662-7035.

Sincerely,

Allen R. McKay, RS
Environmental Health Supervisor


Cc: Dennis Gleason





GENERAL NOTES

1. THE CONTRACTOR SHALL VERIFY THE LOCATION OF ALL UTILITIES AND SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM ALL APPLICABLE AGENCIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM ALL APPLICABLE AGENCIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM ALL APPLICABLE AGENCIES.
2. EXISTING UTILITIES AND UNDERGROUND SERVICES SHALL BE IDENTIFIED AND MARKED PRIOR TO CONSTRUCTION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM ALL APPLICABLE AGENCIES.
3. ALL UTILITY OWNER CONSENTS TO ALL FACILITIES AT ALL TIMES.


EXISTING
 OPERATION AND
 MAINTENANCE
 BUILDING




	LANGDON WIND FARM OPERATION AND MAINTENANCE BUILDING SEPTIC SYSTEM D.H. BLATTHNER & SONS, INC.	SHEET NO. 1 OF 3
	SITE PLAN	DATE: 10/20/14



1 SEPTIC TANK
 2 SCALE NONE





NOTE:
 1. TANK DIMENSIONS SHOWN ARE MINIMUM REQUIRED DIMENSIONS. DIMENSIONS MAY VARY TO PROVIDE A PROTECTED TANK SYSTEM WHICH MEETS OR EXCEEDS DESIGN DIMENSIONS.
 2. ANY PART OF THE EXTERIOR SEPTIC SYSTEM WITHIN A FEET OF THE FINISHED GROUND SURFACE SHALL BE COVERED WITH INSULATION ABOVE IT, AND THE SIDE OF THE PIPING.




Advanced Engineering and Environmental Services, Inc. • 2016 Washington Street South, Grand Forks, ND • (701-746-8037) (701-746-0310) • www.aes2a.com

2	LANGDON WIND FARM OPERATION AND MAINTENANCE BUILDING SEPTIC SYSTEM D.H. BLATTNER & SONS, INC.		REGISTERED PROFESSIONAL ENGINEER NORTH DAKOTA Jason Bruce No. 53348 Date 9/18/10
	PROJECT NO.		DATE
	DRAWN BY		CHECKED BY



Advanced Engineering and Environmental Services, Inc. • 2016 Washington Street South, Grand Forks, ND • (701) 748-8087 • (701) 748-0370 • www.aes2s.com



NOTE: GROUP THROUGH STRUCTURE ONLY APPLIES TO THE
 FIRST ABSORPTION BOX. ALL OTHERS ARE COULDED LEVEL.

