



REV	DESCRIPTION	DRWN	DSGN	APPD	DATE	REV	DESCRIPTION	DRWN	DSGN	APPD	DATE
1	ISSUE FOR BID	CDB	CDB	DAM	10/19/09	5	MOVED STRUCTURE 051 BACK 10 FEET TO ORIGINAL STA 389+50	CDB	CDB	DAM	07/12/10
2	ISSUED FOR CONSTRUCTION	CDB	CDB	DAM	02/03/10	6	AS-BUILT	CDB	CDB	DAM	02/25/11
3	MODIFIED CROSSING TEXT AND MILE INFORMATION	CDB	CDB	DAM	03/11/10						
4	MOVED STRUCTURE 051 AHEAD 10 FEET TO 389+60	CDB	CDB	DAM	06/03/10						

STATE NAME: NORTH DAKOTA		NAD83 NDSPCS INTL FT NORTH ZONE				DESIGN BY: DAM/CDB	10/12/09
DESIGN INFORMATION						DRAWN BY: CDB	10/12/09
CONDUCTOR	1272 MCM 45/7 ACSR	STRINGING TENSION	6501	NESC TENSION	12617	DESIGN R.S.	900
OPGW	AC-71/571		2277		6131	DESIGN CHK: MBN ENGRG.	01/08/10
						DRAFT CHK:	
						APPROVED: DAM	10/12/09
FACILITY: TRANSMISSION SYSTEM MAINTENANCE		LOCATION UNIT: 296-230KV LINE-WILLISTON SUBSTATION TO TIOGA SUBSTATION		WILLISTON TO TIOGA 230KV TRANSMISSION LINE			
SCALE: AS SHOWN		COUNTY NAME: WILLIAMS		BASIN DRAWING NO. 296-090-T3-008			
MILE 6 & 7		REV.		6			