



REV	DESCRIPTION	DRWN	DSGN	APPD	DATE	REV	DESCRIPTION	DRWN	DSGN	APPD	DATE
1	ISSUE FOR BID	CDB	CDB	DAM	10/27/09						
2	ISSUED FOR CONSTRUCTION	CDB	CDB	DAM	02/03/10						
3	MODIFIED CROSSING TEXT AND MILE INFORMATION	CDB	CDB	DAM	03/11/10						
4	AS-BUILT	CDB	CDB	DAM	03/07/11						

  

DESIGN INFORMATION					
CONDUCTOR	SIZE	STRINGING TENSION	NESC TENSION	DESIGN R.S.	ACTUAL R.S.
	1272 MCM 45/7 ACSR	6501	12617	800	830
	OPGW	AC-71/571	2285	5932	800

  

DESIGN BY: DAM/CDB		10/12/09
DRAWN BY: CDB		10/12/09
DESIGN CHK: MBN ENGRG.		01/08/10
DRAFT CHK:		
APPROVED: DAM		10/12/09

  

FACILITY: TRANSMISSION SYSTEM MAINTENANCE	
LOCATION UNIT: 296-230KV LINE-WILLISTON SUBSTATION TO TIOGA SUBSTATION	
WILLISTON TO TIOGA 230KV TRANSMISSION LINE	
SCALE: AS SHOWN	
COUNTY NAME: WILLIAMS	
BASIN DRAWING NO. 296-090-T3-034	
REV. 4	