



REV	DESCRIPTION	DRWN	DSGN	APPD	DATE
1	ADDED DISTRIBUTION CROSSING AT 2832+63. ISSUE FOR BID	CDB	CDB	DAM	10/15/09
2	ISSUED FOR CONSTRUCTION	CDB	CDB	DAM	02/03/10
3	MODIFIED CROSSING TEXT AND MILE INFORMATION	CDB	CDB	DAM	03/11/10
4	AS-BUILT	CDB	CDB	DAM	03/07/11

REV	DESCRIPTION	DRWN	DSGN	APPD	DATE
1	ADDED DISTRIBUTION CROSSING AT 2832+63. ISSUE FOR BID	CDB	CDB	DAM	10/15/09
2	ISSUED FOR CONSTRUCTION	CDB	CDB	DAM	02/03/10
3	MODIFIED CROSSING TEXT AND MILE INFORMATION	CDB	CDB	DAM	03/11/10
4	AS-BUILT	CDB	CDB	DAM	03/07/11

DESIGN INFORMATION		DESIGN BY:	DATE
CONDUCTOR	1272 MCM 45/7 ACSR	DAM/CDB	10/12/09
OPGW	AC-71/571	CDB	10/12/09
STRINGING TENSION	6555	DESIGN CHK:	01/08/10
NESC TENSION	12617	DRAFT CHK:	
DESIGN R.S.	750	APPROVED:	DAM 10/12/09
ACTUAL R.S.	774		

STATE NAME: NORTH DAKOTA	NAD83 NDSPCS INTL FT NORTH ZONE	DESIGN BY: DAM/CDB	10/12/09
DESIGN INFORMATION		DRAWN BY: CDB	10/12/09
CONDUCTOR	1272 MCM 45/7 ACSR	DESIGN CHK: MBN ENGRG.	01/08/10
OPGW	AC-71/571	DRAFT CHK:	
STRINGING TENSION	6555	APPROVED: DAM	10/12/09
NESC TENSION	12617		
DESIGN R.S.	750		
ACTUAL R.S.	774		

FACILITY: TRANSMISSION SYSTEM MAINTENANCE  
 LOCATION UNIT: 296-230KV LINE-WILLISTON SUBSTATION TO TIOGA SUBSTATION  
**WILLISTON TO TIOGA 230KV TRANSMISSION LINE**  
 SCALE: AS SHOWN  
 COUNTY NAME: WILLIAMS  
 BASIN DRAWING NO. 296-090-T3-055  
 REV. 4