

Lein, Jerry R.

From: Brian Bjella [brbjella@flecklaw.com]
Sent: Friday, March 28, 2008 4:53 PM
To: Lein, Jerry R.
Cc: Binek, William W.
Subject: Langdon Wind-Case No. PU-07-722

Jerry & Bill-

This report is submitted for filing in the above case as late filed exhibits Nos. 3 and 6.

Late filed exhibit #3-The Commission requested a report of turbines within 130 feet of the project boundary as stated on Table 9 (page 18) of the application. Langdon Wind has determined that there are no turbines within 130 feet of the project boundary. The nearest turbine to any project boundary is #3, which is 460 feet from the project boundary. All other turbines are at greater distances from the project boundary.

Late filed exhibit #6- The Commission requested a report clarifying section 7.6.1 (page 34) of the application, as to whether the dBA levels for rural residences are measured inside or outside of the residences. Langdon Wind reports that dBA levels are measured at the outside perimeter of the residences.

21 **PU-07-722** Filed: 3/28/2008 Pages: 1
Late Filed Exhibits Nos. 3 and 6

Langdon Wind, LLC