

STATE OF NORTH DAKOTA
PUBLIC SERVICE COMMISSION

M-Power, LLC
230 kV Transmission Line Barnes/Steele County
Siting Application

Case No. PU-08-107

AFFIDAVIT OF SERVICE REGULAR, EMAIL OR INSIDE MAIL

STATE OF NORTH DAKOTA
COUNTY OF BURLEIGH

Janet Marquart deposes and says that:

she is over the age of 18 years and not a party to this action and, on the 6th day of **November, 2008**, she deposited in the United States Mail, Bismarck, North Dakota, 34 envelopes by first class mail, fully prepaid, securely sealed, and 18 envelopes by Inside Mail, each containing a photocopy, and 46 electronic mail messages, each with an attached electronic copy of:

Findings of Fact, Conclusions of Law and Order
Certificate of Site Compatibility Number 106
Route Permit No. 116


The envelopes and electronic mails respectively were addressed as follows:

See attached list.

Each post office address shown is the respective addressee's last reasonably ascertainable post office address and each email address is the respective addressee's last reasonably ascertainable electronic mailing address.

Subscribed and sworn to before me
this 6th day of **November, 2008**.

SEAL



Janet Marquart

John G. Hamre

Notary Public

Steven Tomac

2498 59th St
St Anthony ND 58566-9640

Roger Johnson
Agriculture Department
State Capitol
Bismarck ND 58505

Arvid Barstad
Cementing Service
710 W 15th St
Williston ND 58801

Will Kaul
Cooperative Power Association
P O Box 800
Elk River MN 55330-0800

Dennis Lavallee
Council Construction Consumers
180 S. Weidman Ste. 127
Ballwin MO 63021-5724

Department of Commerce
1600 E Century Ave Ste 20
Bismarck ND 58503-0649

Dept of Career and Technical Education
State Capitol
Bismarck ND 58505

Jeff Engleson
Energy Development Impact Office
1707 N 9th St
Bismarck ND 58501

John Hoeven
Governor's Office
State Capitol
Bismarck ND 58505

Jay Casler
INDEPTH DATA INC
44 S Bdwy 18th Fl
White Plains NY 10601-4425

Stanley Wright

Box 97
Stanley ND 58784-0097

Mike Hummel
BNI Coal, Ltd.
PO Box 897
Bismarck ND 58502-0897

Bob Fogarty
Cenex Minot Terminal
Box 429
Minot ND 58701-0429

Todd Lindquist
Corp of Engineers
PO Box 527
Riverdale ND 58565-0527

Dakota Resource Council
PO Box 1095
Dickinson ND 58602-1095

Carol Olson
Department of Human Services
State Capitol
Bismarck ND 58505

J Williams
Dome Pipeline Corporation
2959 Sierra Ct SW
Iowa City IA 52246

Cathy Callahan
Geo Resources Inc
PO Box 1505
Williston ND 58801-1505

Historical Society
North Dakota Heritage Center
Bismarck ND 58505

Indian Affairs Commission
State Capitol
Bismarck ND 58505

News Director
KHND AM Radio
PO Box 6
Harvey ND 58341-0006

Harvey Ness
Lignite Energy Council
PO Box 2277
Bismarck ND 58502-2277

Dave Goodin
Montana-Dakota Utilities Co
400 North 4th Street
Bismarck ND 58502-1457

Galen Anderson
Nakota Company
PO Box 1633
Bismarck ND 58502-1633

Mike Foley
NARUC
1101 Vermont Avenue NW Ste 200
Washington DC 20005

James Irwin
Natural Gas Week
1411 K Street Suite 602
Washington DC 20005-3404

Thomas Hanson
ND Assoc of Soil Conservation Dist
3310 University Drive
Bismarck ND 58504-7564

Harlan Fuglesten
ND Association of RECs
PO Box 727
Mandan ND 58554-0727

Francis G Ziegler, P.E.
ND Department of Transportation
State Highway Building
Bismarck ND 58505

MR ED MURPHY
ND GEOLOGICAL SURVEY
INSIDE MAIL

Maren Daley
ND Job Service
P.O. Box 5507
Bismarck ND 58506-5507

Lisa K Fair-McEvers
ND Labor Dept
600 E Blvd Ave

Mike Haupt
ND Land Department
1707 N 9th St
Bismarck ND 58501

Doug Prchal
North Dakota Parks & Rec
1600 E Century Ave Ste 3
Bismarck ND 58503-0649

Wes Wiedenmeyer
NRCS
Box 1458
Bismarck ND 58502-1458

Wayne Stenehjem
Office of Attorney General
State Capitol
Bismarck ND 58505

OMB
600 E. Boulevard Dept. 110
Bismarck ND 58505-0406

Public Utilities Reports Inc
Law Dept 8229 Boone Blvd Ste 401
Vienna VA 22182

Dale Frink
State Engineer
ND Water Commission 900 East Boulevard
Bismarck ND 58505

State Health Department
State Capitol
Bismarck ND 58505

Janell Cole Capitol Reporter
The Forum
Inside Mail

John Kapsner
The Vogel Law Firm
P O Box 2097
Bismarck ND 58502-2097

Chief of Resource Management
Theodore Roosevelt National Park
P O Box 7
Medora ND 58645-0007

Valerie Naylor
Theodore Roosevelt Nat'l Park
PO Box 7
Medora ND 58645

M Zschomler
U S Fish & Wildlife
3425 Miriam Ave
Bismarck ND 58501-7926

Steve Williams
U S Forest Service
240 W Century Ave
Bismarck ND 58501-1494

District Chief
U S Geological Survey
821 E Interstate Ave
Bismarck ND 58501

District Engineer
US Army Engineer District Omaha
106 S 15th St
Omaha NE 68102-1618

Jon Cameron
Valley City Public Works
254 2nd Ave NE
Valley City ND 58072

Brian Morris
Western Area Power Administration
PO Box 1173
Bismarck ND 58502-1173

Keith Tiggelaar
Williston Basin Interstate Pplne Co
P O Box 5601
Bismarck ND 58506-5601

Paul Lehman
Xcel Energy
414 Nicollet Mall
Minneapolis MN 55401-1993

ndaero@nd.gov
Melinda Weninger
Aeronautics Commission
PO Box 5020
Bismarck ND 58502-5020

colson@bepc.com
Clare Olson
Basin Electric Power Coop
1717 E Interstate Ave
Bismarck ND 58501-0564

carp1091@qwest.net
Robert Colton
Carpenters Union
217 S Mandan St
Bismarck ND 58504-5516

bschmidt@kwh.com
Brad Schmidt
Cass County Electric Coop
4100 32nd Ave SW
Fargo ND 58104

jmittleider@nd.gov
John Mittleider
Department of Commerce
600 East Blvd
Bismarck ND 58505

jwmorris@flecklaw.com
John Morrison
Fleck Mather & Strutz, Ltd.
PO Box 2798
Bismarck ND 58502-2798

dsaggau@GREnergy.com
Davic Saggau
Great River Energy
P O Box 800
Elk River MN 55330-0800

nlange@iwla.org
Nancy Lange
Izaak Walton League of America
1619 Dayton Ave Ste 202
St Paul MN 55104

sanditabor@lignite.com
Sandi Tabor
Lignite Energy Council
PO Box 2277
Bismarck ND 58502-2277

harking@oz.net
Harriet King
McGraw-Hill/Platts

apbismarck@ap.org
Phyllis Mensing
Associated Press
PO Box 1018
Bismarck ND 58502-1018

rharper@bepc.com
Ron Harper
Basin Electric Power Coop
1717 E Interstate Ave
Bismarck ND 58501-0564

shandy@kwh.com
Scott Handy
Cass County Electric Coop
4100 32nd Ave SW
Fargo ND 58104

bnicholls@dadco.com
Bryan Nicholls
D A Davidson & Co

brbjella@flecklaw.com
Brian R. Bjella
Fleck Mather & Strutz, Ltd.
PO Box 2798
Bismarck ND 58502-2798

tgrove@greenergy.com
Terry Grove
Great River Energy
P O Box 800
Elk River MN 55330-0800

kander@ictc.com
Keith Anderson
Inter-Community Telephone Company LLC
PO Box 8
Nome ND 58062-0008

sales@kmavradio.com
KMAV AM/FM RADIO
PO Box 216
Mayville ND 58257-0216

jdwyer@lignite.com
John Dwyer
Lignite Energy Council
PO Box 2277
Bismarck ND 58502-2277

craig_scott@bobcat.com
Craig Scott
Melroe Company
P O Box 128
Gwinner ND 58040-0128

dloer@minnkota.com
David W. Loer
Minnkota Power Cooperative, Inc
Box 13200
Grand Forks ND 58208-3200

don.ball@mdu.com
Don Ball
Montana-Dakota Utilities Co
400 North 4th Street
Bismarck ND 58502-1457

ronness@ndoil.org
N D Petroleum Council
PO Box 1395
Bismarck ND 58502-1395

hfuglest@ndarec.com
Harlan Fugelsten
ND Assn Rural Electric Coops
PO Box 727
Mandan ND 58554-0727

kchristianson@state.nd.us
Kim Christianson
ND Department of Commerce

Bismarck ND

julie.tessier@thomson.com
Julie Tessier
Netscan

jim.melchior@coteau.com
Jim Melchior
North American Coal Corp
2000 Schafer St Ste D
Bismarck ND 58501-1204

pat@ndta.net
Patricia Gisinger
North Dakota Telephone Assoc
PO Box 2614
Bismarck ND 58502-2614

rdenault@otpc.com
Russ Denault
Otter Tail Corporation
410 College Ave
Crookston MN 56716

dloer@minnkota.com
David Loer
Square Butte Elec Coop
PO Box 13200
Grand Forks ND 58208-3200

phillip.franklin@minot.af.mil
Lt. Col. Phil Franklin
Minot Air Force Base 91st Missile Wing
300 Minuteman Drive, Ste 101
Minot AFB ND 58705-5016

karen.collins@mdu.com; tamie.aberle@mdu.com
Karen Collins
Montana-Dakota Utilities Co
400 North 4th Street
Bismarck ND 58502-1457

jpaczkowski@state.nd.us
John Paczkowski
N D Water Commission
900 E Boulevard
Bismarck ND 58505

tom@ndcorn.org
Tom Lilja
ND Corn Utilization Council
1325 23rd ST S
Fargo ND 58103

tsteinwa@nd.gov
MR TERRY STEINWAND
ND GAME & FISH DEPT
INSIDE MAIL

carla.deutsch@thomson.com
Carla Deutsch
Netscan

asap@bis.midco.net
Allyn Sapa
North Dakota Chapter of the Wildlife Society
PO Box 1442
Bismarck ND 58505-0480

beth.jensen@transcanada.com
Beth Jensen
Northern Border Pipeline Company
PO Box 3330
Omaha NE 68103-0330

lakeleader@aol.com
John M Wylie II
Platts Electric Power Publications
109 S Maple St
Oologah OK 74053-1175

mdickerson@nd.gov
Marcy Dickerson
State Tax Department
State Capitol
Bismarck ND 58505

john.irby@bismarcktribune.com
John Irby, Editor
The Bismarck Tribune
PO Box 5516
Bismarck ND 58502-5516

news@wdaz.com

WDAZ-TV
PO Box 12639
Grand Forks ND 58208-2639

mark.nisbet@xcelenergy.com
Mark Nisbet
Xcel Energy
PO Box 2747
Fargo ND 58108-2747

kjvannin@usgs.gov
K Vannin
U S Geological Survey

keith.tiggelaar@wbip.com
Keith Tiggelaar
Williston Basin Interstate Pplne Co
P O Box 5601
Bismarck ND 58506-5601

dave.sederquist@xcelenergy.com
Dave Sederquist
Xcel Energy
PO Box 2747
Fargo ND 58108-2747

STATE OF NORTH DAKOTA
PUBLIC SERVICE COMMISSION

M-Power, LLC
230 kV Electric Transmission Line-Steele County
Siting Application

Case No. PU-08-107

FINDINGS OF FACT, CONCLUSIONS OF LAW, AND ORDER

October 30, 2008

Appearances

Commissioners Susan E. Wefald, Tony Clark, and Kevin Cramer.

Lawrence Bender, Fredrikson & Byron, P.A., 200 North 3rd Street, Suite 150, Bismarck, North Dakota 58501 on behalf of the Applicant, M-Power, LLC

Annette Bendish, Counsel, North Dakota Public Service Commission, State Capitol Building, 12th Floor, Bismarck, North Dakota 58505, on behalf of the North Dakota Public Service Commission.

Al Wahl, Administrative Law Judge, Office of Administrative Hearings, 1701 North Ninth Street, Bismarck, ND 58501-1882, as Procedural Hearing Officer.

Preliminary Statement

On March 3, 2008, M-Power, LLC (M-Power) filed a Letter of Intent (LOI) with the Commission indicating that it planned to file applications for both a certificate of corridor compatibility and a route permit for the proposed transmission facilities.

On April 4, 2008, the Commission acknowledged the filing of the LOI, shortened the one-year notice period to one day and assessed a filing fee of \$22,750 due upon the filing of the application.

On May 21, 2008, M-Power filed a consolidated application for a waiver of procedures and times schedules, a certificate of corridor compatibility application, and a route permit application authorizing construction of approximately 13 miles of 230,000 volt (230 kV) electric transmission line collectively referred to as the proposed Luverne Wind Farm Generation Outlet in Steele and Barnes Counties, North Dakota (Application).

On June 19, 2008, the Commission deemed the application complete and issued a Notice of Filing and Notice of Hearing, scheduling a public hearing for July 28, 2008 at 10:00 a.m. CDT at the Cooperstown Country Club, 305 Fairway Drive, Cooperstown, North Dakota. The notice identified the following issues to be considered:

1. Will the location, construction, and operation of the proposed facilities produce minimal adverse effects on the environment, and upon the welfare of the citizens of North Dakota?
2. Are the proposed facilities compatible with the environmental preservation and the efficient use of resources?
3. Will the proposed facility locations minimize adverse human and environmental impact while ensuring continuing system reliability and integrity and ensuring that energy needs are met and fulfilled in an orderly and timely fashion?
4. Is it appropriate for the Commission to waive the procedures as requested including the request for a single consolidated application for corridor certificate and route permit?

The Commission held the public hearing on M-Power's Application as scheduled on July 28, 2008 in Cooperstown, North Dakota. Following the hearing, the Commission received from M-Power certain late filed exhibits as requested at the hearing.

Having allowed all interested persons an opportunity to be heard and having heard, reviewed, and considered all testimony and evidence presented, the Commission makes the following:

Findings of Fact

1. M-Power is a North Dakota limited liability company headquartered in Finley, North Dakota. The 230 kV transmission line proposed by M-Power in this Application would interconnect with M-Power's proposed Luverne Wind Farm (Case No. PU-08-34.)
2. The proposed 230 kV, 3-phase, alternating current electric transmission line will be located in Steele and Barnes Counties, North Dakota, and will be approximately 13 miles in length extending from M-Power's Luverne Wind Farm collector substation to an interconnection with a new Pillsbury-Fargo transmission line and Pillsbury substation under construction by Minnkota Power Cooperative, Inc. (Case No. PU-08-48)
3. Otter Tail Corporation has filed an application for a certificate of public convenience and necessity to construct and own the proposed 230 kV transmission line along with a portion of the proposed Luverne Wind Farm. That application is pending before the Commission. (Case No. PU-08-766)

4. The proposed transmission line will be constructed using wood H-frame structures. Each structure will be approximately 60 feet in height with an average span between each structure of 750 feet.

5. The proposed transmission line will be designed and constructed to meet or surpass all relevant state codes, as well as the National Electric Safety Code, the Rural Utilities Service, the Avian Power Line Interconnection Committee, the Raptor-Safe Design standards, and M-Power company standards.

6. The total cost of construction of the M-Power proposed transmission facility is approximately \$4.55 million.

7. Section 49-22-16(3) of the North Dakota Century Code provides that an applicant for a route permit from the Commission shall obtain all permits that may be required to construct and operate the transmission facility.

8. M-Power's application and supplemental filings contain a listing of permits and approvals that must be obtained for M-Power's proposed transmission facility and the status of each of these permits or approvals.

9. The federal, state and local departments, agencies, and entities that were consulted by M-Power and provided comment during the application process are:

- a. Federal Agencies – Bureau of Indian Affairs; Federal Aviation Administration; National Park Service; United States Air Force, Grand Forks Air Force Base; United States Army Corps of Engineers, North Dakota Regulatory Office; United States Army Corps of Engineers, St. Paul District Office; United States Fish and Wildlife Service
- b. State Agencies – Job Service North Dakota, North Dakota Department of Commerce, North Dakota Department of Health, North Dakota Department of Transportation, North Dakota Game and Fish Department, North Dakota Office of the Attorney General, North Dakota Parks and Recreation Department, North Dakota State Water Commission, Senator Kent Conrad, State Historical Society of North Dakota
- c. Local Entities – Dakota Rural Water District, Steele County, Barnes County, Sisseton Wahpeton Oyate Tribal Historic Preservation Officer, Universal Ensco, Inc.

10. Chapter 69-06-08 of the North Dakota Administrative Code sets forth certain criteria to guide the Commission in evaluating the suitability of granting an application for a certificate of corridor compatibility and route permit. The criteria as set forth in Section 69-06-08-02 of the North Dakota Administrative Code are classified as Exclusion Areas, Avoidance Areas, Selection Criteria, and Policy Criteria. A transmission facility route shall not be sited within an Exclusion Area. A transmission

facility route shall not be sited within an Avoidance Area unless the applicant shows under the circumstances there are no reasonable alternatives. In determining whether an Avoidance Area should be designated for a facility, the Commission may consider, among other things, the proposed management of adverse impacts; the orderly siting of facilities; system reliability and integrity; the efficient use of resources; and alternative routes. In accordance with the Commission's Selection Criteria, a transmission route shall be approved only if it is demonstrated that no significant adverse impacts will result from the location, construction, and maintenance of the transmission facility. In accordance with the Commission's Policy Criteria, preference may be given to an applicant demonstrating certain benefits of the transmission facility.

11. The corridor and route proposed by M-Power for its transmission facility does not include any geographical areas listed as Exclusion Areas.

12. The corridor and route proposed by M-Power for its transmission facility does not include any geographical areas listed as Avoidance Areas except that there are several inhabited residences within the proposed corridor, none of which are within 500 feet of the proposed route.

13. M-Power has completed both a Class I record search, and a Class III pedestrian survey for archeological and cultural resources for a width of 150 feet along the proposed route. Neither the Class I nor Class III searches revealed any sites thought to be eligible for the National Register of Historic Places. The State Historic Preservation Officer (SHPO) concurred with a "No Significant Sites Affected" determination.

14. The proposed route will result in the loss of a minimal amount of woodlands. Those woodlands primarily consist of field or farmstead windbreaks. Structure placement was requested by landowners to minimize impacts to row crop farming. Consistent with the rules and regulations of the Commission, M-Power has agreed that it will replace any destroyed trees or woody vegetation on a two-for-one basis with saplings that are two or more years old.

15. M-Power conducted a wetland delineation of the proposed route. There are numerous wetlands within the proposed corridor. M-Power's proposed structure placement along the proposed route is such that no wetland will be impacted by the proposed route. The U.S. Fish & Wildlife Service (USFWS) has preliminarily reviewed the wetland delineation and transmission structure placement and does not anticipate impacts to wetlands on USFWS easements. M-Power intends to acquire all the necessary approvals from the USFWS and US Army Corps of Engineers before commencement of construction of its proposed transmission facility.

16. M-Power submitted substantial evidence to demonstrate that the proposed transmission facility would not have any significant impact on the Selection Criteria set forth in Section 69-06-08-01(3) of the North Dakota Administrative Code.

17. M-Power submitted substantial evidence to demonstrate its commitment to maximize the benefits of the proposed transmission facility as much as is possible to

meet the Policy Criteria set forth in Section 69-06-08-01(4) of the North Dakota Administrative Code.

18. The route for the proposed 13 mile 230 kV transmission line is located within a highly rural area. There is no information to indicate that any new residential construction is contemplated within the corridor or route.

19. The route for the proposed 13 mile 230 kV transmission line crosses areas that are primarily agricultural land. There are several areas within the proposed route where tree and shrub growth may require right-of-way clearing. Significant amounts of grading are not contemplated for preparation of the proposed transmission line right of way.

20. The proposed 13 mile 230 kV transmission line is not anticipated to result in any negative impacts to public services such as local services, electric service, roads, traffic, water supply or telephone and other communication services.

21. M-Power's proposed transmission facility route is located approximately 900 feet from the nearest occupied residence. At that location, noise from the proposed transmission facility is expected to be below rural background noise levels.

22. No impact to the recreational resources in the area of the proposed corridor and route are anticipated by the proposed transmission facility.

23. Land use is not expected to change because of construction of the proposed transmission facility. The majority of the area under or adjacent to the transmission line will still be used for agricultural practices following construction of the line.

24. No impact to geologic and groundwater resources are anticipated because of the proposed transmission line.

25. Temporary impacts to vegetation will occur in the right of way area and around each structure location during construction of the transmission line. Permanent impact to vegetation will occur at each structure location.

26. No rare or unique resources have been identified along the route. It is not anticipated that the proposed transmission facility will impact rare and unique resources. Raptors, waterfowl, and other bird species may be affected by the construction and placement of the proposed 230 kV transmission line. The proposed route is located outside of the 180 mile-wide whooping crane migration corridor where 95% of Whooping Crane sightings in North Dakota have occurred. To help avoid potential impacts to avian species along the proposed route during construction and operation of the transmission line, M-Power will utilize suspension insulation with a clearance of approximately 84 inches in order to eliminate the potential for electrocution of raptors. In addition, M-Power will utilize ball markers along the line in areas of concentrated wetlands and at stream crossings to reduce the possibility of collisions.

27. On July 10, 2008, the Barnes County Board of County Commissioners granted M-Power a conditional use permit for the proposed transmission line.

From the foregoing Findings of Fact, the Commission now makes its:

Conclusions of Law

1. The Commission has jurisdiction over this proceeding under Chapter 49-22 of the North Dakota Century Code.
2. The 230 kV transmission line proposed by M-Power is a transmission facility as defined in Section 49-22-03(12) of the North Dakota Century Code.
3. The proposed project is of such design, location and purpose that it will produce minimal adverse effects, as defined under Section 49-22-05.2 of the North Dakota Century Code.
4. The Application submitted by M-Power meets the corridor and route evaluation criteria required by Chapter 49-22 of the North Dakota Century Code.
5. The location, construction, and operation of the proposed transmission facility will produce only minimal adverse effects of the environment and upon the welfare of the citizens of North Dakota.
6. The proposed transmission facility is compatible with the environmental preservation and the efficient use of resources.
7. The proposed transmission facility corridor and route will minimize adverse human and environmental impact while ensuring continuing system reliability and integrity and ensuring that energy needs are met and fulfilled in an orderly and timely fashion.
8. The proposed transmission facility is of such length, design, location, and purpose that it will produce minimal adverse effects.

From the foregoing Findings of Fact and Conclusions of Law, the Commission now makes its:

Order


The Commission orders:


1. M-Power's application for a waiver of procedures and time schedules is granted.
2. Certificate of Compatibility for a Transmission Facility Corridor No. 106 is issued to M-Power, designating a Corridor for its proposed transmission facility route.

3. Route Permit for Construction of a Transmission Facility No. 107 is issued to M-Power granting authority to construct the transmission facility as described in the application and presented at the hearing.
4. M-Power shall conduct a preconstruction conference prior to commencement of any construction, and must include an M-Power representative, its construction supervisor, and a representative of Commission staff to ensure that M-Power fully understands the conditions set forth in this order.
5. M-Power shall comply with the rules and regulations of all other agencies having jurisdiction over any phase of the proposed transmission facility. Prior to commencing construction of any phase of the proposed project, M-Power shall obtain all other necessary approvals and permits for construction of such phase, and provide copies to the Commission prior to the construction of each such phase.
6. M-Power shall inform the Commission of its intent to start construction on the transmission facility prior to the commencement of construction, and, once construction has started, M-Power shall keep the Commission updated of construction activities on a weekly basis.
7. M-Power shall construct and operate the transmission facility in the manner described in its Application and at the hearing, and in accordance with all applicable safety requirements.
8. M-Power shall promptly report to the Commission the presence in the permit area of any critical habitat of threatened or endangered species, or of bald or golden eagles that M-Power becomes aware of and that were not previously reported to the Commission.
9. If any cultural resource, paleontological site, archeological site, historical site, or gravesite is discovered during construction of the facility, earth disturbing activities in the immediate vicinity of the discovery must be halted. The resources must be marked, preserved, and protected from further disturbance until a professional examination can be made in consultation with the North Dakota State Historic Preservation Officer (SHPO) and clearance to proceed is given by SHPO. A report of such examination must be filed with the Commission.
10. All pre-existing roads and lanes used during construction must be restored to a condition that will accommodate their previous use and areas used as temporary roads during construction must be restored to their original condition.
11. Construction must be suspended when weather conditions are such that construction activities will cause irreparable damage, unless adequate protection measures approved by the Commission are taken.

12. Reclamation along the right-of-way shall be continuous and coordinated with construction.
13. Reclamation, fertilization and reseeding is to be done by M-Power according to the Natural Resource Conservation Service or USFWS recommendations for CRP, native prairie and other non-cropped lands unless otherwise specified by the landowner and approved by the Commission. M-Power's obligation for reclamation and maintenance of the right-of-way shall continue throughout the life of the transmission line.
14. M-Power shall comply with the Commission's Tree and Shrub Mitigation Specifications attached to this Order, except that the width of clear cuts through windbreaks, shelterbelts and all other wooded areas shall be limited to 125 feet rather than 50 feet.
15. M-Power shall work with landowners and residents to mitigate any increase in television and residential radio interference that results from the transmission line.
16. M-Power shall repair or replace all fences and gates removed or damaged during all phases of construction and operation of the proposed transmission facility.
17. M-Power shall obtain approval from the Commission or from Commission staff prior to any changes in structure locations.
18. M-Power shall provide the Commission with a copy of the design specifications for construction of the transmission line showing the location of the transmission line as built within three months of the completion of construction.
19. The authorizations granted by the corridor certificate and route permit are subject to modification by order of the Commission if deemed necessary to further protect the public or the environment.

PUBLIC SERVICE COMMISSION


Tony Clark
Commissioner


Susan E. Wefald
President


Kevin Cramer
Commissioner

STATE OF NORTH DAKOTA
PUBLIC SERVICE COMMISSION

M-Power, LLC
Electric Generation/Wind – Griggs/Steele
County
Siting Application

Case No. PU-08-34

M-Power, LLC
230 kV Transmission Line Barnes/Steele County
Siting Application

Case No. PU-08-107

Tree and Shrub Mitigation Specifications

Inventory

1. Trees and shrubs anticipated to be cleared, including those that are considered invasive species or noxious weeds (e.g., *Caragana arborescens*, *Elaeagnus angustifolia*, *Rhamnus cathartica*, *Tamarix chinensis*, *T. parviflora*, *T. ramosissima*, *Ulmus pumila*), shall be inventoried before cutting. The inventory shall record the location, number, and species of trees and shrubs.
2. In windbreaks, shelterbelts, and other planted areas, trees or shrubs anticipated to be cleared, regardless of size, shall be inventoried for replacement.
3. In native growth areas, trees anticipated to be cleared that are 1-inch diameter at breast height (dbh) or greater shall be inventoried for replacement.
4. In native growth areas, shrubs anticipated to be cleared in the permanent right-of-way shall be inventoried for replacement.
5. In native growth areas outside the permanent right-of-way, shrubs shall be cut flush with the surface of the ground, taking care to leave the naturally occurring seed bank and root stock intact. If soil disturbance is necessary, the native topsoil shall be preserved and replaced after construction. Shrubs shall be allowed to regenerate naturally where native topsoil is preserved and replaced. Where native topsoil is not preserved and replaced, shrubs anticipated to be cleared shall be inventoried for replacement.
6. In native growth areas, trees and shrubs may be inventoried by actual count or by sampling method that will properly represent the woody vegetation population. A sampling plan developed by the company, filed with the North Dakota Public Service Commission (Commission), and approved prior to the start of construction shall define the sampling method to be used for trees, for tall shrubs and for low shrubs. The data from the sample plots shall be extrapolated to the total acreage of the wooded area to be cleared to determine the species and quantity of trees and shrubs to be replaced.

Clearing for Construction

7. Trees and shrubs shall be selectively cleared, leaving mature trees and shrubs intact where practical.

8. The width of clear cuts through windbreaks, shelterbelts and all other wooded areas shall be limited to 50 feet or less unless otherwise approved by the Commission.

9. If the area of trees or shrubs actually cleared differs from the area inventoried, the difference in number of trees and shrubs to be replaced shall be noted on the inventory.

Replacement

10. Prior to replacement, documentation identifying the number and variety of trees removed as well as the mitigation plan for the proposed number, variety, type, location and date of replacement plantings shall be filed with the Commission for approval.

11. Tree replacement shall be on a 2 to 1 basis with 2-year-old saplings. Shrub replacement shall be on a 2 to 1 basis with stem cuttings.

12. Trees and shrubs shall be replaced by the same species or similar species suitable for North Dakota growing conditions as recommended by the North Dakota Forest Service.

13. Landowners shall be given the option of having replacement trees/shrubs planted off the right-of-way on the landowner's property or waiving that requirement in writing and allowing those replacement trees or shrubs to be planted at alternative locations.

14. At the conclusion of the project, documentation identifying the actual number, variety, type, location, and date of the replacement plantings shall be filed with the Commission.

15. Tree and shrub replacements shall be inspected once a year for three years, on about the anniversary of the plantings, and, on or shortly before October 1 of each year, a report shall be submitted to the Commission documenting the condition of replacement planting and any woodlands work completed. If after three years from the anniversary of the plantings the survival rate is less than 75%, the Commission may order additional planting(s).

PUBLIC SERVICE COMMISSION

STATE OF NORTH DAKOTA

Certificate of Site Compatibility for a Transmission Facility Corridor

Certificate Number 106


This is to certify that the Commission has designated a transmission facility corridor for M-Power, LLC's approximately 13 miles of 230 kV 3-phase alternating current transmission line in Barnes and Steele Counties of North Dakota.

This certificate is issued in accordance with the Order of this Commission dated October 30, 2008 in Case No. PU-08-107 and is subject to the conditions and limitations noted in the Order.


Bismarck, North Dakota, October 30, 2008.

ATTEST:

PUBLIC SERVICE COMMISSION



Executive Director



Commissioner

PUBLIC SERVICE COMMISSION

STATE OF NORTH DAKOTA

Route Permit No. 116

This is to certify that the Commission has designated a transmission facility route for M-Power, LLC's approximately 13 miles of 230 kV, 3-phase, alternating current transmission line and associated facilities in Barnes and Steele Counties of North Dakota.


This certificate is issued in accordance with the Order of this Commission dated October 30, 2008 in Case No. PU-08-107 and is subject to the conditions and limitations noted in the Order.

Bismarck, North Dakota, October 30, 2008.

ATTEST:

PUBLIC SERVICE COMMISSION


Executive Director


Commissioner