

# MATERIAL TESTING SERVICES, LLC

PROJECT: 2009 WILLIAMS CR 9 PHASE IV AML  
WILLISTON, NORTH DAKOTA  
ND000111

REPORTED TO: AML DIVISION  
NORTH DAKOTA PUBLIC SERVICE COMMISSION  
600 EAST BOULEVARD AVENUE, DEPT. 408  
BISMARCK, NORTH DAKOTA 58505-0480

LABORATORY NUMBER: W09-044

| TEST NUMBER | LOCATION (HOLE) | DATE | TIME  | TEMP. | SLUMP | BATCH WEIGHT | UNIT WEIGHT | YIELD | TOTAL YARDS | TICKET NUMBER | 14 DAY STRENGTH | 28 DAY STRENGTH | 56 DAY STRENGTH |
|-------------|-----------------|------|-------|-------|-------|--------------|-------------|-------|-------------|---------------|-----------------|-----------------|-----------------|
| 1           | A9-1            | 7/20 | 1:15  |       |       | 25817        |             |       | 9           | 571           |                 |                 |                 |
| 2           | A9-1            | 7/20 | 2:00  |       |       | 25456        |             |       | 9           | 573           |                 |                 |                 |
| 3           | A9-1            | 7/20 | 3:00  |       |       | 25564        |             |       | 9           | 574           |                 |                 |                 |
| 4           | A9-3            | 7/21 | 1:45  | 68    | 11    | 32030        | 140.3       | 25.3  | 9           | 576           | 350             | 890             | Discard         |
| 5           | A9-3            | 7/21 | 2:26  |       |       | 32031        | 139.8       | 25.5  | 9           | 577           |                 |                 |                 |
| 6           | BF              | 7/21 | 3:44  | 67    | 10    | 22717        | 139.8       | 18.1  | 9           | 578           | 410             | 1020            | Discard         |
| 7           | BF              | 7/23 |       | 76.5  | 11    | 22671        | 135.1       | 22.8  | 9           | 581           |                 |                 |                 |
| 8           | A9-8            | 7/23 | 12:35 | 69    | 11    | 30715        | 137.8       | 24.7  | 9           | 582           | 315             | 630             | Discard         |
| 9           | A9-8            | 7/23 | 1:07  | 71    | 11.5  | 30623        | 135.9       | 25.0  | 9           | 583           |                 |                 |                 |
| 10          | A9-8            | 7/23 | 1:35  |       |       | 30681        | 135.9       | 25.0  | 9           | 584           |                 |                 |                 |
| 11          | A9-8            | 7/23 | 1:57  |       |       | 30642        | 135.9       | 25.0  | 9           | 585           |                 |                 |                 |
| 12          | A9-8            | 7/23 | 2:37  |       |       | 30651        | 135.9       | 25.0  | 9           | 586           |                 |                 |                 |
| 13          | A9-8            | 7/23 | 3:03  |       |       | 30558        | 135.9       | 25.0  | 9           | 587           | 350             | 730             | Discard         |
| 14          | A9-8            | 7/23 | 3:40  | 80    | 11.5  | 30634        | 132.7       | 25.7  | 9           | 588           |                 |                 |                 |
| 15          | A9-8            | 7/23 | 4:06  | 78.5  | 10.75 | 30437        | 132.7       | 25.5  | 9           | 589           |                 |                 |                 |
| 16          | A9-8            | 7/23 | 4:25  |       |       | 30592        | 132.7       | 25.6  | 9           | 590           |                 |                 |                 |
| 17          | A9-8            | 7/23 | 4:50  |       |       | 30582        | 132.7       | 25.6  | 9           | 591           |                 |                 |                 |
| 18          | A9-8            | 7/23 | 5:13  |       |       | 30630        | 132.7       | 25.7  | 9           | 592           |                 |                 |                 |
| 19          | A9-13           | 7/24 | 8:45  |       |       | 31008        |             |       | 9           | 593           |                 |                 |                 |
| 20          | A9-13           | 7/24 | 9:14  | 72    | 111   | 31026        | 136.7       | 25.2  | 9           | 594           | 40              | 1130            | Discard         |
| 21          | A9-13           | 7/24 | 9:35  |       |       | 31055        | 136.7       | 25.2  | 9           | 595           |                 |                 |                 |

by 

# MATERIAL TESTING SERVICES, LLC


PROJECT: 2009 WILLIAMS CR 9 PHASE IV AML  
 WILLISTON, NORTH DAKOTA  
 ND000111

REPORTED TO: AML DIVISION  
 NORTH DAKOTA PUBLIC SERVICE COMMISSION  
 600 EAST BOULEVARD AVENUE, DEPT. 408  
 BISMARCK, NORTH DAKOTA 58505-0480

LABORATORY NUMBER: W09-044

| TEST NUMBER | LOCATION (HOLE) | DATE | TIME  | TEMP. | SLUMP | BATCH WEIGHT | UNIT WEIGHT | YIELD | TOTAL YARDS | TICKET NUMBER | 14 DAY STRENGTH | 28 DAY STRENGTH | 56 DAY STRENGTH |
|-------------|-----------------|------|-------|-------|-------|--------------|-------------|-------|-------------|---------------|-----------------|-----------------|-----------------|
| 22          | A9-14           | 7/20 | 10:24 | 72    | 10.75 | 30920        | 137.75      | 24.9  | 9           | 596           |                 |                 |                 |
| 23          | A9-14           | 7/20 | 10:57 |       |       | 30836        | 137.75      | 24.9  | 9           | 597           |                 |                 |                 |
| 24          | A9-14           | 7/20 | 11:16 |       |       | 30875        | 137.75      | 24.9  | 9           | 598           |                 |                 |                 |
| 25          | A9-14           | 7/20 | 11:42 | 73    | 11    | 30875        | 135.71      | 25.3  | 9           | 599           | 380             | 940             | Discard         |
| 26          | A9-14           | 7/20 | 12:02 |       |       | 30849        | 135.71      | 25.3  | 9           | 600           |                 |                 |                 |
| 27          | A9-14           | 7/20 | 12:27 |       |       | 30725        | 135.71      | 25.2  | 9           | 601           |                 |                 |                 |
| 28          | A9-16           | 7/20 | 8:55  |       |       | 30671        | 135.71      | 25.1  | 9           | 604           |                 |                 |                 |
| 29          | A9-16           | 7/20 | 9:12  |       |       | 30698        | 135.71      | 25.1  | 9           | 605           |                 |                 |                 |
| 30          | A9-16           | 7/20 | 9:39  | 78    | 10.5  | 30766        | 136.2       | 25.1  | 9           | 606           | 310             | 610             | Discard         |
| 31          | A9-16           | 7/20 | 10:06 |       |       | 30633        | 136.2       | 25.0  | 9           | 607           |                 |                 |                 |
| 32          | A9-19           | 7/20 | 10:47 |       |       | 30736        | 136.2       | 25.1  | 9           | 608           |                 |                 |                 |
| 33          | A9-19           | 7/20 | 11:05 |       |       | 30717        | 136.2       | 25.0  | 9           | 609           |                 |                 |                 |
| 34          | A9-19           | 7/20 | 11:35 |       |       | 30718        | 136.2       | 25.0  | 9           | 610           |                 |                 |                 |
| 35          | A9-19           | 7/20 | 11:53 | 78    | 11.25 | 30800        | 135.71      | 25.2  | 9           | 611           | 290             | 580             | Discard         |
| 36          | A9-19           | 7/20 | 12:14 |       |       | 30736        | 135.71      | 25.2  | 9           | 612           |                 |                 |                 |
| 37          | A9-19           | 7/20 | 12:40 |       |       | 30792        | 135.71      | 25.2  | 9           | 613           |                 |                 |                 |
| 38          | A9-19           | 7/20 | 1:18  |       |       | 30763        | 135.71      | 25.2  | 9           | 614           |                 |                 |                 |
| 39          | A9-19           | 7/20 | 1:36  |       |       | 30717        | 135.71      | 25.2  | 9           | 615           |                 |                 |                 |
| 40          | A9-19           | 7/20 | 2:22  | 79    | 11    | 30717        | 136.12      | 25.1  | 9           | 616           | 350             | 720             | Discard         |
| 41          | A9-19           | 7/20 | 3:03  |       |       | 30745        | 136.12      | 25.1  | 9           | 617           |                 |                 |                 |
| 42          | A9-19           | 7/20 | 3:32  |       |       | 30717        | 136.12      | 25.1  | 9           | 618           |                 |                 |                 |

Material Testing Services, LLC

by 

# MATERIAL TESTING SERVICES, LLC

PROJECT: 2009 WILLIAMS CR 9 PHASE IV AML  
 WILLISTON, NORTH DAKOTA  
 ND000111

REPORTED TO: AML DIVISION  
 NORTH DAKOTA PUBLIC SERVICE COMMISSION  
 600 EAST BOULEVARD AVENUE, DEPT. 408  
 BISMARCK, NORTH DAKOTA 58505-0480

LABORATORY NUMBER: W09-044

| TEST NUMBER | LOCATION (HOLE) | DATE | TIME  | TEMP. | SLUMP | BATCH WEIGHT | UNIT WEIGHT | YIELD | TOTAL YARDS | TICKET NUMBER | 14 DAY STRENGTH | 28 DAY STRENGTH | 56 DAY STRENGTH |
|-------------|-----------------|------|-------|-------|-------|--------------|-------------|-------|-------------|---------------|-----------------|-----------------|-----------------|
| 43          | A9-19           | 7/27 | 4:00  |       |       | 30706        | 136.12      | 25.1  | 9           | 619           |                 |                 |                 |
| 44          | A9-19           | 7/27 | 4:20  |       |       | 30698        | 136.12      | 25.1  | 9           | 620           |                 |                 |                 |
| 45          | A9-19           | 7/27 | 4:45  | 78    | 11    | 30793        | 138.16      | 24.8  | 9           | 621           | 280             | 740             | Discard         |
| 46          | A9-19           | 7/27 | 5:05  |       |       | 30736        | 138.16      | 24.7  | 9           | 622           |                 |                 |                 |
| 47          | A9-19           | 7/27 | 5:30  |       |       | 30736        | 138.16      | 24.7  | 9           | 623           |                 |                 |                 |
| 48          | A9-19           | 7/28 | 8:10  |       |       | 30771        | 138.16      | 24.7  | 9           | 624           |                 |                 |                 |
| 49          | A9-19           | 7/28 | 8:36  |       |       | 30771        | 138.16      | 24.7  | 9           | 625           |                 |                 |                 |
| 50          | A9-19           | 7/28 | 9:11  | 73    | 10.75 | 30780        | 135.3       | 25.3  | 9           | 626           | 210             | 430             | Discard         |
| 51          | A9-19           | 7/28 | 9:37  |       |       | 30741        | 135.3       | 25.2  | 9           | 627           |                 |                 |                 |
| 52          | A9-19           | 7/28 | 10:04 |       |       | 30759        | 135.3       | 25.3  | 9           | 628           |                 |                 |                 |
| 53          | A9-19           | 7/28 | 10:25 |       |       | 30693        | 135.3       | 25.2  | 9           | 629           |                 |                 |                 |
| 54          | A9-19           | 7/28 | 10:52 |       |       | 30758        | 135.3       | 25.3  | 9           | 630           |                 |                 |                 |
| 55          | A9-19           | 7/28 | 11:12 | 77    | 11    | 30693        | 134.08      | 25.4  | 9           | 631           | 250             | 610             | Discard         |
| 56          | A9-19           | 7/28 | 11:40 |       |       | 30704        | 134.08      | 25.4  | 9           | 632           |                 |                 |                 |
| 57          | A9-19           | 7/28 | 11:57 |       |       | 30658        | 134.08      | 25.4  | 9           | 633           |                 |                 |                 |
| 58          | A9-19           | 7/28 | 12:28 |       |       | 30702        | 134.08      | 25.5  | 9           | 634           |                 |                 |                 |
| 59          | A9-19           | 7/28 | 12:45 |       |       | 30779        | 134.08      | 25.5  | 9           | 635           |                 |                 |                 |
| 60          | A9-19           | 7/28 | 1:16  | 78    | 11    | 30812        | 134.69      | 25.4  | 9           | 636           | 250             | 530             | Discard         |
| 61          | A9-19           | 7/28 | 1:34  |       |       | 30697        | 134.69      | 25.3  | 9           | 637           |                 |                 |                 |
| 62          | A9-19           | 7/28 | 2:03  |       |       | 30704        | 134.69      | 25.3  | 9           | 638           |                 |                 |                 |
| 63          | A9-19           | 7/28 | 2:20  |       |       | 30760        | 134.69      | 25.4  | 9           | 639           |                 |                 |                 |

Material Testing Services, LLC

by 

# MATERIAL TESTING SERVICES, LLC

PROJECT: 2009 WILLIAMS CR 9 PHASE IV AML  
 WILLISTON, NORTH DAKOTA  
 ND000111

REPORTED TO: AML DIVISION  
 NORTH DAKOTA PUBLIC SERVICE COMMISSION  
 600 EAST BOULEVARD AVENUE, DEPT. 408  
 BISMARCK, NORTH DAKOTA 58505-0480

LABORATORY NUMBER: W09-044

| TEST NUMBER | LOCATION (HOLE) | DATE | TIME  | TEMP. | SLUMP | BATCH WEIGHT | UNIT WEIGHT | YIELD | TOTAL YARDS | TICKET NUMBER | 14 DAY STRENGTH | 28 DAY STRENGTH | 56 DAY STRENGTH |
|-------------|-----------------|------|-------|-------|-------|--------------|-------------|-------|-------------|---------------|-----------------|-----------------|-----------------|
| 64          | A9-19           | 7/28 | 2:50  |       |       | 32279        | 134.7       | 26.6  | 9           | 640           |                 |                 |                 |
| 65          | A9-19           | 7/28 | 3:07  | 75    | 11    | 32328        | 134.1       | 26.8  | 9           | 641           | 210             | 560             | Discard         |
| 66          | A9-19           | 7/28 | 3:43  |       |       | 32918        | 134.1       | 27.3  | 9           | 642           |                 |                 |                 |
| 67          | A9-19           | 7/28 | 4:00  |       |       | 32853        | 134.1       | 27.2  | 9           | 643           |                 |                 |                 |
| 68          | A9-19           | 7/29 | 8:16  |       |       | 32767        | 134.1       | 27.2  | 9           | 644           |                 |                 |                 |
| 69          | A9-19           | 7/29 | 8:36  |       |       | 32816        | 134.1       | 27.2  | 9           | 645           |                 |                 |                 |
| 70          | A9-19           | 7/29 | 9:00  | 72    | 11    | 32786        | 135.7       | 26.8  | 9           | 646           | 280             | 620             | Discard         |
| 71          | A9-19           | 7/29 | 9:24  |       |       | 31867        | 135.7       | 26.1  | 9           | 647           |                 |                 |                 |
| 72          | A9-19           | 7/29 | 9:46  |       |       | 32823        | 135.7       | 26.9  | 9           | 648           |                 |                 |                 |
| 73          | A9-19           | 7/29 | 10:30 |       |       | 32831        | 135.7       | 26.9  | 9           | 649           |                 |                 |                 |
| 74          | A9-19           | 7/29 | 10:50 |       |       | 32787        | 135.7       | 26.8  | 9           | 650           |                 |                 |                 |
| 75          | A9-19           | 7/29 | 11:11 | 71    | 11    | 32824        | 137         | 26.6  | 9           | 651           | 270             | 650             | Discard         |
| 76          | A9-19           | 7/29 | 11:37 |       |       | 32757        | 137         | 26.6  | 9           | 652           |                 |                 |                 |
| 77          | A9-19           | 7/29 | 12:05 |       |       | 32777        | 137         | 26.6  | 9           | 653           |                 |                 |                 |
| 78          | A9-19           | 7/29 | 12:35 |       |       | 32784        | 137         | 26.6  | 9           | 654           |                 |                 |                 |
| 79          | A9-19           | 7/29 | 12:56 |       |       | 32712        | 137         | 26.5  | 9           | 655           |                 |                 |                 |
| 80          | A9-19           | 7/29 | 1:43  | rain  |       | 32787        | 137         | 26.6  | 9           | 656           |                 |                 |                 |
| 81          | A9-19           | 7/29 | 2:42  | 75    | 10.5  | 32767        | 139.2       | 26.2  | 9           | 657           | 280             | 730             | Discard         |
| 82          | A9-21           | 7/29 | 3:23  |       |       | 31951        | 139.2       | 25.5  | 9           | 658           |                 |                 |                 |
| 83          | A9-21           | 7/29 | 3:54  |       |       | 32786        | 139.2       | 26.2  | 9           | 659           |                 |                 |                 |
| 84          | A9-27           | 7/30 | 8:04  |       |       | 32927        | 139.2       | 26.3  | 9           | 660           |                 |                 |                 |

Material Testing Services, LLC

by 

# MATERIAL TESTING SERVICES, LLC


PROJECT: 2009 WILLIAMS CR 9 PHASE IV AML  
 WILLISTON, NORTH DAKOTA  
 ND000111

REPORTED TO: AML DIVISION  
 NORTH DAKOTA PUBLIC SERVICE COMMISSION  
 600 EAST BOULEVARD AVENUE, DEPT. 408  
 BISMARCK, NORTH DAKOTA 58505-0480

LABORATORY NUMBER: W09-044

| TEST NUMBER | LOCATION (HOLE) | DATE | TIME  | TEMP. | SLUMP | BATCH WEIGHT | UNIT WEIGHT | YIELD | TOTAL YARDS | TICKET NUMBER | 14 DAY STRENGTH | 28 DAY STRENGTH | 56 DAY STRENGTH |
|-------------|-----------------|------|-------|-------|-------|--------------|-------------|-------|-------------|---------------|-----------------|-----------------|-----------------|
| 85          | A9-30           | 7/30 | 8:50  |       |       | 32901        | 139.2       | 26.3  | 9           | 661           |                 |                 |                 |
| 86          | A9-30           | 7/30 | 9:14  | 69    | 11.5  | 32878        | 131.4       | 27.8  | 9           | 662           | 200             | 440             | Discard         |
| 87          | A9-30           | 7/30 | 9:54  |       |       | 32862        | 131.4       | 27.6  | 9           | 663           |                 |                 |                 |
| 88          | A9-30           | 7/30 | 10:13 |       |       | 32814        | 131.4       | 27.7  | 9           | 664           |                 |                 |                 |
| 89          | A9-30           | 7/30 | 10:33 |       |       | 32764        | 131.4       | 27.7  | 9           | 665           |                 |                 |                 |
| 90          | A9-30           | 7/30 | 10:57 |       |       | 32934        | 131.4       | 27.8  | 9           | 666           |                 |                 |                 |
| 91          | A9-30           | 7/30 | 11:15 | 71    | 11.5  | 32870        | 133.9       | 27.3  | 9           | 667           | 220             | 390             | Discard         |
| 92          | A9-30           | 7/30 | 11:41 |       |       | 32858        | 133.9       | 27.3  | 9           | 668           |                 |                 |                 |
| 93          | A9-30           | 7/30 | 11:58 |       |       | 32820        | 133.9       | 27.2  | 9           | 669           |                 |                 |                 |
| 94          | A9-30           | 7/30 | 12:30 |       |       | 32663        | 133.9       | 27.1  | 9           | 670           |                 |                 |                 |
| 95          | A9-30           | 7/30 | 12:48 |       |       | 32745        | 133.9       | 27.2  | 9           | 671           |                 |                 |                 |
| 96          | A9-30           | 7/30 | 1:14  | 76    | 11    | 32727        | 133.5       | 27.2  | 9           | 672           | 240             | 440             | Discard         |
| 97          | A9-30           | 7/30 | 1:32  |       |       | 32681        | 133.5       | 27.2  | 9           | 673           |                 |                 |                 |
| 98          | A9-30           | 7/30 | 1:58  |       |       | 32692        | 133.5       | 27.2  | 9           | 674           |                 |                 |                 |
| 99          | A9-30           | 7/30 | 2:16  |       |       | 32691        | 133.5       | 27.2  | 9           | 675           |                 |                 |                 |
| 100         | A9-30           | 7/30 | 2:39  |       |       | 32681        | 133.5       | 27.2  | 9           | 676           |                 |                 |                 |
| 101         | A9-30           | 7/30 | 2:57  | 76    | 11.5  | 32683        | 128.6       | 28.2  | 9           | 677           | 160             | 300             | Discard         |
| 102         | A9-30           | 7/30 | 3:39  |       |       | 32728        | 128.6       | 28.2  | 9           | 678           |                 |                 |                 |
| 103         | A9-30           | 7/30 | 3:39  |       |       | 32700        | 128.6       | 28.3  | 9           | 679           |                 |                 |                 |
| 104         | A9-30           | 7/30 | 4:01  |       |       | 32814        | 128.6       | 28.4  | 9           | 680           |                 |                 |                 |
| 105         | A9-30           | 7/30 | 4:24  |       |       | 32700        | 128.6       | 28.3  | 9           | 681           |                 |                 |                 |

Material Testing Services, LLC

by 

# MATERIAL TESTING SERVICES, LLC

PROJECT: 2009 WILLIAMS CR 9 PHASE IV AML  
 WILLISTON, NORTH DAKOTA  
 ND000111

REPORTED TO: AML DIVISION  
 NORTH DAKOTA PUBLIC SERVICE COMMISSION  
 600 EAST BOULEVARD AVENUE, DEPT. 408  
 BISMARCK, NORTH DAKOTA 58505-0480

LABORATORY NUMBER: W09-044

| TEST NUMBER | LOCATION (HOLE) | DATE | TIME  | TEMP. | SLUMP | BATCH WEIGHT | UNIT WEIGHT | YIELD | TOTAL YARDS | TICKET NUMBER | 14 DAY STRENGTH | 28 DAY STRENGTH | 56 DAY STRENGTH |
|-------------|-----------------|------|-------|-------|-------|--------------|-------------|-------|-------------|---------------|-----------------|-----------------|-----------------|
| 106         | A9-30           | 7/30 | 4:42  | 77    | 11.5  | 32747        | 1126.3      | 28.8  | 9           | 682           | 180             | 300             | Discard         |
| 107         | A9-30           | 7/30 | 5:05  |       |       | 32427        | 126.3       | 28.5  | 9           | 683           |                 |                 |                 |
| 108         | A9-30           | 8/3  | 8:12  |       |       | 32755        | 126.3       | 28.8  | 9           | 686           |                 |                 |                 |
| 109         | A9-30           | 8/3  | 8:28  |       |       | 32657        | 126.3       | 28.7  | 9           | 687           |                 |                 |                 |
| 110         | A9-30           | 8/3  | 8:53  |       |       | 32630        | 126.3       | 28.7  | 9           | 688           |                 |                 |                 |
| 111         | A9-30           | 8/3  | 9:12  | 74    | 11.75 | 32593        | 133.9       | 27.1  | 9           | 689           | 230             | 360             | Discard         |
| 112         | A9-30           | 8/3  | 9:33  |       |       | 32592        | 133.9       | 27.1  | 9           | 690           |                 |                 |                 |
| 113         | A9-30           | 8/3  | 9:58  |       |       | 32573        | 133.9       | 27.0  | 9           | 691           |                 |                 |                 |
| 114         | A9-30           | 8/3  | 10:16 |       |       | 32630        | 133.9       | 27.1  | 9           | 692           |                 |                 |                 |
| 115         | A9-30           | 8/3  | 10:48 |       |       | 25738        | 133.9       | 24.0  | 8           | 693           |                 |                 |                 |
| 116         | A9-30           | 8/3  | 11:06 | 74    | 11    | 32536        | 133.9       | 27.0  | 9           | 694           | 240             | 500             | Discard         |
| 117         | A9-30           | 8/3  | 11:26 |       |       | 32395        | 133.9       | 26.9  | 9           | 695           |                 |                 |                 |
| 118         | A9-30           | 8/3  | 11:45 |       |       | 32495        | 133.9       | 27.0  | 9           | 696           |                 |                 |                 |
| 119         | A9-30           | 8/3  | 12:02 |       |       | 32592        | 133.9       | 27.1  | 9           | 697           |                 |                 |                 |
| 120         | A9-30           | 8/3  | 12:20 |       |       | 32518        | 133.9       | 27.0  | 9           | 698           |                 |                 |                 |
| 121         | A9-30           | 8/3  | 12:38 | 73    | 11    | 32428        | 134.5       | 26.8  | 9           | 699           | 260             | 450             | Discard         |
| 122         | A9-30           | 8/3  | 12:57 |       |       | 32517        | 134.5       | 26.9  | 9           | 700           |                 |                 |                 |
| 123         | A9-30           | 8/3  | 1:17  |       |       | 32442        | 134.5       | 26.8  | 9           | 701           |                 |                 |                 |
| 124         | A9-30           | 8/3  | 1:41  |       |       | 32432        | 134.5       | 26.8  | 9           | 702           |                 |                 |                 |
| 125         | A9-30           | 8/3  | 1:59  |       |       | 32442        | 134.5       | 26.8  | 9           | 703           |                 |                 |                 |
| 126         | A9-30           | 8/3  | 2:24  | 72    | 11    | 32498        | 134.3       | 26.9  | 9           | 704           | 270             | 400             | Discard         |

Material Testing Services, LLC

by 