

**230 kV Transmission Line / Morton and Oliver Counties
PU-09-587
Week Ending 09-11-2010**

RECEIVED

SEP 14 2010

Work Completed this Week: MJ ELECTRIC UTILITY DIVISION

PUBLIC SERVICE COMMISSION

- MJ completed installation of all avian diverters, all structures.
- MJ completed installation of line jumpers.
- MJ completed clean – up of right of way, structures 72 thru 132.
- MJ continued de-mobilization of major equipment.

230 KV Square Butte Substation Modifications: HOOPER Electric Corporation

- HOOPER completed termination of equipment control cable.
- HOOPER completed installation and wiring of miscellaneous electrical devices.
- HOOPER pierced final adjustments of 230KV dead - end switch.
- HOOPER completed wiring 230KV line wave trap.
- HOOPER completed substation punch list items.
- HOOPER continued final clean – up of substation.
- Commissioning and initial energization of new equipment completed.