

Bison 2 Weekly Construction Report
PU-11-57
Week Ending: 06/24/12

Michels working on 690 terminations in turbine transformers.

Hooper Construction is finishing 230kV bus work in the substation. Substation transformer energized on 6/22/12, soaked for 24 hours and de-energized.

Siemens and their subcontractor, Barnhart, are receiving turbine components, setting base sections, and building rotors.