

Permit # **MH18-00005**  
ACTIVE

**FIRST DISTRICT HEALTH UNIT**  
MAILING: PO BOX 1268, MINOT, ND 58702-1268  
PHYSICAL: 801 11TH AVE SW, MINOT, ND 58701  
PHONE: 701-852-1376  
FAX: 701-852-5043

Bottineau, Burke, McHenry,  
McLean, Renville, Sheridan &  
Ward Counties

**ONSITE SEWAGE TREATMENT SYSTEM PERMIT**

Applicant's Name: \_\_\_\_\_ Phone #: \_\_\_\_\_  
 Owners Name: MEADOWLARK WIND I LLC Phone #: (508) 734-0919  
 Current Mailing Address: 155 FEDERAL ST STE 1200, BOSTON, MA 02110  
 Property Address: \_\_\_\_\_ Latitude & Longitude: 47.861363000, -100.927416000  
 \_\_\_\_\_, ND  
 Legal Description: NW 1/4 Section: 33 Township: 151 N Range: 80 W  
 Subdivision: \_\_\_\_\_ Lot: \_\_\_\_\_ Block: \_\_\_\_\_ Size (acres): 12

Type of Installation	Type of System	Type of Use	Distribution of Effluent	Water Supply
<input checked="" type="checkbox"/> New System	<input type="checkbox"/> Trenches	<input type="checkbox"/> Residential	<input type="checkbox"/> Gravity	<input checked="" type="checkbox"/> Private
<input type="checkbox"/> Expansion	<input type="checkbox"/> Seepage Bed	<input checked="" type="checkbox"/> Non-Residential	<input checked="" type="checkbox"/> Pressure	<input type="checkbox"/> Shared
<input type="checkbox"/> Repair	<input type="checkbox"/> At-Grade			<input type="checkbox"/> Public
<input type="checkbox"/> Tank Only	<input checked="" type="checkbox"/> Mound			
	<input type="checkbox"/> Other			

- Water supply to be constructed in accordance with Regulation 43.35 and ND plumbing code.
- All information given to designer with regards to size/capacity of dwelling is correct and complete. Any changes to number of bedrooms or future additions must be disclosed or design is invalid.
- Sewage treatment system must be installed in accordance with ND plumbing code and FDHU's Regulation #10.
- Homeowner and/or contractor are responsible for ensuring all lot lines and setbacks are observed during system installation.
- Permit expires one (1) year after date issued.

Bedrooms: 0  
 Bathrooms: 2  
 Design Flow: 200 gallons per day  
 Soil Type: clay  
 Working Gallonage of Septic Tank: 1000 gallons  
 Working Gallonage of Pump Tank: 300 gallons  
 Minimum Square Footage: 600 ft<sup>2</sup>  
 Number of Laterals: 3  
 Field Dimensions: 10' X 60'  
 Maximum Depth: 0 inches


**THIS SECTION TO BE FILLED OUT BY OWNER**

Sewer Contractor: GLEASON CONSTRUCTION INC.  
 Note: Sewer contractors must be licensed through FDHU in order to install sewage treatment systems in this health district.

**LRDHU**  
 FDHU License Number: 113

Owner's Signature: Paul F. W... Date: \_\_\_\_\_

Final approval of this permit requires inspection of the uncovered system. FDHU must be notified 48 hours prior to backfilling.

  
 \_\_\_\_\_  
 EHS Permit Issued Signature  
**JIM HECKMAN** 05/14/2018  
 EHS Date