

GWD DESIGN, INC.

Pipeline MAOP Calculation per CFR 195.106 and consistent with ASME B31.4 Sec. 402 & 404

Client: Whiting Petroleum Corporation
Project: Nexen 8" Oil Pipeline
Location: Stanley, ND

Rev.: A
Rev. Date: 7/13/2009
Print Date: 7/20/2009

$$P=(2St/D) \times E \times F \quad (\text{See CFR 195.106 for references below})$$

P = Internal design pressure in p.s.i. (kPa) gage.

S = Yield strength in pounds per square inch (kPa) determined in accordance with paragraph (b) of this section.

t = Nominal wall thickness of the pipe in inches (millimeters).
If this is unknown, it is determined in accordance with paragraph (c) of this section.

D = Nominal outside diameter of the pipe in inches (millimeters).

E = Seam joint factor determined in accordance with paragraph (e) of this section.

F = A design factor of 0.72, except that a design factor of 0.60 is used for pipe, including risers, on a platform located offshore or on a platform in inland navigable waters, and 0.54 is used for pipe that has been subjected to cold expansion to meet the specified minimum yield strength and is subsequently heated, other than by welding or stress relieving as a part of welding, to a temperature higher than 900 °F (482 °C) for any period of time or over 600 °F (316 °C) for more than 1 hour.

Line Pipe Calculation:

S = 52,000 psi API 5L B, X42/X52
t = 0.250 inches
D = 8.625 inches
E = 1 Only ERW pipe will be used (see CFR 195.106 paragraph (e))
F = 0.72

P = 2170 psig From -20 °F to 100 °F

Above Ground Pipe Calculation:

S = 35,000 psi A333 Gr 6 (see attached Fig. 17-25 from GPSA 12th Edition Vol. II)
t = 0.500 inches Sch. 80
D = 8.625 inches
E = 1 Only ERW/Seamless pipe will be used (see CFR 195.106 paragraph (e))
F = 0.72

P = 2922 psig From -50 °F to 100 °F
(NOTE: 4" STD wall used for valves is rated to 2654 psig)

Pipeline "Weak Link":

The weakest point in the pipeline will be the ANSI 600# flanges per ASME B16.5-2003 and as shown in the attached Fig. 17-28 from GPSA 12th Edition Vol. II. MAOP will be 1480 psig.

GWD DESIGN, INC.

Hydrotest Calculation per ASME B31.4 Sec. 437.4

Client: Whiting Petroleum Corporation
Project: Nexen 8" Oil Pipeline
Location: Stanley, ND

Rev.: A
Rev. Date: 7/13/2009
Print Date: 7/20/2009

per ASME B31.4 the hydrotest must be run at 1.25 times the MAOP for 4 hours and 1.1 times for 4 hours

MAOP = 1480 psig (see MAOP Calculation)

Hydrotest Pressure:

Hydrotest Pressure = MAOP x 1.25

Hydrotest Pressure = 1850 psig (Required at Highest Point in Elevation during 1.25 test)

Elevation Change Pressure Head:

Max Elevation Change = Highest Elevation Point - Lowest Elevation Point

Max Elevation Change = 2371 ft- 2157 ft (See Attached Pipeline Profile)

Max Elevation Change = 214 ft

Water Pressure Head = 92.8 psi (Only valid with Water as Test Medium)

Minimum Pressure at Points During Test:

Inlet Elevation = 2175 ft Inlet Pressure = 1935 psig

Outlet Elevation = 2211 ft Outlet Pressure = 1919 psig

High Pt Elevation = 2371 ft High Pt Pressure = 1850 psig

Low Pt Elevation = 2157 ft Low Pt Pressure = 1943 psig

Chart Elevation = 2175 ft Chart Pressure = 1935 psig

NOTE: This assumes Chart will be located at pipeline inlet. Acutal elevation/chart location to be verified.

GWD DESIGN, INC.
Hydrotest Calculation per ASME B31.4 Sec. 437.4

Client: Whiting Petroleum Corporation
Project: Nexen 8" Oil Pipeline
Location: Stanley, ND

Rev.: A
Rev. Date: 7/13/2009
Print Date: 7/20/2009

per ASME B31.4 Sec. 437.4.1: When lines are tested at pressures that develop a hoop stress, based on nominal wall thickness, in excess of 90% of the specified minimum yield strength of the pipe, special care shall be used to prevent overstrain of the pipe.

$$\text{Hoop Stress} = P \times ID / 2t < 90\% S$$

P = Internal Pressure in psig

ID = Internal Diameter in inches

t = Wall Thickness in inches

S = Yield Strength in psi

Line Pipe Hoop Stress Calculation:

To prevent overstrain of pipe Max Hydrotest pressure should be at a hoop stress less than 90% of SMYS

ID = 8.125 in
t = 0.250 in
S = 52,000 psi

Max Hoop Stress = 46,800 psi

P = 2880 psig (Max Pressure that can be applied at lowest point)

Above Ground Pipe Hoop Stress Calculation:

To prevent overstrain of pipe Max Hydrotest pressure should be at a hoop stress less than 90% of SMYS

ID = 7.625 in
t = 0.500 in
S = 35,000 psi

Max Hoop Stress = 31,500 psi

P = 4131 psig

Maximum Allowable Pressure at Points During Test:

Inlet Elevation =	2175 ft	Inlet Pressure =	2872 psig
Outlet Elevation =	2211 ft	Outlet Pressure =	2857 psig
High Pt Elevation =	2371 ft	High Pt Pressure =	2787 psig
Low Pt Elevation =	2157 ft	Low Pt Pressure =	2880 psig
Chart Elevation =	2175 ft	Chart Pressure =	2872 psig

NOTE: This assumes Chart will be located at pipeline inlet. Actual elevation/chart location to be verified.

8" Nexen Oil Pipeline Profile




FIG. 17-27

Gas Transmission and Distribution Piping
Code for Pressure Piping ANSI B31.8-1999
Carbon Steel and High Yield Strength Pipe

(Values apply to A106, API 5L and API 5LX pipe having the same specified minimum yield strength as shown)

Nom Pipe Size	O.D.	Wall Thk.	Allowable Working Pressures up to 250°F, in psig																													
			Construction Type Design Factors																													
			Type A, F = 0.72*					Type B, F = 0.60					Type C, F = 0.50					Type D, F = 0.40														
			GR.B						GR.B						GR.B				GR.B				GR.B									
35,000	42,000	48,000	52,000	60,000	35,000	42,000	48,000	52,000	60,000	35,000	42,000	48,000	52,000	60,000	35,000	42,000	48,000	52,000	60,000	35,000	42,000	48,000	52,000	60,000								
2	(STD)	.154	3268					2723							2270											1816						
	2.375	.218	4626					3855							3213											2570						
3	(STD)	.125	1800					1500							1250											1000						
		.156	2246					1872							1560											1248						
		.188	2707					2256							1880												1504					
		.216	3110					2592							2160												1728					
		.250	3600					3000							2500													2000				
		.281	4046					3372							2810													2248				
3	.300	4320					3600							3000												2400						
4	(STD)	.125	1400	1680	1840			1167	1400	1533					973	1167	1278									778	933	1022				
		.156	1747	2097	2296			1456	1747	1913					1214	1456	1595									971	1165	1276				
		.188	2105	2526	2767			1754	2105	2306					1462	1755	1922										1170	1404	1537			
		.219	2453	2943	3223			2044	2453	2686					1704	2044	2239											1363	1635	1791		
		.237	2654	3185	3488			2212	2654	2907					1844	2212	2423											1475	1770	1938		
		.250	2800	3360	3680			2333	2800	3067					1945	2333	2556											1556	1869	2044		
		.281	3147	3776	4136			2623	3147	3447					2186	2622	2873											1748	2098	2298		
		.312	3494	4193	4593			2912	3494	3827					2427	2912	3190											1941	2330	2552		
		.337	3774	4530	4961			3145	3775	4134					2621	3146	3445											2097	2516	2756		
		6	(STD)	.156	1187	1424	1560	1763		989	1187	1300	1469				824	989	1083	1224									659	791	866	980
.188	1429			1716	1880	2124		1192	1430	1567	1770				993	1192	1306	1475									794	954	1044	1180		
.219	1666			2000	2190	2475		1388	1666	1825	2063				1157	1389	1521	1719									926	1111	1216	1375		
.250	1902			2282	2500	2826		1585	1902	2083	2355				1321	1585	1736	1963										1057	1268	1389	1570	
.280	2130			2556	2799	3164		1776	2130	2333	2637				1479	1775	1944	2198										1183	1420	1555	1758	
.312	2373			2848	3120	3527		1976	2374	2600	2933				1649	1978	2167	2449										1319	1582	1733	1959	
.375	2853			3424	3750	4237		2377	2853	3125	3531				1981	2378	2604	2943										1585	1902	2083	2354	
.432	3287			3943	4319	4883		2739	3286	3599	4089				2283	2738	3000	3391										1826	2191	2400	2713	
8	(STD)			.156	912	1094	1198	1354		760	912	998	1128				633	760	832	940									506	608	666	752
				.188	1098	1318	1444	1632		915	1098	1203	1360				763	915	1003	1133									610	732	802	907
		.203	1186	1424	1559	1762		989	1186	1299	1469				824	989	1083	1224									659	791	866	979		
		.219	1280	1535	1681	1901		1067	1280	1401	1584				889	1067	1168	1320									711	853	934	1056		
		.250	1461	1753	1920	2170		1217	1461	1600	1809				1014	1217	1333	1507									812	974	1067	1206		
		.277	1618	1942	2128	2405		1349	1618	1773	2004				1124	1349	1478	1670									899	1079	1182	1336		
		.312	1823	2189	2396	2709		1520	1823	1997	2258				1266	1520	1664	1881									1013	1216	1331	1505		
		.322	1882	2258	2473	2796		1568	1882	2061	2329				1307	1568	1717	1941									1045	1254	1374	1553		
		.344	2011	2412	2642	2988		1676	2011	2202	2490				1396	1676	1835	2075									1117	1340	1468	1660		
		.375	2191	2628	2860	3256		1826	2191	2399	2713				1521	1826	1999	2261									1217	1460	1599	1808		
.438	2560	3071	3364	3803		2133	2560	2804	3170				1778	2133	2336	2641									1422	1706	1869	2113				
.500	2922	3506	3840	4341		2435	2922	3200	3617				2029	2435	2667	3014									1623	1948	2133	2412				
10	(STD)	.188	881	1058	1158	1310		733	881	965	1091				612	735	804	909									490	588	644	728		
		.203	959	1143	1251	1415		794	952	1043	1179				661	794	869	983									529	635	695	786		
		.219	1026	1231	1348	1525		855	1026	1124	1271				713	855	936	1059									570	684	749	847		
		.250	1172	1407	1540	1741		977	1172	1284	1451				814	977	1070	1209									651	781	856	967		
		.279	1309	1570	1719	1944		1091	1309	1433	1620				909	1091	1194	1350									727	872	955	1080		
		.307	1440	1728	1892	2138		1200	1440	1577	1782				1000	1200	1314	1466									800	960	1051	1189		
		.344	1613	1935	2120	2396		1344	1613	1767	1997				1120	1344	1473	1664									896	1075	1178	1331		
		.365	1711	2054	2249	2542		1426	1711	1874	2119				1188	1426	1562	1766									951	1141	1249	1412		
		.438	2054	2464	2700	3051		1712	2054	2250	2543				1426	1712	1875	2119									1141	1369	1500	1695		
		.500	2344	2813	3051	3483		1953	2344	2567	2902				1628	1953	2140	2419									1302	1563	1712	1935		
12	(STD)	.188	743	892	977	1104		619	743	814	920				516	619	678	767									413	495	543	613		
		.203	803	963	1055	1193		669	803	879	995				556	669	733	829									446	535	586	663		
		.219	866	1039	1138	1287		722	866	948	1073				601	722	790	894									481	577	632	715		
		.250	988	1186	1299	1468		824	988	1082	1224				686	824	902	1020									549	659	722	816		
		.281	1111	1332	1460	1651		926	1111	1217	1376				771	926	10															

FIG. 17-28

Pressure-Temperature Ratings for Pipe Flanges and Flanged Fittings from ANSI B16.5-1996

CLASS	150	300	400	600	900	1500	2500
Material Group 1.1						(Carbon Steel)	
						A105 (1), A216-WCB (1), A515-70 (1) A516-70 (1) (2) A350-LF2 (1), A537-C1.1 (3)	
°F	Pressures are in pounds per square inch, gauge (psig)						
-20 to 100	285	740	990	1480	2220	3705	6170
200	260	675	900	1350	2025	3375	5625
300	230	655	875	1315	1970	3280	5470
400	200	635	845	1270	1900	3170	5280
500	170	600	800	1200	1795	2995	4990
600	140	550	730	1095	1640	2735	4560
650	125	535	715	1075	1610	2685	4475
700	110	535	710	1065	1600	2665	4440
750	95	505	670	1010	1510	2520	4200
800	80	410	550	825	1235	2060	3430
850	65	270	355	535	805	1340	2230
900	50	170	230	345	515	860	1430
950	35	105	140	205	310	515	860
1000	20	50	70	105	155	260	430
Material Group 2.1						(Type 304)	
						A182-F304 (5), A182-F304H A240-304 (5), A351-CF8 (5) A351-CF3 (4)	
-20 to 100	275	720	960	1440	2160	3600	6000
200	230	600	800	1200	1800	3000	5000
300	205	540	720	1080	1620	2700	4500
400	190	495	660	995	1490	2485	4140
500	170	465	620	930	1395	2330	3880
600	140	435	580	875	1310	2185	3640
650	125	430	575	860	1290	2150	3580
700	110	425	565	850	1275	2125	3540
750	95	415	555	830	1245	2075	3460
800	80	405	540	805	1210	2015	3360
850	65	395	530	790	1190	1980	3300
900	50	390	520	780	1165	1945	3240
950	35	380	510	765	1145	1910	3180
1000	20	320	430	640	965	1605	2675
1050		310	410	615	925	1545	2570
1100		255	345	515	770	1285	2145
1150		200	265	400	595	995	1655
1200		155	205	310	465	770	1285
1250		115	150	225	340	565	945
1300		85	115	170	255	430	715
1350		60	80	125	185	310	515
1400		50	65	90	145	240	400
1450		35	45	70	105	170	285
1500		25	35	55	80	135	230

Notes:

- (1) Upon prolonged exposure to temperatures above about 800°F (425°C), the carbide phase of carbon steel may be converted to graphite: permissible but not recommended for prolonged use above 800°F
- (2) Not to be used over 850°F
- (3) Not to be used over 700°F
- (4) Not to be used over 800°F
- (5) At temperatures over 1000°F (540°C), use only when the carbon content is 0.04 percent or higher
- (6) For temperatures above 1000°F (540°C), use only if the material is heat treated by heating it to a temperature of at least 1900°F (1040°C) and quenching in water or rapidly cooling by other means

6.3. HAZOP Recommendations: Whiting Oil & Gas


During discussion of node 1 (Robinson Lake inlet from the Whiting Oil and Gas Co. crude pipeline), a representative from Whiting was available to provide information to the PHA team related to the pipeline and nearby operations.

As a result of the review of this node, six (6) recommendations were made for which input or follow-up from Whiting would be required. Two (2) of these six recommendations were ranked as "H" high risk. These recommendations were as follows:

Recommendations	Max RR	Responsibility
32. Review means to divert overland water from the Whiting facility away from the diked area at the Nexen Robinson Lake facility, as this water could reduce the capacity of the Nexen dikes. (Causes: 1.15.2)	H	Travis Mecham and Bill Herrmann
35. Review the location of the truck unloading facility, as Whiting trucks will require access via the truck unloading area to other areas of the Robinson Lake site. (Causes: 1.15.4)	H	Bill Herrmann, Barry Garvin, Travis Mecham
1. Consider having Whiting add a bladder valve upstream of AOV-1001 (line 8-CO-ACA-1010), in order to protect and maintain backpressure in the Whiting oil pipeline. (Causes: 1.1.1, 1.1.2)	M	Bill Herrmann and Barry Garvin
3. Consider the addition of a low pressure alarm to PIT-1001, on the Whiting pipeline, as a potential means to identify leaks on the Whiting pipeline and at the inlet to the Robinson Lake station. (Causes: 1.1.1, 1.1.2)	M	Bill Herrmann and Barry Garvin
4. Verify with Whiting that their pipeline pumps will shut down on high discharge pressure, and/or verify that PSVs are included on the Whiting pipeline, to reduce the likelihood of potential pipeline ruptures that could occur should AOV-1001 at Robinson Lake malfunction closed. Also determine if the response time of the shutdowns on the Whiting pipeline are quick enough to reduce the likelihood of a spill in the event AOV-1001 malfunctions closed. (Causes: 1.1.3)	M	Bill Herrmann and Barry Garvin
33. Consider removing the drain line from the Whiting plant (the contents of which are currently unknown). (Causes: 1.15.3)		Travis Mecham and Bill Herrmann

Stanley Outlet Pump Scenarios	Daily	Pump Operations
P-262 = 500 bph	12 M	1 bp INTERIM (P-262)
P-263 = 1000 bph	24 M	1 bp INTERIM (P-263)
P-262/263 = 1500 bph	36 M	2 bp INTERIM (P-262 & P-263 in parallel)
P-262/263/264 = 2500 bph	48 M	3 bp INTERIM (P-262, P-263 & P-264 in parallel)
P-262/263/264/265 = 3500 bph	60 M	4 bp INTERIM (P-262, P-263, P-264 & P-265 in parallel)


Future
Future



R-L Outlet Pump Scenarios	Daily	Pump Operations
P-201 or 202 = 417 bph	10 M	1 bp INTERIM (P-201)
P-201 and 202 = 500 bph	12 M	2 bp INTERIM (P-201 & P-202)
P-201 and 202 w/ P-264 = 600 bph	19.4 M	2 bp INTERIM (plus P-264 from Stanley)

Future

Tank Levels, Day 1



Monthly Tank Levels

