

OTTER TAIL POWER COMPANY
Case No. PU-11-165

Response to: La Capra Associates Inc on behalf of PSC
Analyst: Douglas A. Smith
Date Received: 9/30/2011
Date Due: 10/10/2011
Date of Response: 10/10/2011
Responding Witness: Mark Rolfes, Manager, Generation Development - (218) 739-8648

Information Request No: ND-LCA-3-1

Please provide the estimated cost of upgrading the "Mercury control equipment" (as described in Joint Exhibit 1, page 9) if the work is done separately from the AQCS work.

RESPONSE:

If the Mercury control equipment is installed separately we would not expect the cost to be significantly different. Please note that we are not upgrading as currently there is no specific Mercury control equipment.

If the Mercury control equipment is installed prior to the AQCS there will be additional cost as the ductwork where the material would be injected will be removed and new installed.