

Sheldon, Scott F.

From: Sederquist, Dave <dave.sederquist@xcelenergy.com>
Sent: Tuesday, November 15, 2011 4:16 PM
To: Sheldon, Scott F.
Cc: Lein, Jerry R.; Diller, Michael R.
Subject: Xcel Energy outage

We are experiencing high winds in Fargo today – gusts in 30-40 mph range. We did have a tree fall and take out a 4 kV line and a 23 kV line today at 1:10 pm, interrupting 1,930 customers for about 51 minutes today in north Fargo. It was not a feeder-level outage, but thought I'd let you know anyway.

Dave Sederquist
Xcel Energy
Sr. Regulatory/Financial Consultant
2302 Great N. Drive, Fargo, ND 58102
P: 701.241.8632 C: 701.371.5256 F: 701.241.8682

E: dave.sederquist@xcelenergy.com

No trees were killed in the sending of this message. However, several electrons were terribly inconvenienced.

Confidentiality Notice: This e-mail message and any attached files is for the sole use of intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, distribution, or copying is prohibited. If you are not the intended recipient(s), please contact the sender by replying to this e-mail and destroy/delete all copies of this e-mail message.

112 PU-11-55 Filed 11/15/2011 Pages: 1
Email update on Nov. 15th outage - Fargo
Northern States Power Company

59 PU-11-557 Filed 11/15/2011 Pages: 1
Email update on Nov. 15th outage - Fargo
Northern States Power Company

137 PU-10-657 Filed 11/15/2011 Pages: 1
Email update on Nov. 15th outage - Fargo
Northern States Power Company