

-Info-Public Service Commission

From: Thiessen, Peter <Peter.Thiessen@mdu.com>
Sent: Monday, July 28, 2014 10:24 AM
To: Lein, Jerry R.; kmagstadt@wenck.com; -Info-Public Service Commission
Cc: Welte, Alan; aarmbrecht@segainc.com; Thiessen, Peter; Ulberg, Brian
Subject: RE: PSC Case # PU-11-631 (MDU Heskett 3 - Weekly Report 7/21/2014)

Mr. Lein and Mr. Magstadt,
Construction installation activities on PSC Case No. PU-11-631 (MDU Heskett 3) are complete. Final unit startup and testing activities are ongoing. We plan to send a final status update report once the plant has reached commercial operating status. Please let me know if you have any questions or concerns.

Pete Thiessen

Senior Engineer • Power Production • Project Manager, Heskett Unit 3
Montana-Dakota Utilities Co. • 400 North Fourth Street • Bismarck, ND 58501
P: 701.222.7723 • F: 701.222.7845 • E: Peter.Thiessen@mdu.com

From: Ulberg, Brian
Sent: Monday, July 28, 2014 10:07 AM
To: jlein@nd.gov; kmagstadt@wenck.com; ndpsc@nd.gov
Cc: Welte, Alan; Thiessen, Peter; aarmbrecht@segainc.com
Subject: PSC Case # PU-11-631 (MDU Heskett 3 - Weekly Report 7/21/2014)

Mr. Lein,
Please see the attached weekly construction report for PSC Case No. PU-11-631 (MDU Heskett 3). If you have any questions or concerns please call me on my cell at 400-5150.

Thank you

Brian Ulberg

Engineer - Power Production
Montana-Dakota Utilities Co.
400 North Fourth Street
Bismarck, ND 58501-4092
Office: 701-222-7681 | Cell: 701-400-5150

98 **PU-11-631** Filed: 7/28/2014 Pages: 2
**MDU Heskett 3 progress report - week ending
7-21-2014**



PROJECT DETAILS AND PROGRESS:

Contract 140095 – Mechanical and Electrical Installation

- Completed work and left site.

MDU/GE Check-out

- Meeting with GE Controls Team. Explained the DLN 1+ system. Went over changes for latest controls revision
- Installed latest controls revision
- Worked on Proficy Historian
- Ran Unit to test latest controls revision for fuel transfer and inlet bleed heat, emission tuning
- Meeting with GE Controls Team. Discussed issues from for latest controls revision
- Trouble shot the Auto Sync
- Modification to GE Relay corrected the Auto Sync issue.
- GE Training for plant personnel (All week long)

PROJECT OPEN ITEMS / CONCERNS:

- None not already discussed
- Construction Equipment: None
- Visitors: Pete Thiessen (MDU)