

ONEOK Garden Creek II & III

Second Construction Inspection – 8/06/2013

PCS Case No. PU-12-656

Bartlett & West (B&W) conducted a second onsite inspection of the ONEOK Garden Creek II & III Station (Case No. PU-12-656) on August 6th, 2013. B&W inspector Zach Glueckert met with Linde's Construction Site Manager, David Ballard. A construction site tour was conducted and construction progress was discussed.

Work done to date has included earth work, concrete foundation work, steel structure erection, temporary office setup and drainage ponds established with riprap erosion controls. Discussions with Mr. Ballard indicated that all necessary permits have been acquired thus far with the exception of McKenzie County building permits which are being processed but not officially acquired as of the date of inspection. One area of concern is silt fence is in need of repair in various locations along the property boundaries. Mr. Ballard stated that the damage to the silt fence is being scheduled for repair and should be completed shortly. No other issues were found with the construction activities during this site visit.

The following are some photographs with descriptions taken during the site visit.



Figure 1. View from the western edge of Garden Creek II looking south



Figure 2. View from the western edge of Garden Creek II looking east



Figure 3. View from the western edge of Garden Creek II looking northeast



Figure 4. View from the northern edge of Garden Creek II looking east. Riprap installation to control drainage is seen.



Figure 5. View from the northeastern corner of Garden Creek III looking west



Figure 6. View from the northeastern corner of Garden Creek III looking south



Figure 7. View from the southeastern corner of Garden Creek III looking west



Figure 8. View from the southeastern corner of Garden Creek III looking north