

CAPITAL ELECTRIC COOP

MENOKEN SUB CCT 3 OUTAGE HISTORY

2009	2010	2011	2012	2013	2014
1	2	0	0	1	0

CAPITAL ELECTRIC COOPERATIVE

W/O#: Account: 3456902 SO Nbr: 523532 Cycle: 1 Date Needed: 06/03/2013

Srv Map Loc: 452808157

MISCELLANEOUS REQUEST

KRISTI D VETTER
2248 171ST ST NE
MENOKEN, ND 58558

Home Phone: (701)673-3142 Ext.
Work Phone: (701)663-6595 Ext. 4304
Mobile Phone: NONE LISTED

Electrician: T&M ELECTRIC	Service Desc: SECTION 28	Block:	Lot:
Permit #: 547403	Subdivision:		
Inspection:	Builder:	Builder Ph: None Listed	
TRANSFORMER			
Transformer Loc#: 452808T4155	Sub: 15	Circuit: 4	Line Sect: 452807
Serial #: 91009101262	KVA: 37.5		Phase: C
<u>INSTALLED:</u>			
Serial #: _____	KVA: _____		Phase: _____
METERS			
Serial #: 22954979	TWACS: 4186002	Port: 1	LV Rdg: 6492 L V Rdg Dt: 05/01/2014
Reading: _____	Demand: _____	Mult: 1	Dials: 5 Rate: 023
Serial #: 68497173	TWACS: 82864005	Port: 0	LV Rdg: 9135 L V Rdg Dt: 05/01/2014
Reading: _____	Demand: _____	Mult: 1	Dials: 5 Rate: 045
<u>INSTALLED:</u>			
Serial #: _____	TWACS: _____	Type: _____	Port: _____
Reading: _____	Demand: _____	Mult: _____	Dials: _____

DESCRIPTION:
NO POWER REPORTED. C PHASE BREAKER WAS OPEN IN SUB, UNDERGROUND FAULT BETWEEN V4071 AND V1 AT STERLING SUB.

LD MH 6-2-13

FIELD COMMENTS:

Man Hours: _____
Unit/Mile: _____
Time Out: _____
Time On: _____
Completed By: _____
Date: _____



Dispatched To: _____
Job Briefing : _____
Close Date: 6/20/13
Taken By: ln 06/03/2013

CAPITAL ELECTRIC COOPERATIVE

W/O#: Account: SO Nbr: 501160 Cycle: Date Needed: 08/30/2010
Srv Map Loc: 45-33

GENERAL MAINT

Home Phone: NONE LISTED
Work Phone: NONE LISTED
Mobile Phone: NONE LISTED

Electrician:	Service Desc:	Block:	Lot:
Permit #:	Subdivision:		
Inspection:	Builder:	Builder Ph:	None Listed
TRANSFORMER			
Transformer Loc#:	Sub:	Circuit:	Line Sect:
Serial #:	KVA:		Phase:
<u>INSTALLED:</u>			
Serial #:	KVA:		Phase:
METERS			
Serial #:	TWACS:	Port:	LV Rdg:
Reading:	Demand:	Mult:	L V Rdg Dt:
<u>INSTALLED:</u>			
Serial #:	TWACS:	Type:	Port:
Reading:	Demand:	Mult:	Dials:

DESCRIPTION:

B PHASE BREAKER OPEN IN MENOKEN SUB CCT3. ISOLATED LINE URD FAULT BETWEEN V1 SEC.27 AND V1 SEC.25. CLOSED BREAKER IN SUB AND CLOSED NORMAL OPEN AT 47-30 V1.

JOHN MIKE DALE STEVE K 8-27-10

FIELD COMMENTS:

Man Hours: _____
Unit/Mile: _____
Time Out: _____
Time On: _____
Completed By: _____
Date: _____



Dispatched To: _____
Job Briefing : _____
Close Date: 9/1/10
Taken By: ln 08/30/2010

CAPITAL ELECTRIC COOPERATIVE

W/O#: Account: SO Nbr: 500657 Cycle: Date Needed: 08/16/2010
Srv Map Loc: 45-33

POWER INTERRUPTION

Home Phone: NONE LISTED
Work Phone: NONE LISTED
Mobile Phone: NONE LISTED

Electrician:	Service Desc:	Block:	Lot:	
Permit #:	Subdivision:			
Inspection:	Builder:	Builder Ph:	None Listed	
TRANSFORMER				
Transformer Loc#:	Sub:	Circuit:	Line Sect:	
Serial #:	KVA:		Phase:	
<u>INSTALLED:</u>				
Serial #:	KVA:		Phase:	
METERS				
Serial #:	TWACS:	Port:	LV Rdg:	L V Rdg Dt:
Reading:	Demand:	Mult:	Dials:	Rate:
<u>INSTALLED:</u>				
Serial #:	TWACS:	Type:	Port:	
Reading:	Demand:	Mult:	Dials:	

DESCRIPTION:

8-16-10 1413 hrs no power was reported. OCR open in menoken sub 15-3-3

FAULT BETWEEN V1 ,AP 46 SEC 26 AND V2 SEC 25 CABLE IS PARKED ON BOTH ENDS. C PHASE

DUG UP FAULT AND SPLICED IT. IT HAD SPLICES, SO WE DUG UP OTHER SPLICE PIT 96FT TO THE WEST OF THIS ONE AND PUT NEW SPLICE ON IT. WE ALSO DUG UP THE THIRD SPLICE PIT 40 FT TO THE WEST OF THE SECOND ONE AND THAT ONE HAD A NEW SPLICE ON IT.

LES SETH BRAD STEVE K 8-16-10

FIELD COMMENTS:

Man Hours: _____
Unit/Mile: _____
Time Out: _____
Time On: _____
Completed By: _____
Date: _____



Dispatched To: _____
Job Briefing : _____
Close Date: 8/20/10
Taken By: lw 08/16/2010

CAPITAL ELECTRIC COOPERATIVE, INC.
PO Box 730 • Bismarck, ND 58502-0730

No 109409

fw

OUTAGE AND JOB ORDER

Const. No. _____ Retire No. _____ Office Ph. _____
Home Ph. _____

Name Line Outage
Address _____ Dispatched To _____
City _____ State & Zip _____
Area _____ Block _____ Lot _____
Electrician _____ Affidavit No. _____ Rate Class _____
Location: Map 45 Section 33 Detail _____ Account _____
Time Out 12:00 Am Time Reported _____
Time On 2:00 Am Members Affected 135
Miles Driven 43 Man-hours Required 9 1/2

Removed	TRANSFORMERS	Installed
Number _____		Number _____
KVA _____		KVA _____
		<input type="checkbox"/> AØ <input type="checkbox"/> BØ <input type="checkbox"/> CØ

METERS

Number _____	Number _____
Reading _____	Reading _____
Multiplier _____ Dials _____	Multiplier _____ Dials _____
Demand _____	Demand _____
TWACS Number _____	TWACS Number _____
<input type="checkbox"/> Job Briefing Conducted	TWACS Meter <input type="checkbox"/> 1 port <input type="checkbox"/> 3 port <input type="checkbox"/>

Description: No Power

Field Report: CØ ocr open in menoken sub CCT3
UBD Fault between V1 Sec. 33 Map 45 And V1
Sec 30 Map 47

Disconnect: _____ Acct No. _____
Connect: _____ Acct No. _____
Received by: SRS Completed by: Brad, Rick, Matt
Date: 6-16-09 Date: 6-16-09

15-3-3