

Date 09/15/2015	PSC Device Code 3V2	No. of Sections 2	Complete each item with Y (Yes), N (No), or NA (Not Applicable)	
Name of Business CHS INC. Feed Facility			Y New Installation (w/ RFI Check)	Y Performed Calibration
Mailing Address PO Box: 187, Street Address: Edgeley ND 58433			Y Modified Equipment	NA Use as a Reference Scale
Device Location/Name EDGELEY RLWS OTR - 003176			N Replaced Existing Equipment	N Non-Commercial
PO Box: 187, Street Address: 8170 HWY #13			Y Variance Permit Posted; Expiration Date: 03/07/2016	
City Edgeley	State ND	Zip Code 58433	NA Stored/Recalled Weights meet NDAC 69-10-02-23 & 69-10-02-24	
County Lamoure	Telephone Number 701-493-2271		NA Software is NTEP Approved	
Device Contact/Manager Wayne S Cook		Cell Number	NA Built-In Standards; Date Certified:	
Email Address wayne.cook@chsinc.com			Y Multiple Decks/Single Indicator	Y Customer Has Clear View
			Y Clearance Below Scale Clear	NA Video Camera Working
			Y Approach Requirements Met	NA View Distance > 200'
			Y Pit Coping and Crush Strip Good	NA Two-Way Audio Working
NA In response to PSC Quality Assurance Inspection				

Scale Information				
Scale Manufacturer RLWS OTR S/N: 5RMP	Indicator Manufacturer/Model RLWS 9201-2A	Indicator Serial No. 1665400144	Weighing Elements E / 4 Cell 75k	
Capacity/Divisions/Units 80,000 x 20 lbs	Legible Label _ Y _ N	Class III	Printer Manufacturer/Model Epson TM-U295	Printer Serial No. J9KF102067
Deck Size 10' x 15'6"	Clearance (inches) 36"	Approach - 12' Concrete Level East- OK - West 14"		Hard Surface Approach (Length/Slope/Condition) Good
SR or Discrimination Test Zero Load = NA Loaded = NA		Motion Detection Range = 3d	AZSM (Auto Zero) Range = 3d	

LBP / Section / Product Wt.	Value of Test Weights Used	Serial/Test Number	Errors +/-		LBP / Section / Product Wt.	Value of Test Weights Used	Serial/Test Number	Errors +/-	
			As Found	As Left				As Found	As Left
Description:									
1	10,000 lbs		+20	0	1	20,000 lbs		+40	
2	10,000 lbs		0	0	2	20,000 lbs		+20	
3	10,000 lbs		+20	0					
4	10,000 lbs		+20	0		BC=0@0			
	BC=0@0								

Strain Load Test		Remarks (include environmental conditions, if applicable). Attach additional sheets as necessary.
Section (Increasing or Decreasing)	Increasing Sec #2	
Full Truck Weight	61,720	
Test Weight	20,000	
Empty Truck Weight	41,720	
Errors		Quarterly test and inspection as per temporary variance requirement. Found plus on tolerance calibrated scale to 20,000 lb and adjusted corner #2 tolerance.
Physical Seal X Y _ N	Electronic Audit Trail: _ Y X N	
Seal Date: 09/15/2015	Audit Trail Information:	
Seal Type: Lead		
Meets tolerances in PSC adopted NIST Handbook 44? _ Maintenance <input checked="" type="checkbox"/> Acceptance		
<input checked="" type="checkbox"/> Approved _ Rejected _ Taken out of Service <input checked="" type="checkbox"/> Sticker Applied		
By signing this test report, I declare that I have examined this report and to the best of my knowledge and belief, the report is complete and the facts stated are sufficient, true and correct. I also declare that, except for conditions noted in "Remarks," the device meets the minimum requirements of the State laws and rules, including NIST Handbook 44, for use of the device in commerce.		
Permit Holder Signature	1337	
	Permit Number	
Operator Signature	09/15/2015	
	Date	