



APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY
 Public Service Commission
 SFN 51277 (2/2014)



TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED

Name of Company RJT Testing + Service LLC	Email Address joan.fults@yahoo.com	Application Date 4-23-15	
Mailing Address 49134 150th St	City Donnelly	State MN	Zip Code 56235
Telephone Number 320-589-4421	Cell Phone Number 320-288-6115	Fax Number	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: <u>100 gal</u> <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: <u>100 gal</u> <input checked="" type="checkbox"/> 5. LPG <input type="checkbox"/> 6. Stationary LPG <input checked="" type="checkbox"/> 7. Fertilizer: Max. Flow Rate: <u>100 gal</u> <input checked="" type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
e.g. 1001	e.g. John Doe	e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6
1710	Randy Fults	Liquid 2,3,4,5,7,8

Application for Registration as a Registered Service Company
Page 2



List below all field standards (attach current calibration reports):

100 gal LP Prover	
100 gal Refines Fuel	

Additional Application Items (initial where appropriate):


Standardized Test Report	<input checked="" type="checkbox"/> Copy enclosed
	<input type="checkbox"/> No change in report filed previously
Tested and Approved Sticker	<input type="checkbox"/> Copy enclosed
	<input checked="" type="checkbox"/> No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	<input type="checkbox"/> Copy enclosed
	<input checked="" type="checkbox"/> No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.

Yes No

I am Randy Fults, and have authority to represent this company. By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.



 Signature

Send Completed Application and Related Documents To:

Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480
Telephone: (701) 328-2400
Fax: (701) 328-2410

North Dakota

nd.gov

Official Portal for
North Dakota State GovernmentNorth Dakota
LEGISLATURE

SECRETARY OF STATE NORTH DAKOTA

[Home](#) | [Business Records Search](#)

RJT TESTING AND SERVICE, LLC

Corporation Details

System ID: 30651200**Phone:** (320) 589-4421**Type:** FOREIGN LIMITED LIABILITY COMPANY**Status:** Active & Good Standing**Original File Date:** 01/31/2012**Effective Date:** 01/31/2012**State of Origin:** Minnesota

Nature of Business

WEIGHTS & MEASURES & VK'S ON LP TRUCKS & REFINED FUEL TRUCKS

Principal Office

49134 150TH ST DONNELLY, MN 56235-1012

Registered Agent

JOHNSTON LAW OFFICE, P.C.

221 S 4TH ST

GRAND FORKS, ND 58201-4737

Established Date: Jan 31, 2012

Generate an Annual Report To File

To Generate a Annual Report form to be filed with the Secretary of State, select the appropriate year of the report you intend to file. This report does not contain details of a report previously filed with the Secretary of State. The annual report years reflected are an indication of the various report forms available in this site and is not an indication that an entity needs to file reports for all years. Missing years indicate that the forms for the missing year have not yet been deployed to the website, or have already been removed, and can be obtained by contacting the Secretary of State.

[2014](#) (generates a forms-fillable pdf in a new pop-up window)[Return to Search Results](#)[Contact Us](#)[Disclaimer](#)[Privacy Policy](#)

We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.



Receipt Date: December 8, 2014
Test Date: December 8, 2014
Report Date: December 8, 2014

State Test No.: 333513
Serial No.: 051271555-0101
Barcode: 202151

Calibration Report

RJT TESTING & SERVICE
49134 150TH ST
DONNELLY, MN 56235
Contact: RANDY FULTS
Phone: 320-589-4421
PO Number: NONE
SOP: 33
Technician ID: 13

Item(s) Submitted: 100 Gallon Prover
Manufacturer: Determan Brownie
Material: Stainless Steel (304)
Description: Dry Bottom
Condition: Good
Temperature: 19.3°C
Pressure: 737.9 mmHg
Relative Humidity: 32. %

Nominal Volume		Volume (gallons)	Error (in ³)	Uncertainty (in ³)	Coefficient of Expansion(°F)
100 gal	As Found	99.994	-1.4	3.0	0.0000288
	As Left	99.994	-1.4	3.0	

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow and at a reference temperature of 60 °F.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Kari Anderson

Kari Anderson
Metrologist

Reviewed by:

Mark Nicollet

Mark Nicollet
Quality Manager



Receipt Date: March 16, 2015
Test Date: March 17, 2015
Report Date: March 17, 2015

State Test No.: 333982
Serial No.: 44588
Barcode: 202232

Calibration Report

RJT TESTING & SERVICE
49134 150TH ST
DONNELLY, MN 56235
Contact: RANDY FULTS
Phone: 320-589-4421
PO Number: NONE
SOP: 34
Technician ID: 07

Item(s) Submitted: 100 gallon LPG Prover
Manufacturer: Arrow Tank
Material: Mild Steel
Description: Wet Bottom
Condition: Good
Temperature: 19.5°C
Pressure: 748.8 mmHg
Relative Humidity: 27. %

Nominal Volume	Error As Found (in ³)	Error As Left (in ³)	Uncertainty (in ³)	Coefficient of Expansion(°F)
100 gal	17	0	10	0.0000186

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel at a reference temperature of 60 °F and a reference pressure of 100 psig.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95%.


Results apply to item identified in this report only.

Mark Nicollet


Quality Manager

Reviewed by:

Pete Whebbe


Metrologist



Receipt Date: March 16, 2015
 Test Date: March 17, 2015
 Report Date: March 17, 2015

State Test No.: 333982
 Serial No.: 44588
 Barcode: 202232

Pressure Correction Chart

RJT TESTING & SERVICE
 49134 150TH ST
 DONNELLY, MN 56235
 Contact: RANDY FULTS
 Phone: 320-589-4421
 PO Number: NONE
 SOP: 34
 Technician ID: 07

Item(s) Submitted: 100 gallon LPG Prover
 Manufacturer: Arrow Tank
 Material: Mild Steel
 Description: Wet Bottom
 Condition: Good
 Temperature: 19.5°C
 Pressure: 748.8 mmHg
 Relative Humidity: 27. %

Pressure Gauge Reading (PSIG)	Volume Correction (gal)
0	-0.121
10	-0.107
20	-0.092
30	-0.077
40	-0.062
50	-0.048
60	-0.038
70	-0.028
80	-0.018
90	-0.009
100	0.001
110	0.009
120	0.018
130	0.026
140	0.034
150	0.042
160	0.053
170	0.063
180	0.073
190	0.083
200	0.094

Mark Nicollet


 Quality Manager

United States Department of Commerce

National Institute of Standards and Technology

Certificate of Metrological Traceability For:

Minnesota

This laboratory has demonstrated evidence of an unbroken chain of metrological traceability of its standards to the international system of units (SI), documented measurement uncertainties, uses documented measurement procedures, successfully completed training and proficiency tests, documented calibration intervals, submitted a quality management system, and demonstrated suitable measurement assurance for the Scope listed on this certificate.

The Office of Weights and Measures Program assesses laboratories to NIST Handbook 143 - Program Handbook for State Weights and Measures Laboratories and ISO/IEC 17025:2005.

Scope

Mass Echelon II

50 kg to 1 mg
1000 lb to 0.001 lb
4 oz to 0.03125 oz

Mass Echelon III

50 kg to 1 mg
5000 lb to 0.001 lb
4 oz to 0.03125 oz

Weight Carts

10 000 lb to 2000 lb

Wheel Load Weighers

20 000 lb to 2000 lb

Railroad Test Cars

110 000 lb to 80 000 lb

Volume Gravimetric, I

20 L to 1 mL
100 gal to 0.25 qt

Volume Transfer, II

1500 gal to 5 gal
100 gal to 25 gal LPG



2015

A handwritten signature in blue ink that reads "Carol T. Hockert".

Carol T. Hockert, Chief
NIST Office of Weights and Measures

Effective Dates: 2015-01-01 to 2015-12-31

RJT Testing and Service, LLC
 49134 150th Street, Donnelly, MN
 320.288.6115



COPY

Invoice Number

Operator No.	Date 4-23-15	Date Last Tested 4-14	Check All That Apply			
Name of Business (Hankinson) Wickenburg Diment Co-op Elev			<input type="checkbox"/> Self-Certification			
Location of Device 203 Main St			<input type="checkbox"/> New Installation			
Mailing Address PO Box 438			<input checked="" type="checkbox"/> Routine Service	<input checked="" type="checkbox"/> Annual	<input type="checkbox"/> Semi-Annual	
City Hankinson			<input type="checkbox"/> Equipment Repaired			
State ND			<input type="checkbox"/> Rejected Equipment Tag # (Attach)			
Zip Code 58041			<input type="checkbox"/> Non-Commercial			
County Richland			<input type="checkbox"/> Service Contract? Expires			
Telephone Number 701-640-8909			<input type="checkbox"/> Variance Posted? <input type="checkbox"/> Yes <input type="checkbox"/> No			

Standard Used Refined Fuel	Size 100 gal	Last Cal. Date 12-14
-------------------------------	-----------------	-------------------------

TYPE OF DEVICE/PSC CODE						
Retail Pump 16	Mobile Delivery 19	LPG Propane 21G	Liquid Fert./Agri Chemical 21F	Pipeline/Transport 20	CNG 21C	Other

Fill out all that apply:

Device Code	Meter/Pump/Hose #	Product	Serial #	Variance		Meter Factor/Totalizer Readings		Money Error	Approved (A) Rejected (R)
				As Found	As Left	Before	After		
				(State Units) 10 Lbs					
21F	TCS	Rdop	109-589052	100.0	100.0	28220	28220 28421		A
21F	TCS	BC Plus	061-571836	100.05	100.05	38604	38805		A
21F	TCS	V-NXT	604645	100.6	100.0	12024	12325		A

I hereby declare the statements made here are correct:		REMARKS & ADJUSTMENTS MADE	
Are there any other jurisdictional devices at this location that require testing? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Adjusted # 3 meters	
HAS SECURITY SEAL AND STICKER BEEN APPLIED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Rejected	Service Agency (Print) RJT Testing and Service, LLC		
Inspector/Permit Holder Signature <i>Ryan Paul</i>	Permit No. 1710		
Owner - Operator Signature <i>Delvin Jansen</i>			