

## Monthly Construction Progress Report

Case #: PU-14-852

Project: Lonesome Creek Station Unit 6

Month Ending: April 30, 2021

Title	Name	Company	Office Phone	Cell Phone
Project Manager	Trent Schwahn	BEPC	701-557-5128	701-202-3131
Project Engineer	Mark Jenson	BEPC	701-557-5661	701-595-2200
Field Coordinator	Darrell Slavick	BEPC	701-557-5146	701-202-5418
Contractor Project Manager	Paul Kikel	Casey Ind.	TBD	303-335-6962

### Project Safety & Environmental

The site had no major incidents this month.  
No recordable precipitation amounts at the site, just high winds, BMPs maintained per SWPPP.

### Construction Progress

- Finish mechanical installation of air filter house. Working on filters and sealing/cleaning.
- Finish assembling and welding SCR sections
- Continue installing aboveground piping
- Completed the remaining tie-ins to the existing facility piping
- Pulling wire and installing conduit/tray to skids and the main GE package
- Complete footings and wall concrete work for the new shop building, backfill ongoing

### Scheduled Activities

- Grout remaining skids
- Complete backfill and concrete floor placement for new shop building
- Continue conduit, cable, and instrument installation
- Wrap up above ground piping installation
- Fire protection installation

### Comments

None at this time.

Report Signatory	Date
Darrell Slavick      Field Coordinator	May 5, 2021