



**APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY**

Public Service Commission  
SFN 51277 (2/2014)



**TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED**

<b>Name of Company</b> Valley Petroleum Equipment Inc.	<b>Email Address</b> kathy@valleypetroleum.com	<b>Application Date</b> 6/12/15	
<b>Mailing Address</b> PO BOX 13355	<b>City</b> Grand Forks	<b>State</b> ND	<b>Zip Code</b> 58208-3355
<b>Telephone Number</b> 701-772-7201	<b>Cell Phone Number</b>	<b>Fax Number</b> 701-772-1301	

Select below all device types your company will certify:

<b>Scales (include maximum capacity, if applicable)</b>	<b>Liquid (include maximum flow rate, if applicable)</b>
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input checked="" type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: _____ <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: _____ <input type="checkbox"/> 5. LPG <input type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

<b>Permit No.</b>	<b>Employee</b>	<b>Device Types Registered to Certify (list using device type numbers from above)</b>
e.g. 1001	e.g. John Doe	e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6
1438	Steve Sulland	Liquid - 1, 2, 3, 4
1440	Dave Freije	" "
1596	Curtis Kurtz	" "
1643	Michael Bakken	" "
1713	Robert Schneider	" "
1615	Jon McMillan	Liquid - 3

Continued on Page 2

Application for Registration as a Registered Service Company  
Page 2

List below all field standards (attach current calibration reports):

Brownie 100 Gal - sn: 6841004-2	
Ellisco 5 Gal sn: None	
Serahhin 5 Gal - sn: 10-07753	
" " 42985	
" " 98-8992-15	
" " 10-07754	
" " 43326	
" " 98-8992-09	

Additional Application Items (initial where appropriate):

Standardized Test Report	<input checked="" type="checkbox"/> Copy enclosed
	<input checked="" type="checkbox"/> No change in report filed previously
Tested and Approved Sticker	<input type="checkbox"/> Copy enclosed
	<input checked="" type="checkbox"/> No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	<input type="checkbox"/> Copy enclosed
	<input checked="" type="checkbox"/> No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.

Yes     No

I am Kathy Reiser, Treasurer, and have authority to represent this company. By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.

Kathy Reiser  
Signature

Send Completed Application and Related Documents To:

Public Service Commission  
600 E Boulevard Ave Dept 408  
Bismarck ND 58505-0480  
Telephone: (701) 328-2400  
Fax: (701) 328-2410

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334356  
Serial No.: 6841004-2  
Barcode: 017726

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 33  
Technician ID: 11

Item(s) Submitted: 100 Gallon Prover  
Manufacturer: Brownie  
Material: Mild Steel  
Description: Dry Bottom  
Condition: Good  
Temperature: 22.8°C  
Pressure: 735.9 mmHg  
Relative Humidity: 57. %  
Standard H<sub>2</sub>O Temp.: 13.6 °C  
Artifact H<sub>2</sub>O Temp.: 13.8 °C

Nominal Volume (gal)		Tested Volume (gal)	Error (in <sup>3</sup> )	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion(°F)
100	As Found	100.011	2.8	3.0	0.0000186
	As Left	100.011	2.8	3.0	

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow and at a reference temperature of 60 °F.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Pete Whebbe



Metrologist

Reviewed by:

Mark Nicollet



Quality Manager

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334357  
Serial No.: 10-07754  
Barcode: 201426

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Seraphin  
Material: Stainless Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 19.4 °C  
Artifact H<sub>2</sub>O Temp.: 19.5 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (°F)
5	As Found	0.00	5.0000	0.62	0.0000265
	As Left	0.00	5.0000	0.62	

Neck Calibration: No neck calibration was done at this time.

This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Pete Whebbe



Metrologist

Reviewed by:  
Mark Nicollet



Quality Manager

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334358  
Serial No.: 98-8992-09  
Barcode: 018398

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Seraphin  
Material: Stainless Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 17.0 °C  
Artifact H<sub>2</sub>O Temp.: 17.1 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (°F)
5	As Found	-0.15	4.9994	0.62	0.0000265
	As Left	-0.15	4.9994	0.62	

Neck Calibration: No neck calibration was done at this time.


This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Pete Whebbe



Metrologist

Reviewed by:  
Mark Nicollet



Quality Manager

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334359  
Serial No.: 42985  
Barcode: 017725

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Seraphin  
Material: Mild Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 19.1 °C  
Artifact H<sub>2</sub>O Temp.: 19.2 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (°F)
5	As Found	-0.04	4.9998	0.62	0.0000186
	As Left	-0.04	4.9998	0.62	

Neck Calibration: No neck calibration was done at this time.


This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.


Pete Whebbe



Metrologist

Reviewed by:

Mark Nicollet



Quality Manager

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334360  
Serial No.: 10-07753  
Barcode: 201425

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Seraphin  
Material: Stainless Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 16.9 °C  
Artifact H<sub>2</sub>O Temp.: 17.1 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (°F)
5	As Found	0.31	5.0013	0.62	0.0000265
	As Left	0.00	5.0000	0.62	

Neck Calibration: No neck calibration was done at this time.

This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.


Pete Whebbe



Metrologist

Reviewed by:

Mark Nicollet



Quality Manager

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334361  
Serial No.: 43326  
Barcode: 017723

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Seraphin  
Material: Mild Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 19.2 °C  
Artifact H<sub>2</sub>O Temp.: 19.3 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero		Coefficient of Expansion (°F)
			Line (gal)	Uncertainty (in <sup>3</sup> )	
5	As Found	-0.04	4.9998	0.62	0.0000186
	As Left	-0.04	4.9998	0.62	

Neck Calibration: No neck calibration was done at this time.

This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Pete Whebbe



Metrologist

Reviewed by:

Mark Nicollet



Quality Manager



Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334362  
Serial No.: 98-8992-15  
Barcode: 018399

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Seraphin  
Material: Stainless Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 17.1 °C  
Artifact H<sub>2</sub>O Temp.: 17.2 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (°F)
5	As Found	-0.10	4.9996	0.62	0.0000265
	As Left	-0.10	4.9996	0.62	

Neck Calibration: No neck calibration was done at this time.

This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.


Results apply to item identified in this report only.

Pete Whebbe



Metrologist

Reviewed by:  
Mark Nicollet



Quality Manager

Receipt Date: June 8, 2015  
Test Date: June 8, 2015  
Report Date: June 8, 2015

State Test No.: 334363  
Serial No.: None  
Barcode: 017724

## Calibration Report

VALLEY PETROLEUM EQUIP  
5510 10TH AVE NE  
GRAND FORKS, ND 58206-1355  
Contact: STEVE SULLAND  
Phone: 701-772-7261  
PO Number: NONE  
SOP: 32  
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure  
Manufacturer: Ellisco  
Material: Mild Steel  
Equipment Number: None  
Condition: Good  
Temperature: 23.1 °C  
Pressure: 729.9 mmHg  
Relative Humidity: 52. %  
Standard H<sub>2</sub>O Temp.: 19.2 °C  
Artifact H<sub>2</sub>O Temp.: 19.3 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (°F)
5	As Found	-0.08	4.9997	0.62	0.0000186
	As Left	-0.08	4.9997	0.62	

Neck Calibration: No neck calibration was done at this time.


This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.


Results apply to item identified in this report only.

Pete Whebbe



Metrologist

Reviewed by:  
Mark Nicollet



Quality Manager