



Receipt Date: June 16, 2015  
Test Date: June 18, 2015  
Report Date: June 18, 2015

State Test No.: 334409  
Serial No.: 24360  
Barcode: 201188

## Calibration Report

WESTMOR FLUID SOLUTIONS LLC  
14044 W. FREEWAY DRIVE  
COLUMBUS, MN 55038  
Contact: Ryan Hartin  
Phone: 763-502-9613  
PO Number: NONE  
SOP: 34  
Technician ID: 11

Item(s) Submitted: 25 gallon LPG Prover  
Manufacturer: Arrow  
Material: Mild Steel  
Description: Wet Bottom  
Condition: Good  
Temperature: 25.1°C  
Pressure: 737.6 mmHg  
Relative Humidity: 53. %  
Standard H<sub>2</sub>O Temp.: 16.8 °C  
Artifact H<sub>2</sub>O Temp.: 17.4 °C

Nominal Volume (gal)	Error As Found (in <sup>3</sup> )	Error As Left (in <sup>3</sup> )	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion(°F)
25	-5	-5	4	0.0000186

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel at a reference temperature of 60 °F and a reference pressure of 100 psig.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95%.

Results apply to item identified in this report only.

Pete Whebbe

*Pete Whebbe*  
Metrologist

Reviewed by:

Mark Nicollet

*Mark Nicollet*  
Quality Manager



Receipt Date: June 16, 2015  
 Test Date: June 18, 2015  
 Report Date: June 18, 2015

State Test No.: 334409  
 Serial No.: 24360  
 Barcode: 201188

## Pressure Correction Chart

WESTMOR FLUID SOLUTIONS LLC  
 14044 W. FREEWAY DRIVE  
 COLUMBUS, MN 55038  
 Contact: Ryan Hartin  
 Phone: 763-502-9613  
 PO Number: NONE  
 SOP: 34  
 Technician ID: 11

Item(s) Submitted: 25 gallon LPG Prover  
 Manufacturer: Arrow  
 Material: Mild Steel  
 Description: Wet Bottom  
 Condition: Good  
 Temperature: 25.1°C  
 Pressure: 737.6 mmHg  
 Relative Humidity: 53. %

Pressure Gauge Reading (PSIG)	Volume Correction (gal)
0	-0.079
10	-0.071
20	-0.062
30	-0.054
40	-0.045
50	-0.037
60	-0.034
70	-0.031
80	-0.028
90	-0.025
100	-0.022
110	-0.019
120	-0.017
130	-0.014
140	-0.012
150	-0.009
160	-0.007
170	-0.004
180	-0.002
190	0.001
200	0.003

Pete Whebbe

Metrologist



Receipt Date: June 16, 2015  
Test Date: June 17, 2015  
Report Date: June 17, 2015

State Test No.: 334410  
Serial No.: 28816  
Barcode: 019785

## Calibration Report

WESTMOR FLUID SOLUTIONS LLC  
14044 W. FREEWAY DRIVE  
COLUMBUS, MN 55038  
Contact: Ryan Hartin  
Phone: 763-502-9613  
PO Number: NONE  
SOP: 34  
Technician ID: 11

Item(s) Submitted: 100 gallon LPG Prover  
Manufacturer: ARROW  
Material: Mild Steel  
Description: Wet Bottom  
Condition: Good  
Temperature: 25.5°C  
Pressure: 735.1 mmHg  
Relative Humidity: 50. %  
Standard H<sub>2</sub>O Temp.: 15.1 °C  
Artifact H<sub>2</sub>O Temp.: 15.7 °C

Nominal Volume (gal)	Error As Found (in <sup>3</sup> )	Error As Left (in <sup>3</sup> )	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion(°F)
100	-14	-14	10	0.0000186

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel at a reference temperature of 60 °F and a reference pressure of 100 psig.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95%.

Results apply to item identified in this report only.

Pete Whebbe

*Pete Whebbe*  
Metrologist

Reviewed by:

Mark Nicollet

*Mark Nicollet*  
Quality Manager



Receipt Date: June 16, 2015  
 Test Date: June 17, 2015  
 Report Date: June 17, 2015

State Test No.: 334410  
 Serial No.: 28816  
 Barcode: 019785

## Pressure Correction Chart

WESTMOR FLUID SOLUTIONS LLC  
 14044 W. FREEWAY DRIVE  
 COLUMBUS, MN 55038  
 Contact: Ryan Hartin  
 Phone: 763-502-9613  
 PO Number: NONE  
 SOP: 34  
 Technician ID: 11

Item(s) Submitted: 100 gallon LPG Prover  
 Manufacturer: ARROW  
 Material: Mild Steel  
 Description: Wet Bottom  
 Condition: Good  
 Temperature: 25.5°C  
 Pressure: 735.1 mmHg  
 Relative Humidity: 50. %

Pressure Gauge Reading (PSIG)	Volume Correction (gal)
0	-0.228
10	-0.207
20	-0.186
30	-0.165
40	-0.144
50	-0.123
60	-0.111
70	-0.098
80	-0.086
90	-0.073
100	-0.061
110	-0.054
120	-0.047
130	-0.040
140	-0.033
150	-0.026
160	-0.020
170	-0.015
180	-0.009
190	-0.004
200	0.002

Pete Whebbe

Metrologist



Receipt Date: June 16, 2015  
Test Date: June 16, 2015  
Report Date: June 17, 2015

State Test No.: 334411  
Set Serial No.: None  
Barcode: 201189

## Calibration Report

WESTMOR FLUID SOLUTIONS LLC  
14044 W. FREEWAY DRIVE  
COLUMBUS, MN 55038

Contact: Ryan Hartin  
Phone: 763-502-9613  
PO Number: NONE  
SOP: 12  
Technician ID: 11

Item(s) Submitted: Cast Hand Weights  
Manufacturer: Rice Lake  
ASTM E617 Type: II  
Equipment ID#: None  
Condition: Fair/Heavy Paint  
Temperature: 20.°C  
Pressure: 740.3 mmHg  
Relative Humidity: 45. %

Nominal Value	Serial No.	Correction (mg)		NIST HB 105-1 Class		Unc. (mg) (k=2)
		As Found	As Left	As Found	As Left	
25 lb		9980.	590.	*	F	75.
25 lb		10630.	-30.	*	F	75.
25 lb		10140.	-260.	*	F	75.
25 lb		9590.	800.	*	F	75.
25 lb		9240.	-50.	*	F	75.
25 lb		9370.	470.	*	F	75.
25 lb		10130.	-40.	*	F	75.
25 lb		8640.	130.	*	F	75.
25 lb		10640.	30.	*	F	75.
25 lb		10410.	690.	*	F	75.
25 lb		10510.	210.	*	F	75.
25 lb		8250.	410.	*	F	75.
25 lb		10390.	110.	*	F	75.
25 lb		7450.	50.	*	F	75.
25 lb		10550.	80.	*	F	75.
25 lb		10180.	130.	*	F	75.
25 lb		8510.	30.	*	F	75.
25 lb		9730.	500.	*	F	75.
25 lb		9320.	-60.	*	F	75.
25 lb		10390.	160.	*	F	75.

\* Weight(s) as found exceed NIST HB 105-1 Class F tolerance.

**Weights were heavily painted. A light coat of sprayed-on flat aluminum paint is recommended. See attached.**

When used as a set these weights meet NIST HB 105-1 class F tolerances.

The resulting tolerance class of the weight is determined by combining the correction of the weight and the uncertainty of the measurement. The corrections given above correlate to a conventional mass scale versus 8.0 g/cm<sup>3</sup> density and an air density of 1.2 mg/cm<sup>3</sup>. The items listed above have been compared to the Standards of the State of Minnesota which are currently in control. These standards are traceable to the SI through NIST. Calibration processes were monitored and found to be in control. Uncertainty calculations conform to NIST Technical Note 1297. Results apply to items identified in this report only.

Pete Whobbe

*Peter J. Whobbe*  
Metrologist

Reviewed by:

Mark Nicollet

*Mark Nicollet*  
Quality Manager