



APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY

Public Service Commission
SFN 51277 (2/2014)



TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED

Name of Company <i>CMS Petroleum Equipment</i>	Email Address <i>CMSPetroleum@hotmail.com</i>	Application Date	
Mailing Address <i>P.O. Box 85</i>	City <i>Morris</i>	State <i>ND</i>	Zip Code <i>58267</i>
Telephone Number <i>320 589 9017</i>	Cell Phone Number <i>320 760 9680</i>	Fax Number <i>320 589 2827</i>	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: <u>100</u> <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: <u>100</u> <input checked="" type="checkbox"/> 5. LPG <input checked="" type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
<i>e.g. 1001</i>	<i>e.g. John Doe</i>	<i>e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6</i>
<i>1729</i>	<i>Joe McNally</i>	<i>3456</i>
<i>1730</i>	<i>Jeff Finke</i>	<i>3458</i>
<i>1733</i>	<i>John Schuitz</i>	<i>3454</i>



List below all field standards (attach current calibration reports):

100 GALLON LP	
100 GALLON REFRIG	


Additional Application Items (initial where appropriate):

Standardized Test Report	<input checked="" type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> No change in report filed previously
Tested and Approved Sticker	<input checked="" type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	<input checked="" type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.
 Yes No

I am Joel McNally, and have authority to represent this company.
By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.



Signature

Send Completed Application and Related Documents To:

Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480
Telephone: (701) 328-2400
Fax: (701) 328-2410



Receipt Date: November 30, 2015
 Test Date: December 2, 2015
 Report Date: December 2, 2015

State Test No.: 335146
 Serial No.: 33011
 Barcode: 018524

Calibration Report

CMS PETROLEUM EQUIPMENT
 48150 210TH ST
 MORRIS, MN 56267
 Contact: Joel McNally
 Phone: 320-589-9017
 PO Number: NONE
 SOP: 34
 Technician ID: 11

Item(s) Submitted: 100 Gallon LPG Prover
 Manufacturer: Arrow Tank & Eng
 Material: Mild Steel
 Description: Wet Bottom
 Condition: Good
 Temperature: 18.2 °C
 Pressure: 734.5 mmHg
 Relative Humidity: 40. %
 Standard H₂O Temp.: 13.1 °C
 Artifact H₂O Temp.: 13.3 °C

Nominal Volume (gal)	Error As Found (in ³)	Error As Left (in ³)	Uncertainty (in ³)	Coefficient of Expansion(°F)
100	-2	-2	10	0.0000186

Neck Calibration: No neck calibration was done at this time.


This prover has been calibrated as a "to contain after wet down" vessel at a reference temperature of 60 °F and a reference pressure of 100 psig.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.


The reported uncertainty conforms to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008). The confidence interval is 95%.

Results apply to item identified in this report only.

Pete Whebbe


 Metrologist

Reviewed by:
 Mark Nicollet


 Quality Manager



Receipt Date: November 30, 2015
 Test Date: December 2, 2015
 Report Date: December 2, 2015

State Test No.: 335145
 Serial No.: 102
 Barcode: 017450

Calibration Report

CMS PETROLEUM EQUIPMENT
 48150 210TH ST
 MORRIS, MN 56267
 Contact: Joel McNally
 Phone: 320-589-9017
 PO Number: NONE
 SOP: 33
 Technician ID: 11

Item(s) Submitted: 100 Gallon Prover
 Manufacturer: Kleespie
 Material: Mild Steel
 Description: Dry Bottom
 Condition: Fair
 Temperature: 18.2 °C
 Pressure: 734. mmHg
 Relative Humidity: 39.3 %
 Standard H₂O Temp.: 13.3 °C
 Artifact H₂O Temp.: 13.4 °C

Nominal Volume (gal)		Tested Volume (gal)	Error (in ³)	Uncertainty (in ³)	Coefficient of Expansion(/°F)
100	As Found	99.972	-6.5	3.0	0.0000195
	As Left	99.999	-0.2	3.0	

Neck Calibration: No neck calibration was done at this time.

Prover has minor leak at bottom of sight gauge; did not affect calibration-no visible change in reading after 20 minutes; must be repaired.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow and at a reference temperature of 60 °F.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008). The confidence interval is 95%.

Pete Whebbe

Metrologist

Reviewed by:

Mark Nicollet

Quality Manager



Receipt Date: November 30, 2015
 Test Date: December 2, 2015
 Report Date: December 2, 2015

State Test No.: 335146
 Serial No.: 33011
 Barcode: 18524

Pressure Correction Chart

CMS PETROLEUM EQUIPMENT
 48150 210TH ST
 MORRIS, MN 56267
 Contact: Joel McNally
 Phone: 320-589-9017
 PO Number: NONE
 SOP: 34
 Technician ID: 11

Item(s) Submitted: 100 Gallon LPG Prover
 Manufacturer: Arrow Tank & Eng
 Material: Mild Steel
 Description: Wet Bottom
 Condition: Good
 Temperature: 18.2°C
 Pressure: 734.5 mmHg
 Relative Humidity: 40. %

Pressure Gauge Reading (PSIG)	Volume Correction (gal)
0	-0.119
10	-0.109
20	-0.100
30	-0.090
40	-0.081
50	-0.071
60	-0.059
70	-0.046
80	-0.034
90	-0.021
100	-0.009
110	-0.003
120	0.003
130	0.009
140	0.015
150	0.021
160	0.028
170	0.035
180	0.042
190	0.049
200	0.056

Pete Whebbe

Metrologist

United States Department of Commerce

National Institute of Standards and Technology

Certificate of Metrological Traceability For:

Minnesota



This laboratory has demonstrated evidence of an unbroken chain of metrological traceability of its standards to the international system of units (SI), documented measurement uncertainties, uses documented measurement procedures, successfully completed training and proficiency tests, documented calibration intervals, submitted a quality management system, and demonstrated suitable measurement assurance for the Scope listed on this certificate.

The Office of Weights and Measures Program assesses laboratories to NIST Handbook 143 - Program Handbook for State Weights and Measures Laboratories and ISO/IEC 17025:2005.

2015

Scope

Mass Echelon II	Weight Carts	Volume Gravimetric, I
50 kg to 1 mg	10 000 lb to 2000 lb	20 L to 1 mL
1000 lb to 0.001 lb	Wheel Load Weighers	100 gal to 0.25 qt
4 oz to 0.03125 oz	20 000 lb to 2000 lb	Volume Transfer, II
Mass Echelon III	Railroad Test Cars	1500 gal to 5 gal
50 kg to 1 mg	110 000 lb to 80 000 lb	100 gal to 25 gal LPG
5000 lb to 0.001 lb		
4 oz to 0.03125 oz		

A handwritten signature in blue ink, appearing to read "Carol T. Hockett".

Carol T. Hockett, Chief
NIST Office of Weights and Measures

Effective Dates: 2015-01-01 to 2015-12-31



SECRETARY OF STATE NORTH DAKOTA



[Home](#) | [Business Records Search](#)

CMS PETROLEUM EQUIPMENT CO.

Corporation Details

System ID: 12648800 **Phone:** (320) 589-9017
Type: FOREIGN BUSINESS CORPORATION
Status: Active & Good Standing
Original File Date: 04/07/1999 **Effective Date:** 04/07/1999
State of Origin: Minnesota

Nature of Business

PETROLEUM EQUIPMENT SALES & SERVICE

Principal Office

48505 210TH ST PO BOX 85 MORRIS, MN 56267-0085

Registered Agent

QUAM PETROLEUM SERVICE, INC.
4720 HWY 6 S
MANDAN, ND 58554-8513
Established Date: Jun 06, 2005

Generate an Annual Report To File

To Generate a Annual Report form to be filed with the Secretary of State, select the appropriate year of the report you intend to file. This report does not contain details of a report previously filed with the Secretary of State. The annual report years reflected are an indication of the various report forms available in this site and is not an indication that an entity needs to file reports for all years. Missing years indicate that the forms for the missing year have not yet been deployed to the website, or have already been removed, and can be obtained by contacting the Secretary of State.

[2015](#) (generates a forms-fillable pdf in a new pop-up window)

[Return to Search Results](#)

[Contact Us](#)

[Disclaimer](#) | [Privacy Policy](#)

 We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

 Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.