



APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY

Public Service Commission
SFN 51277 (2/2014)



TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED

Name of Company RJT Testing + Service	Email Address Joan Fults @ Yahoo.com	Application Date 12-28-15	
Mailing Address 49134 150th st	City Donnelly	State MN	Zip Code 56235
Telephone Number 320-589-4421	Cell Phone Number 320-288-6115	Fax Number 320-589-4421	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: <u>150 gal</u> <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: <u>100 gal</u> <input checked="" type="checkbox"/> 5. LPG <input checked="" type="checkbox"/> 6. Stationary LPG <input checked="" type="checkbox"/> 7. Fertilizer: Max. Flow Rate: <u>100 gal</u> <input checked="" type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
e.g. 1001	e.g. John Doe	e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6
1710	Randy Fults	Liquid - 2, 3, 5, 6, 7, 8



List below all field standards (attach current calibration reports):

100 gal Refined Fuel	100 gal LP Prover

Additional Application Items (initial where appropriate):


Standardized Test Report	<input type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> <u>XRF</u> No change in report filed previously
Tested and Approved Sticker	<input type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> <u>XRF</u> No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	<input type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> <u>XRF</u> No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.

Yes No

I am Randy Fulst, and have authority to represent this company. By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.




 Signature

Send Completed Application and Related Documents To:

Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480
Telephone: (701) 328-2400
Fax: (701) 328-2410

North Dakota

nd.gov Official Portal for
North Dakota State GovernmentNorth Dakota
LEGENDARY

SECRETARY OF STATE NORTH DAKOTA

[Home](#) | [Business Records Search](#)

RJT TESTING AND SERVICE, LLC

Corporation Details

System ID: 30651200 **Phone:** (320) 589-4421
Type: FOREIGN LIMITED LIABILITY COMPANY
Status: Active & Good Standing
Original File Date: 01/31/2012 **Effective Date:** 01/31/2012
State of Origin: Minnesota

Nature of Business

WEIGHTS & MEASURES & VK'S ON LP TRUCKS & REFINED FUEL TRUCKS

Principal Office

49134 150TH ST DONNELLY, MN 56235-1012

Registered Agent

JOHNSTON LAW OFFICE, P.C.
221 S 4TH ST
GRAND FORKS, ND 58201-4737
Established Date: Jan 31, 2012

Generate an Annual Report To File

To Generate a Annual Report form to be filed with the Secretary of State, select the appropriate year of the report you intend to file. This report does not contain details of a report previously filed with the Secretary of State. The annual report years reflected are an indication of the various report forms available in this site and is not an indication that an entity needs to file reports for all years. Missing years indicate that the forms for the missing year have not yet been deployed to the website, or have already been removed, and can be obtained by contacting the Secretary of State.

[2015](#) (generates a forms-fillable pdf in a new pop-up window)

[Return to Search Results](#)

[Contact Us](#)[Disclaimer](#) | [Privacy Policy](#)

We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.



Receipt Date: December 7, 2015
Test Date: December 7, 2015
Report Date: December 7, 2015

State Test No.: 335168
Serial No.: 051271555-0101
Barcode: 202151

Calibration Report

RJT TESTING & SERVICE
49134 150TH ST
DONNELLY, MN 56235

Contact: Randy Fults
Phone: 320-589-4421
PO Number: None
SOP: 33
Technician ID: 19

Item(s) Submitted: 100 Gallon Prover
Manufacturer: Determan Brownie
Material: Stainless Steel (304)
Description: Dry Bottom
Condition: Good
Temperature: 18.0 °C
Pressure: 737.7 mmHg
Relative Humidity: 39.4 %
Standard H₂O Temp.: 13.0 °C
Artifact H₂O Temp.: 13.1 °C

Nominal Volume (gal)		Tested Volume (gal)	Error (in ³)	Uncertainty (in ³)	Coefficient of Expansion(°F)
100	As Found	100.009	2.0	3.0	0.0000288
	As Left	100.009	2.0	3.0	

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow and at a reference temperature of 60 °F.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008). The confidence interval is 95%.

Erik Alfvin

Metrologist

Reviewed by:


Mark Nicollet

Quality Manager

*will be
retested
in
3-16*

Receipt Date: March 16, 2015
Test Date: March 17, 2015
Report Date: March 17, 2015

State Test No.: 333982
Serial No.: 44588
Barcode: 202232



Calibration Report

RJT TESTING & SERVICE
49134 150TH ST
DONNELLY, MN 56235
Contact: RANDY FULTS
Phone: 320-589-4421
PO Number: NONE
SOP: 34
Technician ID: 07

Item(s) Submitted: 100 gallon LPG Prover
Manufacturer: Arrow Tank
Material: Mild Steel
Description: Wet Bottom
Condition: Good
Temperature: 19.5°C
Pressure: 748.8 mmHg
Relative Humidity: 27. %

Nominal Volume	Error As Found (in ³)	Error As Left (in ³)	Uncertainty (in ³)	Coefficient of Expansion(°F)
100 gal	17	0	10	0.0000186

Neck Calibration: No neck calibration was done at this time.

This prover has been calibrated as a "to contain after wet down" vessel at a reference temperature of 60 °F and a reference pressure of 100 psig.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95%.

Results apply to item identified in this report only.

Mark Nicollet

Mark Nicollet
Quality Manager

Reviewed by:

Pete Whebbe

Pete Whebbe
Metrologist

Receipt Date: March 16, 2015
Test Date: March 17, 2015
Report Date: March 17, 2015

State Test No.: 333982
Serial No.: 44588
Barcode: 202232



Pressure Correction Chart

RJT TESTING & SERVICE
49134 150TH ST
DONNELLY, MN 56235
Contact: RANDY FULTS
Phone: 320-589-4421
PO Number: NONE
SOP: 34
Technician ID: 07

Item(s) Submitted: 100 gallon LPG Prover
Manufacturer: Arrow Tank
Material: Mild Steel
Description: Wet Bottom
Condition: Good
Temperature: 19.5°C
Pressure: 748.8 mmHg
Relative Humidity: 27. %

Pressure Gauge Reading (PSIG)	Volume Correction (gal)
0	-0.121
10	-0.107
20	-0.092
30	-0.077
40	-0.062
50	-0.048
60	-0.038
70	-0.028
80	-0.018
90	-0.009
100	0.001
110	0.009
120	0.018
130	0.026
140	0.034
150	0.042
160	0.053
170	0.063
180	0.073
190	0.083
200	0.094

Mark Nicollet



Quality Manager

United States Department of Commerce

National Institute of Standards and Technology

Certificate of Metrological Traceability For:

Minnesota



This laboratory has demonstrated evidence of an unbroken chain of metrological traceability of its standards to the international system of units (SI), documented measurement uncertainties, uses documented measurement procedures, successfully completed training and proficiency tests, documented calibration intervals, submitted a quality management system, and demonstrated suitable measurement assurance for the Scope listed on this certificate.

The Office of Weights and Measures Program assesses laboratories to NIST Handbook 143 - Program Handbook for State Weights and Measures Laboratories and ISO/IEC 17025:2005.

2015

Scope

Mass Echelon II
50 kg to 1 mg
1000 lb to 0.001 lb
4 oz to 0.03125 oz

Mass Echelon III
50 kg to 1 mg
5000 lb to 0.001 lb
4 oz to 0.03125 oz

Weight Carts
10 000 lb to 2000 lb

Wheel Load Weighers
20 000 lb to 2000 lb

Railroad Test Cars
110 000 lb to 80 000 lb

Volume Gravimetric, I
20 L to 1 mL
100 gal to 0.25 qt

Volume Transfer, II
1500 gal to 5 gal
100 gal to 25 gal LPG

A handwritten signature in blue ink, appearing to read "Carol T. Hockert".

Carol T. Hockert, Chief
NIST Office of Weights and Measures

Effective Dates: 2015-01-01 to 2015-12-31