



**APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY**

Public Service Commission  
SFN 51277 (2/2014)



**TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED**

<b>Name of Company</b> Midwest Pump & Tank	<b>Email Address</b> mpt@midwestpump.com	<b>Application Date</b> Feb 26, 2016	
<b>Mailing Address</b> 820 South Hwy 281 PO Box 2105	<b>City</b> ABERDEEN	<b>State</b> SD	<b>Zip Code</b> 57401
<b>Telephone Number</b> 605-225-0577	<b>Cell Phone Number</b> 605-380-5185	<b>Fax Number</b> 605-225-0516	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input checked="" type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: <u>100</u> <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: <u>100</u> <input type="checkbox"/> 5. LPG <input type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
e.g. 1001	e.g. John Doe	e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6
1415	JOE JUVE	Liquid 1, 2, 3, 4
1533	JERRY SJERVEN	Liquid 1, 2, 3, 4




Application for Registration as a Registered Service Company

Page 2

List below all field standards (attach current calibration reports):

SERAPHIN 5 gallon	S# 07-05607
ELLISCO 5 gallon	No S#
GAS SERVICE + Supply 100gal	S# 1221


Additional Application Items (initial where appropriate):

Standardized Test Report		Copy enclosed No change in report filed previously
Tested and Approved Sticker		Copy enclosed No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal		Copy enclosed No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.  
 Yes     No

I am JERRY SIERVEN, and have authority to represent this company.  
By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.

  
Signature

Send Completed Application and Related Documents To:

Public Service Commission  
600 E Boulevard Ave Dept 408  
Bismarck ND 58505-0480  
Telephone: (701) 328-2400  
Fax: (701) 328-2410

Receipt Date: June 5, 2015  
 Test Date: June 5, 2015  
 Report Date: June 5, 2015

State Test No.: 334351  
 Serial No.: None  
 Barcode: 013146

## Calibration Report

MIDWEST PUMP & TANK  
 820 S HWY 281  
 ABERDEEN, SD 57402-2105  
 Contact: JERRY  
 Phone: 605-380-5185  
 PO Number: NONE  
 SOP: 32  
 Technician ID: 07

Item(s) Submitted: 5 Gallon Measure  
 Manufacturer: Seraphin  
 Material: Mild Steel  
 Equipment Number: None  
 Condition: Good  
 Temperature: 23.6 °C  
 Pressure: 741.5 mmHg  
 Relative Humidity: 56. %  
 Standard H<sub>2</sub>O Temp.: 22.4 °C  
 Artifact H<sub>2</sub>O Temp.: 22.4 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (1/°F)
5	As Found	0.26	5.0011	0.62	0.0000186
	As Left	0.26	5.0011	0.62	

Neck Calibration: No neck calibration was done at this time.


This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.


The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Mark Nicollet

  
 Quality Manager

Reviewed by:  
 Pete Whebbe

  
 Metrologist

Receipt Date: June 5, 2015  
 Test Date: June 5, 2015  
 Report Date: June 5, 2015

State Test No.: 334350  
 Serial No.: 07-05607  
 Barcode: 013144

## Calibration Report

MIDWEST PUMP & TANK  
 820 S HWY 281  
 ABERDEEN, SD 57402-2105  
 Contact: Jerry Sjervew  
 Phone: 605-380-5185  
 PO Number: NONE  
 SOP: 32  
 Technician ID: 07

Item(s) Submitted: 5 Gallon Measure  
 Manufacturer: Seraphin  
 Material: Stainless Steel  
 Equipment Number: None  
 Condition: Good  
 Temperature: 23.6 °C  
 Pressure: 741.5 mmHg  
 Relative Humidity: 56. %  
 Standard H<sub>2</sub>O Temp.: 22.3 °C  
 Artifact H<sub>2</sub>O Temp.: 22.3 °C

Nominal Volume (gal)		Error (in <sup>3</sup> )	Volume at Zero Line (gal)	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion (1/°F)
5	As Found	0.31	5.0013	0.62	0.0000265
	As Left	0.14	5.0006	0.62	

Neck Calibration: No neck calibration was done at this time.

This measure or prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds, a drain time of 10 seconds after cessation of full flow and at a reference temperature of 60 °F.

The measure or prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.


The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.

Results apply to item identified in this report only.

Mark Nicollet

  
 Quality Manager

Reviewed by:  
 Pete Whebbe

  
 Metrologist

Receipt Date: June 5, 2015  
Test Date: June 5, 2015  
Report Date: June 5, 2015

State Test No.: 334349  
Serial No.: 1221  
Barcode: 201254

## Calibration Report

MIDWEST PUMP & TANK  
820 S HWY 281  
ABERDEEN, SD 57402-2105  
Contact: JERRY  
Phone: 605-380-5185  
PO Number: NONE  
SOP: 33  
Technician ID: 07

Item(s) Submitted: 100 Gallon Prover  
Manufacturer: Gas Service & Supply  
Material: Stainless Steel  
Description: Dry Bottom  
Condition: Excellent  
Temperature: 23.3°C  
Pressure: 741.5 mmHg  
Relative Humidity: 58. %  
Standard H<sub>2</sub>O Temp.: 12.9 °C  
Artifact H<sub>2</sub>O Temp.: 13.0 °C

Nominal Volume (gal)		Tested Volume (gal)	Error (in <sup>3</sup> )	Uncertainty (in <sup>3</sup> )	Coefficient of Expansion(°F)
100	As Found	99.992	-1.8	3.0	0.0000265
	As Left	99.992	-1.8	3.0	

Neck Calibration: No neck calibration was done at this time.


This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow and at a reference temperature of 60 °F.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

The reported uncertainty conforms to NIST Technical Note 1297. The confidence interval is 95 %.


Results apply to item identified in this report only.

Mark Nicollet

  
Quality Manager

Reviewed by:

Pete Whebbe

  
Metrologist