



**APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY**  
 Public Service Commission  
 SFN 51277 (2/2014)



**TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED**

<b>Name of Company</b>		<b>Email Address</b>		<b>Application Date</b>	
North Country Business Products		naylor@ncbpine.com		2/26/16	
<b>Mailing Address</b>		<b>City</b>		<b>State</b>	<b>Zip Code</b>
4626 Amber Valley Pkwy		Fargo		ND	58104
<b>Telephone Number</b>		<b>Cell Phone Number</b>		<b>Fax Number</b>	
(701) 277-3231		N/A		(701) 277-3246	

Select below all device types your company will certify:

<b>Scales (include maximum capacity, if applicable)</b>	<b>Liquid (include maximum flow rate, if applicable)</b>
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input checked="" type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: _____ <input type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: _____ <input type="checkbox"/> 5. LPG <input type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

<b>Permit No.</b>	<b>Employee</b>	<b>Device Types Registered to Certify (list using device type numbers from above)</b>
e.g. 1001	e.g. John Doe	e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6
1587	Roger Wilman	Scales - 7
1734	Peter Beiss	
11010	Cory Keith	
11679	Ben Moore	
1553	Chris Thompson	
1466	David Naylor	

Continued on Page 2

Pages: 7

WM-16-107 Filed: 3/2/2016 Application for permit

2

North Country Business Products, Inc.

List below all field standards (attach current calibration reports):

(5) 30# weight sets (attached)	


Additional Application Items (initial where appropriate):

Standardized Test Report	<input type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> No change in report filed previously
Tested and Approved Sticker	<input type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	<input type="checkbox"/> Copy enclosed <input checked="" type="checkbox"/> No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.  
 Yes     No

I am Dave Naylor, and have authority to represent this company.  
 By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.

  
 Signature

Send Completed Application and Related Documents To:

Public Service Commission  
 600 E Boulevard Ave Dept 408  
 Bismarck ND 58505-0480  
**Telephone:** (701) 328-2400  
**Fax:** (701) 328-2410

Receipt Date: April 10, 2015  
 Test Date: April 28, 2015  
 Report Date: April 28, 2015

State Test No.: 334119  
 Set Serial No.: None  
 Barcode: 201261

## Calibration Report

NORTH COUNTRY BUSINESS PRODUCTS  
 2127 S. MINNESOTA AVE. #205  
 SIOUX FALLS, SD 56619  
 Contact: CAROL BRAUN  
 Phone: 218-722-3528  
 PO Number: NONE  
 SOP: 12  
 Technician ID: 09

Item(s) Submitted: 30 lb kit w/decimals  
 Manufacturer: Rice Lake  
 ASTM E617 Type: I & II  
 Equipment ID#: None  
 Condition: Good  
 Temperature: 20.1°C  
 Pressure: 740.8 mmHg  
 Relative Humidity: 52. %

*SIOUX FALLS*

Nominal Value	Serial No.	Correction (mg)		NIST HB105-1 Class		Unc. (mg) (k=2)
		As Found	As Left	As Found	As Left	
5 lb		103	103	F	F	10.
5 lb		75	75	F	F	10.
5 lb		64	64	F	F	10.
5 lb		69	69	F	F	10.
5 lb		71	71	F	F	10.
1 lb		23	23	F	F	6.
1 lb		21	21	F	F	6.
1 lb		20	20	F	F	6.
1 lb		25	25	F	F	6.
1 lb		27	27	F	F	6.
0.5 lb		23	23	F	F	6.
0.2 lb		11.72	11.72	F	F	0.07
0.2 lb		2.86	2.86	F	F	0.07
0.1 lb		1.12	1.12	F	F	0.07
0.05 lb		1.57	1.57	F	F	0.07
0.02 lb		0.22	0.22	F	F	0.07
0.02 lb		0.43	0.43	F	F	0.07
0.005 lb		0.15	0.15	F	F	0.07
0.002 lb		0.36	0.36	F	F	0.07
0.002 lb		0.15	0.15	F	F	0.07
0.001 lb		-0.05	-0.05	F	F	0.07

When used as a set these weights meet NIST HB 105-1 class F tolerances.

The resulting tolerance class of the weight is determined by combining the correction of the weight and the uncertainty of the measurement. The corrections given above correlate to a conventional mass scale versus 8.0 g/cm<sup>3</sup> density and an air density of 1.2 mg/cm<sup>3</sup>. The items listed above have been compared to the Standards of the State of Minnesota which are currently in control. These standards are traceable to the SI through NIST. Calibration processes were monitored and found to be in control. Uncertainty calculations conform to NIST Technical Note 1297. Results apply to items identified in this report only.

Heidi Jones  
*Heidi Jones*  
 Laboratory Administrator

Reviewed by:  
 Mark Nicollet  
*Mark Nicollet*  
 Quality Manager

Receipt Date: April 13, 2015  
 Test Date: April 30, 2015  
 Report Date: April 30, 2015

State Test No.: 334129  
 Set Serial No.: None  
 Barcode: 201687

## Calibration Report

NORTH COUNTRY BUSINESS PRODUCTS  
 541 S. AIRPORT RD.  
 BISMARCK, ND 58504  
 Contact: CAROL BRAUN  
 Phone: 218-722-3528  
 PO Number: NONE  
 SOP: 12  
 Technician ID: 09


Item(s) Submitted: 30 lb kit w/decimals  
 Manufacturer: Rice Lake  
 ASTM E617 Type: I & II  
 Equipment ID#: None  
 Condition: Good  
 Temperature: 20.7°C  
 Pressure: 738.9 mmHg  
 Relative Humidity: 45. %


*Bismarck*

Nominal Value	Serial No.	Correction (mg)		NIST HB105-1 Class		Unc. (mg) (k=2)
		As Found	As Left	As Found	As Left	
5 lb		-11	-11	F	F	10.
5 lb		3	3	F	F	10.
5 lb		20	20	F	F	10.
5 lb		9	9	F	F	10.
5 lb		-3	-3	F	F	10.
1 lb		9	9	F	F	6.
1 lb		2	2	F	F	6.
1 lb		24	24	F	F	6.
1 lb		6	6	F	F	6.
1 lb		20	20	F	F	6.
0.5 lb		13	13	F	F	6.
0.2 lb		6.60	6.60	F	F	0.07
0.2 lb		8.23	8.23	F	F	0.07
0.1 lb		3.24	3.24	F	F	0.07
0.05 lb		1.45	1.45	F	F	0.07
0.02 lb		0.38	0.38	F	F	0.07
0.02 lb		0.45	0.45	F	F	0.07
0.01 lb		0.49	0.49	F	F	0.07
0.005 lb		0.73	0.73	F	F	0.07
0.002 lb		0.49	0.49	F	F	0.07
0.002 lb		0.49	0.49	F	F	0.07
0.001 lb		0.48	0.48	F	F	0.07

When used as a set these weights meet NIST HB 105-1 class F tolerances.

The resulting tolerance class of the weight is determined by combining the correction of the weight and the uncertainty of the measurement. The corrections given above correlate to a conventional mass scale versus 8.0 g/cm<sup>3</sup> density and an air density of 1.2 mg/cm<sup>3</sup>. The items listed above have been compared to the Standards of the State of Minnesota which are currently in control. These standards are traceable to the SI through NIST. Calibration processes were monitored and found to be in control. Uncertainty calculations conform to NIST Technical Note 1297. Results apply to items identified in this report only.

Heidi Jones  
  
 Laboratory Administrator

Reviewed by:  
 Mark Nicollet  
  
 Quality Manager

Receipt Date: May 8, 2015  
 Test Date: June 4, 2015  
 Report Date: June 4, 2015

State Test No.: 334240  
 Set Serial No.: Fargo Weight Set #1  
 Barcode: 201693

## Calibration Report

NORTH COUNTRY BUSINESS PRODUCTS  
 4626 AMBER VALLEY PARKWAY  
 FARGO, ND 58104

Contact: CARIE LINDEMANN  
 Phone: 701-277-3231  
 PO Number: NONE  
 SOP: 12  
 Technician ID: 09

Item(s) Submitted: 30 lb kit w/decimals  
 Manufacturer: Rice Lake  
 ASTM E617 Type: I & II  
 Equipment ID#: None  
 Condition: Good  
 Temperature: 20.1°C  
 Pressure: 737.4 mmHg  
 Relative Humidity: 53. %

*Fargo*

Nominal Value	Serial No.	Correction (mg)		NIST HB105-1 Class		Unc. (mg) (k=2)
		As Found	As Left	As Found	As Left	
5 lb		63	63	F	F	10.
5 lb		59	59	F	F	10.
5 lb		64	64	F	F	10.
5 lb		63	63	F	F	10.
5 lb		59	59	F	F	10.
1 lb		3	3	F	F	6.
1 lb		4	4	F	F	6.
1 lb		19	19	F	F	6.
1 lb		14	14	F	F	6.
1 lb		6	6	F	F	6.
0.5 lb		16	16	F	F	6.
0.2 lb		4.66	4.66	F	F	0.07
0.2 lb		4.91	4.91	F	F	0.07
0.1 lb		3.03	3.03	F	F	0.07
0.05 lb		1.33	1.33	F	F	0.07
0.02 lb		0.43	0.43	F	F	0.07
0.02 lb		0.33	0.33	F	F	0.07
0.01 lb		0.13	0.13	F	F	0.07
0.005 lb		0.80	0.80	F	F	0.07
0.002 lb		0.15	0.15	F	F	0.07
0.002 lb		0.13	0.13	F	F	0.07
0.001 lb		0.31	0.31	F	F	0.07

When used as a set these weights meet NIST HB 105-1 class F tolerances.

The resulting tolerance class of the weight is determined by combining the correction of the weight and the uncertainty of the measurement. The corrections given above correlate to a conventional mass scale versus 8.0 g/cm<sup>3</sup> density and an air density of 1.2 mg/cm<sup>3</sup>. The items listed above have been compared to the Standards of the State of Minnesota which are currently in control. These standards are traceable to the SI through NIST. Calibration processes were monitored and found to be in control. Uncertainty calculations conform to NIST Technical Note 1297. Results apply to items identified in this report only.

Heidi Jones  
*Heidi Jones*  
 Laboratory Administrator

Reviewed by:  
 Mark Nicollet  
*Mark Nicollet*  
 Quality Manager

Receipt Date: June 9, 2015  
Test Date: June 20, 2015  
Report Date: June 20, 2015

State Test No.: 334390  
Set Serial No.: Fargo weight set #2  
Barcode: 201683

## Calibration Report

NORTH COUNTRY BUSINESS PRODUCTS  
4626 AMBER VALLEY PARKWAY  
FARGO, ND 58104


Contact: CARIE LINDEMANN  
Phone: 701-277-3231  
PO Number: NONE  
SOP: 12  
Technician ID: 09


Item(s) Submitted: 30 lb kit w/decimals  
Manufacturer: Troemner  
ASTM E617 Type: I & II  
Equipment ID#: None  
Condition: Good  
Temperature: 20.5°C  
Pressure: 730.3 mmHg  
Relative Humidity: 50. %

Nominal Value	Serial No.	Correction (mg)		NIST HB105-1 Class		Unc. (mg) (k=2)
		As Found	As Left	As Found	As Left	
5 lb		-15	-15	F	F	10.
5 lb		-25	-25	F	F	10.
5 lb		-15	-15	F	F	10.
5 lb		-14	-14	F	F	10.
5 lb		-10	-10	F	F	10.
1 lb		2	2	F	F	6.
1 lb		3	3	F	F	6.
1 lb		-1	-1	F	F	6.
1 lb		4	4	F	F	6.
1 lb		0	0	F	F	6.
0.5 lb		2.30	2.30	F	F	6.
0.2 lb		8.35	8.35	F	F	0.07
0.2 lb		10.98	10.98	F	F	0.07
0.1 lb		-1.91	-1.91	F	F	0.07
0.05 lb		2.87	2.87	F	F	0.07
0.02 lb		0.46	0.46	F	F	0.07
0.02 lb		-0.70	-0.70	F	F	0.07
0.01 lb		0.66	0.66	F	F	0.07
0.005 lb		0.21	0.21	F	F	0.07
0.002 lb		0.34	0.34	F	F	0.07
0.002 lb		0.46	0.46	F	F	0.07
0.001 lb		0.40	0.40	F	F	0.07

When used as a set these weights meet NIST HB 105-1 class F tolerances.

The resulting tolerance class of the weight is determined by combining the correction of the weight and the uncertainty of the measurement. The corrections given above correlate to a conventional mass scale versus 8.0 g/cm<sup>3</sup> density and an air density of 1.2 mg/cm<sup>3</sup>. The items listed above have been compared to the Standards of the State of Minnesota which are currently in control. These standards are traceable to the SI through NIST. Calibration processes were monitored and found to be in control. Uncertainty calculations conform to NIST Technical Note 1297. Results apply to items identified in this report only.

Heidi Jones  
  
Laboratory Administrator

Reviewed by:  
Pete Whebbe  
  
Metrologist

Belle Fourche



14305 SOUTHCROSS DRIVE #150  
BURNSVILLE, MN 55306-7008  
MN.GOV/COMMERCE/  
651.539.1555 FAX 651.539.1553  
AN EQUAL OPPORTUNITY EMPLOYER

Receipt Date: July 27, 2015  
Test Date: October 7, 2015  
Report Date: October 7, 2015

State Test No.: 334610  
Set Serial No.: 1235  
Barcode: 201270

### Calibration Report

NORTH COUNTRY BUSINESS PRODUCTS  
915 STANLEY  
BELLE FOURCHE, SD 57717  
Contact: CARIE LINDEMANN  
Phone: 701-277-3231  
PO Number: NONE  
SOP: 12  
Technician ID: 09

Item(s) Submitted: 30 lb. kit w/ decimals and fractions  
Manufacturer: Troemner  
ASTM E617 Type: I & II  
Equipment ID#: None  
Condition: Good  
Temperature: 20.7 °C  
Pressure: 743.1 mmHg  
Relative Humidity: 47. %

Nominal Value	Serial No.	Correction (mg)		NIST HB105-1 Class		Unc. (mg) (k=2)
		As Found	As Left	As Found	As Left	
5 lb		123	123	F	F	10.
5 lb		111	111	F	F	10.
5 lb		123	123	F	F	10.
5 lb		82	82	F	F	10.
5 lb		102	102	F	F	10.
1 lb		37.5	37.5	F	F	6.
1 lb		28.8	28.8	F	F	6.
1 lb		47.4	47.4	F	F	6.
1 lb		46.4	46.4	F	F	6.
1 lb		42.5	42.5	F	F	6.
0.2 lb		-0.92	-0.92	F	F	0.07
0.2 lb		4.09	4.09	F	F	0.07
0.1 lb		4.25	4.25	F	F	0.07
0.05 lb		0.27	0.27	F	F	0.07
0.02 lb		0.25	0.25	F	F	0.07
0.02 lb		0.45	0.45	F	F	0.07
0.01 lb		-0.28	-0.28	F	F	0.07
0.005 lb		0.58	0.58	F	F	0.07
0.002 lb		0.19	0.19	F	F	0.07
0.001 lb		-0.47	-0.47	F	F	0.07