



APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY

Public Service Commission
SFN 51277 (2/2014)



TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED

Name of Company Valley Petroleum Equipment Inc	Email Address kathy@valleypetroleum.com	Application Date 6/8/2016	
Mailing Address PO Box 13355	City Grand Forks	State ND	Zip Code 58208-3355
Telephone Number 701-772-7261	Cell Phone Number	Fax Number 701-772-1301	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input checked="" type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: _____ <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: _____ <input type="checkbox"/> 5. LPG <input type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
<i>e.g. 1001</i>	<i>e.g. John Doe</i>	<i>e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6</i>
1440	Dave Freije	Liquid - 1, 2, 3, 4
1596	Curtis Kurtz	Liquid - 1, 2, 3, 4
1643	Michael Bakken	Liquid - 1, 2, 3, 4
1775	Scott Schmaltz	Liquid - 1, 2, 3, 4
1776	Carl Jungberg	Liquid - 1, 2, 3, 4
1779	Chris Sprenger	Liquid - 1, 2, 3, 4

Continued on Page 2

Application for Registration as a Registered Service Company
Page 2



List below all field standards (attach current calibration reports):

Brownie 100 Gal - sn: 6841004-2	
Ellisco 5 Gal - sn: None	
Seraphin 5 Gal - sn: 10-07753	
Seraphin 5 gal - sn: 42985	
Seraphin 5 gal - sn: 98-8992-15	
Seraphin - 5 gal - sn: 10-07754	
Seraphin - 5 gal - sn: 43326	
Seraphin - 5 gal - sn: 98-8992-09	


Additional Application Items (initial where appropriate):

Standardized Test Report	<input checked="" type="checkbox"/> KR	Copy enclosed No change in report filed previously
Tested and Approved Sticker	<input checked="" type="checkbox"/> KR	Copy enclosed No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	<input checked="" type="checkbox"/> KR	Copy enclosed No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.
 Yes No

I am Kathy Reiser, Treasurer/Co-owner, and have authority to represent this company. By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.



Signature

Send Completed Application and Related Documents To:

Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480
Telephone: (701) 328-2400
Fax: (701) 328-2410

Bauske, Shelly A.

From: Kathy Reiser <kathy@valleypetroleum.com>
Sent: Thursday, July 07, 2016 11:01 AM
To: Bauske, Shelly A.
Subject: RE: Application for Registration as a Registered Service Company

Hi Shelly,
Sorry about this...keep Jon but not Steve please. Steve has retired.

Sent from my Verizon, Samsung Galaxy smartphone

----- Original message -----

From: "Bauske, Shelly A." <sbauske@nd.gov>
Date: 7/7/16 10:52 AM (GMT-06:00)
To: Kathy Reiser <kathy@valleypetroleum.com>
Subject: Application for Registration as a Registered Service Company

Good Morning Kathy

I received the Application for Registration as a Registered Service Company for Valley Petroleum and I have two employees on my list that aren't on yours:

Steve Sulland – Permit No. 1438
Jon McMillan – Permit No. 1615

Please let me know the status of these employees.

Thank you!

Shelly Bauske
Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480
701-328-4070
701-328-2410 (fax)
sbauske@nd.gov

North Dakota

nd.gov Official Portal for
North Dakota State GovernmentNorth Dakota
LEGENDARY

SECRETARY OF STATE NORTH DAKOTA


[Home](#) | [Business Records Search](#)

VALLEY PETROLEUM EQUIPMENT, INC.

Corporation Details

System ID: 1580000 **Phone:** (701) 772-7261
Type: BUSINESS CORPORATION
Status: Active & Good Standing
Original File Date: 05/09/1984 **Effective Date:** 05/09/1984
State of Origin: North Dakota

Nature of Business

SALES, INSTALLATION & SERVICE PETROLEUM HANDLING EQUIPMENT

Principal Office

5510 10TH AVE N PO BOX 13355 GRAND FORKS, ND 58208-3355

Registered Agent

HOWARD D SWANSON
 3334 PRIMROSE CT
 PO BOX 12909
 GRAND FORKS, ND 58208-2909
 Established Date: Nov 03, 1997

Authorized Shares

Class	Number	Par Value
	50000.000000	\$.000000

Generate an Annual Report To File

To Generate a Annual Report form to be filed with the Secretary of State, select the appropriate year of the report you intend to file. This report does not contain details of a report previously filed with the Secretary of State. The annual report years reflected are an indication of the various report forms available in this site and is not an indication that an entity needs to file reports for all years. Missing years indicate that the forms for the missing year have not yet been deployed to the website, or have already been removed, and can be obtained by contacting the Secretary of State.

[2015](#) [2016](#) (generates a forms-fillable pdf in a new pop-up window)

[Return to Search Results](#)

[Contact Us](#)
[Disclaimer](#)
[Privacy Policy](#)

We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.



Receipt Date: May 19, 2016
Cal. Date: May 19, 2016
Report Date: May 19, 2016

Report No.: 335975
Serial No.: 6841004-2
Barcode: 017726

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: Steve Sulland
Phone: 701-772-7261
PO Number: None
SOP: 19
Technician ID: 19

Item(s) Submitted: 100 Gallon Prover
Manufacturer: Determan
Material: Mild Steel
Type: No Bottom Zero
Condition: Good*
Temperature: 22.7 °C
Pressure: 738.8 mmHg
Relative Humidity: 36.4 %
Standard H₂O Temp.: 11.9 °C
Artifact H₂O Temp.: 12.1 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
100	As Found	100.012	2.8	2.01	3.3	0.0000186
	As Left	100.012	2.8			

*Prover must be painted with a white or silver glossy finish to prevent heating of contents by next calibration cycle.

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.


CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Erik Alfvin

Metrologist

Reviewed by:
Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 20, 2016
Report Date: May 23, 2016

Report No.: 335977
Serial No.: 10-07754
Barcode: 201426

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: Steve Sulland
Phone: 701-772-7261
PO Number: None
SOP: 19
Technician ID: 19

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Seraphin
Material: Stainless Steel
Type: Measure
Condition: Good
Temperature: 22.1 °C
Pressure: 739.8 mmHg
Relative Humidity: 41.2 %
Standard H₂O Temp.: 15.2 °C
Artifact H₂O Temp.: 15.4 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (1/°F)
5	As Found	4.9988	-0.29	2.06	0.24	0.0000265
	As Left	5.0002	0.04			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Erik Alfvin

Metrologist

Reviewed by:
Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 20, 2016
Report Date: May 23, 2016

Report No.: 335978
Serial No.: 98-8992-15
Barcode: 018399

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: Steve Sulland
Phone: 701-772-7261
PO Number: None
SOP: 19
Technician ID: 19

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Seraphin
Material: Stainless Steel
Type: Measure
Condition: Good
Temperature: 22.1 °C
Pressure: 739.8 mmHg
Relative Humidity: 41.2 %
Standard H₂O Temp.: 16.3 °C
Artifact H₂O Temp.: 16.3 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
5	As Found	5.0002	0.05	2.06	0.24	0.0000265
	As Left	5.0002	0.05			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.


CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Erik Alfvin

Metrologist

Reviewed by:
Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 19, 2016
Report Date: May 19, 2016

Report No.: 335979
Serial No.: None
Barcode: 017724

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: STEVE SULLAND
Phone: 701-772-7261
PO Number: NONE
SOP: 19
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Ellisco
Material: Mild Steel
Type: Measure
Condition: Good
Temperature: 22.6 °C
Pressure: 738.6 mmHg
Relative Humidity: 38.3 %
Standard H₂O Temp.: 15.3 °C
Artifact H₂O Temp.: 15.5 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
5	As Found	4.9996	-0.09	2.06	0.24	0.0000186
	As Left	4.9996	-0.09			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Pete Whebbe

Metrologist

Reviewed by:

Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 19, 2016
Report Date: May 19, 2016

Report No.: 335980
Serial No.: 42985
Barcode: 017725

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: STEVE SULLAND
Phone: 701-772-7261
PO Number: NONE
SOP: 19
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Seraphin
Material: Mild Steel
Type: Measure
Condition: Good
Temperature: 22.6 °C
Pressure: 738.6 mmHg
Relative Humidity: 38.3 %
Standard H₂O Temp.: 15.4 °C
Artifact H₂O Temp.: 15.5 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (1/°F)
5	As Found	5.0010	0.22	2.06	0.24	0.0000186
	As Left	5.0002	0.04			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Pete Whebbe

Metrologist

Reviewed by:

Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 19, 2016
Report Date: May 19, 2016

Report No.: 335981
Serial No.: 43326
Barcode: 017723

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: STEVE SULLAND
Phone: 701-772-7261
PO Number: NONE
SOP: 19
Technician ID: 11

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Seraphin
Material: Mild Steel
Type: Measure
Condition: Good
Temperature: 22.6 °C
Pressure: 738.6 mmHg
Relative Humidity: 38.3 %
Standard H₂O Temp.: 15.6 °C
Artifact H₂O Temp.: 15.8 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
5	As Found	5.0000	0.01	2.06	0.24	0.0000186
	As Left	5.0000	0.01			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Pete Whebbe

Metrologist

Reviewed by:

Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 20, 2016
Report Date: May 23, 2016

Report No.: 335982
Serial No.: 98-8992-09
Barcode: 018398

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: Steve Sulland
Phone: 701-772-7261
PO Number: None
SOP: 19
Technician ID: 19

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Seraphin
Material: Stainless Steel
Type: Measure
Condition: Good
Temperature: 22.1 °C
Pressure: 739.8 mmHg
Relative Humidity: 41.2 %
Standard H₂O Temp.: 18.8 °C
Artifact H₂O Temp.: 18.9 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
5	As Found	4.9994	-0.14	2.06	0.24	0.0000265
	As Left	4.9994	-0.14			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Erik Alfvin

Metrologist

Reviewed by:

Mark Nicollet

Quality Manager



Receipt Date: May 19, 2016
Cal. Date: May 20, 2016
Report Date: May 23, 2016

Report No.: 335983
Serial No.: 08-05150
Barcode: 203007

Calibration Certificate

VALLEY PETROLEUM EQUIP
5510 10TH AVE NE
GRAND FORKS, ND 58206-1355
Contact: Steve Sulland
Phone: 701-772-7261
PO Number: None
SOP: 19
Technician ID: 19

Item(s) Submitted: 5 Gallon Measure
Manufacturer: Seraphin
Material: Stainless Steel
Type: Measure
Condition: Good
Temperature: 22.1 °C
Pressure: 739.8 mmHg
Relative Humidity: 41.2 %
Standard H₂O Temp.: 17.2 °C
Artifact H₂O Temp.: 17.3 °C

Nominal		Calibrated			
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³) CCE (°F)
5	As Found	5.0074	1.70	2.06	0.24 0.0000265
	As Left	4.9996	-0.10		

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Erik Alfvin
Erik Alfvin
Metrologist

Reviewed by:
Mark Nicollet
Mark Nicollet
Quality Manager



Receipt Date: May 19, 2016
 Cal. Date: May 20, 2016
 Report Date: May 23, 2016

Report No.: 335976
 Serial No.: 10-07753
 Barcode: 201425


Calibration Certificate


VALLEY PETROLEUM EQUIP
 5510 10TH AVE NE
 GRAND FORKS, ND 58206-1355
 Contact: Steve Sulland
 Phone: 701-772-7261
 PO Number: None
 SOP: 19
 Technician ID: 19

Item(s) Submitted: 5 Gallon Measure
 Manufacturer: Seraphin
 Material: Stainless Steel
 Type: Measure
 Condition: Broken*
 Temperature: 22.1 °C
 Pressure: 739.8 mmHg
 Relative Humidity: 41.2 %
 Standard H₂O Temp.:
 Artifact H₂O Temp.:

Nominal	Calibrated			
Volume (gal)	Volume (gal)	Error (in ³)	<i>k</i>	U (in ³) CCE (°F)
5	As Found			

***Rejected: Bottom band is loose and test measure does not sit properly. Band must be re-welded so that measure is level.**

Erik Alfvin

 Metrologist

Reviewed by:
 Mark Nicollet

 Quality Manager

United States Department of Commerce

Rational Institute of Standards and Technology

Certificate of Metrological Traceability For:

Minnesota

This laboratory has demonstrated evidence of an unbroken chain of metrological traceability of its standards to the international system of units (SI), documented measurement uncertainties, uses documented measurement procedures, successfully completed training and proficiency tests, documented calibration intervals, submitted a quality management system, and demonstrated suitable measurement assurance for the Scope listed on this certificate.

The Office of Weights and Measures Program assesses laboratories to NIST Handbook 143 - Program Handbook for State Weights and Measures Laboratories and ISO/IEC 17025:2005.

Scope

Mass Echelon II	Weight Carts	Volume Gravimetric, I
50 kg to 1 mg	10 000 lb to 2000 lb	20 L to 10 mL
1000 lb to 0.001 lb	Wheel Load Weighers	100 gal to 0.25 qt
4 oz to 0.03125 oz	20 000 lb to 2000 lb	Volume Transfer, II
Mass Echelon III	Railroad Test Cars	1500 gal to 5 gal
50 kg to 1 mg	110 000 lb to 80 000 lb	100 gal to 25 gal LPG
5000 lb to 0.001 lb		
4 oz to 0.03125 oz		



2016 to 2017

Carol T. Hocken, Chief
NIST Office of Weights and Measures

Effective Dates: 2016-01-01 to 2017-12-31



5510 10th Ave N 677 43rd St NW
Grand Forks, ND 58203 Fargo, ND 58102
(P) 701-772-7261 (P) 701-373-7806
(F) 701-772-1301 (F) 701-373-7807
Grand Forks toll free ~800-727-5499

June 8, 2016



Shelly Bauske
Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480

Re: Field standards re-certification

Shelly,

I have enclosed our *Application for Registration as a Registered Service Company* along with the required documents and copies of the Calibration Reports for our field standards from the MN Weights and Measures Metrology Laboratory.

There was one prover that we need to repair and send in for calibration and another that we need to paint by next year. I will send you the report for the repaired prover once it is done. It is not being used until the repairs and calibration are done.

If you need further information for our re-certification please let me know.

Sincerely,

Kathy Reiser
Secretary/Treasurer