

GLACIER RIDGE WIND PROJECT

Sound Modeling Assessment for the Glacier Ridge Wind Project

Glacier Ridge Wind Project, LLC

Document No.: 10026534-HOU-R-01

Issue: B, **Status:** Final

Date: 15 August 2016



IMPORTANT NOTICE AND DISCLAIMER

1. This document is intended for the sole use of the Customer as detailed on the front page of this document to whom the document is addressed and who has entered into a written agreement with the DNV GL entity issuing this document ("DNV GL"). To the extent permitted by law, neither DNV GL nor any group company (the "Group") assumes any responsibility whether in contract, tort including without limitation negligence, or otherwise howsoever, to third parties (being persons other than the Customer), and no company in the Group other than DNV GL shall be liable for any loss or damage whatsoever suffered by virtue of any act, omission or default (whether arising by negligence or otherwise) by DNV GL, the Group or any of its or their servants, subcontractors or agents. This document must be read in its entirety and is subject to any assumptions and qualifications expressed therein as well as in any other relevant communications in connection with it. This document may contain detailed technical data which is intended for use only by persons possessing requisite expertise in its subject matter.
2. This document is protected by copyright and may only be reproduced and circulated in accordance with the Document Classification and associated conditions stipulated or referred to in this document and/or in DNV GL's written agreement with the Customer. No part of this document may be disclosed in any public offering memorandum, prospectus or stock exchange listing, circular or announcement without the express and prior written consent of DNV GL. A Document Classification permitting the Customer to redistribute this document shall not thereby imply that DNV GL has any liability to any recipient other than the Customer.
3. This document has been produced from information relating to dates and periods referred to in this document. This document does not imply that any information is not subject to change. Except and to the extent that checking or verification of information or data is expressly agreed within the written scope of its services, DNV GL shall not be responsible in any way in connection with erroneous information or data provided to it by the Customer or any third party, or for the effects of any such erroneous information or data whether or not contained or referred to in this document.
4. Any energy forecasts estimates or predictions are subject to factors not all of which are within the scope of the probability and uncertainties contained or referred to in this document and nothing in this document guarantees any particular wind speed or energy output.

KEY TO DOCUMENT CLASSIFICATION

| | | |
|--------------------------|---|---|
| Strictly Confidential | : | For disclosure only to named individuals within the Customer's organization. |
| Private and Confidential | : | For disclosure only to individuals directly concerned with the subject matter of the document within the Customer's organization. |
| Commercial in Confidence | : | Not to be disclosed outside the Customer's organization. |
| DNV GL only | : | Not to be disclosed to non-DNV GL staff |
| Customer's Discretion | : | Distribution for information only at the discretion of the Customer (subject to the above Important Notice and Disclaimer and the terms of DNV GL's written agreement with the Customer). |
| Published | : | Available for information only to the general public (subject to the above Important Notice and Disclaimer). |

Project name: Glacier Ridge Wind Project DNV GL - Energy
 Report title: Sound Modeling Assessment for the Glacier Ridge Renewables Advisory
 Wind Project 333 SW 5th Ave, Suite 400
 Customer: Glacier Ridge Wind Project, LLC Portland, OR 97204 USA
 330 2nd Avenue South, Suite 820, Tel: 503-224-3563
 Minneapolis, MN 55401 USA Enterprise No.: 94-3402236
 Contact person: A. Griger
 Date of issue: 15 August 2016
 Project No.: 10026534
 Document No.: 10026534-HOU-R-01
 Issue/Status B/Final

Task and objective: Sound Assessment of the Glacier Ridge Wind Project located in Barnes County, North Dakota

Prepared by:

Verified by:

Approved by:

Anna Danaitis
Analyst, Environmental Permitting Services

Aren Nercessian
Analyst, Project Development and Engineering

Bruce Moreira
Project Manager, Environmental Permitting Services

Shant Dokouzian,
Senior Project Engineer/Project Development and Engineering

- Strictly Confidential
 Private and Confidential
 Commercial in Confidence
 DNV GL only
 Customer's Discretion
 Published

Keywords:
Sound modeling

© DNV KEMA Renewables, Inc.. All rights reserved.

Reference to part of this report which may lead to misinterpretation is not permissible.

| Issue | Date | Reason for Issue | Prepared by | Verified by | Approved by |
|-------|----------------|------------------|-------------|---------------|--------------------------|
| A | 13 July 2016 | Final | A. Danaitis | A. Nercessian | B. Moreira, M. Cookson |
| B | 15 August 2016 | Turbine shift | A. Danaitis | A. Nercessian | B. Moreira, S. Dokouzian |



Table of contents

| | |
|--|----|
| EXECUTIVE SUMMARY | VI |
| 1 INTRODUCTION | 1 |
| 2 ENVIRONMENTAL SOUND BACKGROUND | 2 |
| 3 APPLICABLE REGULATIONS | 3 |
| 4 DESCRIPTION OF THE WIND PROJECT SITE | 4 |
| 4.1 Site description | 4 |
| 4.2 Wind project layout..... | 4 |
| 4.3 Adjacent wind projects | 4 |
| 4.4 Receptor locations | 4 |
| 5 SOUND ASSESSMENT | 5 |
| 5.1 Description of the sound source..... | 5 |
| 5.2 Ashtabula I and III wind projects | 5 |
| 5.3 Assessment methodology | 6 |
| 6 RESULTS..... | 8 |
| 7 CONCLUSION | 17 |
| 8 REFERENCES | 18 |

Appendices

APPENDIX A – WIND TURBINE GENERATOR AND TRANSFORMER COORDINATES

APPENDIX B – RECEPTOR LOCATIONS AND ASSOCIATED SOUND LEVELS

List of tables

| | |
|---|---|
| Table 5-1 Vestas V126 3.45 MW STE Mode 0 acoustic emission summary..... | 5 |
| Table 5-2 Transformer acoustic emission summary | 5 |
| Table 5-3 Ashtabula I Wind Energy Center – GE sle 1.5 MW acoustic emission summary | 5 |
| Table 5-4 Ashtabula III Wind Energy Center – GE xle 1.6 MW acoustic emission summary..... | 6 |
| Table 5-5 Ashtabula III Wind Energy Center – Transformer acoustic emission summary | 6 |
| Table 5-6 Ashtabula I Wind Energy Center – Transformer acoustic emission summary | 6 |



List of figures

| | |
|---|----|
| Figure 6-1 Modeled sound levels at Glacier Ridge Wind Project | 9 |
| Figure 6-2 Key Map for Detailed Figures | 10 |
| Figure 6-3 Detailed Isocontour Map 1 | 11 |
| Figure 6-4 Detailed Isocontour Map 2 | 12 |
| Figure 6-5 Detailed Isocontour Map 3 | 13 |
| Figure 6-6 Detailed Isocontour Map 4 | 14 |
| Figure 6-7 Detailed Isocontour Map 5 | 15 |
| Figure 6-8 Detailed Isocontour Map 6 | 16 |



EXECUTIVE SUMMARY

Glacier Ridge Wind Project, LLC., is developing the Glacier Ridge Wind Project in North Dakota. Glacier Ridge Wind Project, LLC., has instructed DNV KEMA Renewables, Inc. (DNV GL) to carry out a sound modeling assessment of the proposed wind project. The results of the work are reported here.

The site is located in Barnes County, North Dakota, approximately 6 miles northeast of Valley City, North Dakota. The Project layout currently consists of 99 Vestas V126 wind turbine generators operating in Noise Mode 0, and one transformer. According to the Customer, 87 of the 99 turbines modeled in this report are planned for construction. In order to provide additional flexibility in future siting of wind turbines, all 99 turbines and the transformer have been included in the sound modeling assessment. The cumulative sound contribution of the neighboring Ashtabula I and III projects is also considered.

The sound pressure level (SPL) at each receptor for the aggregate of all wind turbine generators and transformers associated with the Project was calculated based on the ISO 9613-2 method. The results indicate that the calculated sound levels are within the allowable limits under North Dakota noise regulations at each of the 49 receptors located within 1 mile (approximately 1,600 m) of a project turbine or transformer.



1 INTRODUCTION

This report is issued to Glacier Ridge Wind Project, LLC (“Customer”) pursuant to a written agreement arising from the *Proposal for Siting Study Support for the Glacier Ridge Wind Project* dated 31 May 2016, DNV GL Document No. 130652-USPO-P-01-A. The Customer has requested that DNV KEMA Renewables, Inc. (DNV GL) perform Project Development services, including a sound modeling assessment for the Glacier Ridge Wind Project (the “Project”) located in Barnes County, North Dakota.

The Project layout considered for the sound assessment currently consists of 99 Vestas V126 STE wind turbine generators operating in Noise Mode 0 at a hub height of 285 feet (87 m). This layout includes 12 alternate locations. These turbines can have an effect on the sound levels experienced at receptors in the vicinity of the site. The neighboring Ashtabula I and III projects are also considered in the assessment.

The objective of this assessment is to predict the sound levels generated by the Project’s wind turbine generators at all receptors within a mile of the Project, using the ISO 9613-2 method [1] and in accordance with the North Dakota Administrative Code Energy Conversion Facility Siting Criteria, Chapter 69-06-08-01(4) [2] and Barnes County Development Code, Section 6.10 [3].



2 ENVIRONMENTAL SOUND BACKGROUND

Sound levels are expressed in the decibel unit and are quantified on a logarithmic scale to account for the large range of acoustic pressures to which the human ear is exposed. A decibel (dB) is used to quantify sound levels relative to a 0 dB reference. The reference level of 0 dB is defined as a sound pressure level of 20 micropascals (μpa), which is the typical lower threshold of hearing for humans.

Sound levels can be presented both in broadband (sound energy summed across the entire audible frequency spectrum) and in octave band spectra (audible frequency spectrum divided into bands). Frequency is expressed in the Hertz unit (Hz), measuring the cycles per second of the sound pressure waves. The audible range of humans spans from 20 to 20,000 Hz. Since the human ear does not perceive every frequency with equal loudness, spectrally varying sounds are often adjusted with a weighting filter. The A-weighting filter is applied to closely approximate the human ear's response to sound. This scale is commonly used in environmental and industrial sound. Sound expressed in the A-weighted scale is denoted dBA.

A sound source has a certain sound power level (PWL) rating which describes the amount of sound energy per unit of time. This is a basic measure of how much acoustical energy it can produce and is independent of its surroundings. Sound pressure is created as sound energy flows away from the source. The measured sound pressure level (SPL) at a given point depends not only on the power rating of the source and the distance between the source and the measurement point (geometric divergence), but also on the amount of sound energy absorbed by environmental elements between the source and the measurement point (attenuation). Sound attenuation factors include meteorological conditions such as wind direction, temperature, and humidity; sound interaction with the ground; atmospheric absorption; terrain effects; diffraction of sound around objects and topographical features; and foliage.



3 APPLICABLE REGULATIONS

The Glacier Ridge Wind Project is regulated by the North Dakota Public Service Commission (PSC) which has specific noise ordinances under the North Dakota Administrative Code Energy Conversion Facility Siting Criteria Chapter 69-06-08-01(4) [2]. The intent of this report is to verify the Project is in compliance with the North Dakota PSC and Barnes County zoning regulations.

The North Dakota Administrative Code Energy Conversion Facility Siting Criteria, Chapter 69-06-08-01(4) states:

*(4) Additional avoidance areas for wind energy conversion facilities. A wind energy conversion facility site must not include a geographic area where, due to operation of the facility, the sound levels within one hundred feet of an inhabited residence or a community building will exceed **fifty dBA**. The sound level avoidance area criteria may be waived in writing by the owner of the occupied residence or the community building.*

The zoning regulations for Barnes County, North Dakota do not contain any provisions specific to noise from wind energy facilities or wind turbines. General noise regulations state (Section 6.10) [3]:

6.10 Sustained noise of over seventy-five (75) decibels during the day and sixty-five (65) decibels at night is not allowed.

For the purposes of this assessment, the more conservative limit of 50 dBA was applied.

4 DESCRIPTION OF THE WIND PROJECT SITE

4.1 Site description

The site is located in Barnes County, North Dakota approximately 45 miles (72 km) west of Fargo, North Dakota.

The proposed wind project is situated in relatively simple terrain, consisting of flat farm land, with wind turbine base elevations ranging from 1,245 feet to 1,510 feet. The ground cover on and near the site is primarily comprised of farm land and open fields. Dwellings are interspersed throughout the Project site.

4.2 Wind project layout

The proposed turbine layout, which consists of 99 Vestas V126 3.45 MW STE wind turbine generators at a hub height of 285 feet (87 m) operating in Noise Mode 0 and one transformer, has been provided by the Customer [4]. The layout includes 12 alternate turbines locations. The coordinates of each turbine and one transformer are presented in Appendix A.

4.3 Adjacent wind projects

NExtEra Energy Resources owns the operational wind projects Ashtabula I and Ashtabula III, located immediately to the northwest of the Glacier Ridge project. Ashtabula I and III respectively consist of 131 GE sle 1.5 MW and 39 GE xle 1.6 MW wind turbine generators at a hub height of 262 feet (80 m). In the assessment, these wind projects were considered as external cumulative sources of noise. The wind turbine locations for these projects were obtained from the Customer and confirmed with Google Earth imagery.

The closest Ashtabula I turbine is located approximately 1660 feet (506 m) from T60 of the Glacier Ridge project and approximately 1490 feet (454 m) from the nearest receptor in this report.

The closest Ashtabula III turbine is located approximately 3.7 miles (5,971 m) from T77 of the Glacier Ridge project and approximately 3.4 miles (5,432 m) from the nearest receptor in this report.

Sound power level information for the GE sle 1.5 MW and GE xle 1.6 MW wind turbines, as well as the respective transformer locations and sound power levels, were retrieved from the Ashtabula III Wind Energy Center Acoustic Assessment [5].

The coordinates for Ashtabula I and III turbines and transformers are shown in Appendix A.

4.4 Receptor locations

A list of 128 receptors to be considered as sound receptors was provided by the Customer and validated by DNV GL using available aerial imagery. Of the 128 total identified receptors provided by the Customer [6], results for 49 receptors located within 1 mile (approximately 1,600 m) of the project turbines are reported here. It should be noted that results up to a distance of 100 feet from receptors are computed, and the highest result is presented in Section 6, in order to comply with [2]. Coordinates of each receptor center are presented in Appendix B.

5 SOUND ASSESSMENT

5.1 Description of the sound source

The sources of sound considered in this analysis are the Project wind turbine generators and transformer. Sound associated with other sources in the vicinity of the Project, such as construction activities, have not been considered.

Broadband sound power levels and octave band distributions for the Vestas V126 3.45 MW STE (serrated trailing edges) wind turbine generators, at a hub height of 285 feet (87 m), were provided by the Customer [7]. This acoustic emissions data was determined in accordance with the IEC 61400-11 standard [8]. At the request of the Customer, an uncertainty level of 2 dBA was added to the maximum wind turbine acoustic emission. The maximum wind turbine acoustic emission plus the 2 dB uncertainty level (total of 109.3 dBA) is considered in this assessment and is presented in Table 5-1.

Table 5-1 Vestas V126 3.45 MW STE Mode 0 acoustic emission summary

| Frequency [Hz] | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Broadband |
|-------------------------|------|------|------|-------|-------|-------|------|------|------|-----------|
| Sound Power Level [dBA] | 80.7 | 89.2 | 94.8 | 100.6 | 104.5 | 105.0 | 99.6 | 91.3 | 69.6 | 109.3 |

For the transformer, a broadband sound power level of 116.6 dBA was estimated based on standard NEMA TR.1 Table 0-1 [9] and IEEE standard C57.12.90-2006 [10] for one 330 MVA, 345 kV utility scale transformer, as specified by the customer. A typical transformer octave band distribution was estimated, as shown in Table 5-2. The sound power level of the transformer includes a 5 dB penalty for tonality.

Table 5-2 Transformer acoustic emission summary

| Frequency [Hz] | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Broadband |
|-------------------------|------|------|-------|-------|-------|-------|-------|-------|------|-----------|
| Sound Power Level [dBA] | 73.8 | 93.0 | 105.1 | 107.6 | 113.0 | 110.2 | 106.4 | 101.2 | 92.1 | 116.6 |

5.2 Ashtabula I and III wind projects

The octave band sound power levels used to model the GE sle 1.5 MW wind turbines belonging to Ashtabula I Wind Energy Center are shown in Table 5-3. These were taken from the Ashtabula III Wind Energy Center Acoustic Assessment [5].

Table 5-3 Ashtabula I Wind Energy Center – GE sle 1.5 MW acoustic emission summary

| Frequency [Hz] | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Broadband |
|-------------------------|------|------|------|------|-------|------|------|------|------|-----------|
| Sound Power Level [dBA] | N/A | 87.1 | 96.0 | 99.2 | 100.6 | 99.9 | 96.5 | 89.3 | 80.1 | 106.0 |

The octave band sound power levels used to model the GE xle 1.6 MW wind turbines belonging to Ashtabula III Wind Energy Center are shown in. These were taken from the project acoustic assessment [5].

Table 5-4 Ashtabula III Wind Energy Center – GE xle 1.6 MW acoustic emission summary

| Frequency [Hz] | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Broadband |
|-------------------------|------|------|------|-------|-------|-------|------|------|------|-----------|
| Sound Power Level [dBA] | N/A | 86.8 | 95.6 | 101.2 | 102.8 | 102.1 | 99.3 | 91.1 | 88.2 | 108.0 |

For the Ashtabula III transformer, a broadband sound power level of 108.4 dBA was used, using the octave band sound power levels in the acoustic assessment [5]. This includes a 5 dB tonal penalty as per industry best practice. A typical transformer octave distribution was used in the acoustic assessment, as shown in Table 5-5.

Table 5-5 Ashtabula III Wind Energy Center – Transformer acoustic emission summary

| Frequency [Hz] | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Broadband (dBA) |
|------------------------|------|-----|-----|-----|-----|------|------|------|------|-----------------|
| Sound Power Level [dB] | 105 | 111 | 113 | 108 | 108 | 102 | 97 | 92 | 85 | 108.4 |

For the Ashtabula I transformer, details were not provided in the acoustic assessment report. Therefore, a broadband sound power level of 111.4 dBA was estimated using the Ashtabula III transformer sound power levels [5] and adding 3 dBA due to the total capacity of the Ashtabula I project being substantially larger than Ashtabula III. It should be noted that the Ashtabula I transformer has negligible sound contribution to Glacier Ridge receptors. The overall broadband value includes a 5 dB tonal penalty as per industry best practice. The modeled octave band sound power levels, scaled up from Table 5-5, are shown in Table 5-6.

Table 5-6 Ashtabula I Wind Energy Center – Transformer acoustic emission summary

| Frequency [Hz] | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Broadband (dBA) |
|------------------------|------|-----|-----|-----|-----|------|------|------|------|-----------------|
| Sound Power Level [dB] | 108 | 114 | 116 | 111 | 111 | 105 | 100 | 95 | 88 | 111.4 |

5.3 Assessment methodology

The sound pressure level (SPL) at each receptor for the aggregate of all wind turbine generators and transformers associated with the Glacier Ridge Wind Project were calculated using CadnaA 4.2 acoustic modeling software based on the ISO 9613-2 method [1]. The simulation was run for the wind speed corresponding with the maximum sound power level (PWL) of the turbines and the maximum sound power level of the transformer. The hub height of the turbines is 285 feet (87 m). The Glacier Ridge transformer was modeled as a point source at a height of 16 feet (4.9 m) above ground level, assuming the transformer is raised 1 foot (0.3 m) above the ground. The transformers for Ashtabula I and III was modeled as point sources at a height of 14.8 feet (4.5 m) above ground level. All receptors were modeled at a best practice height of 4.9 feet (1.5 m).

The ISO 9613 standard provides a prediction of the equivalent continuous sound pressure level at a distance from one or more point sources. The method consists of octave-band algorithms (i.e., with nominal mid-band frequencies from 31.5 Hz to 8 kHz) for calculating the attenuation of the emitted sound. The algorithm takes into account the following physical effects:

- Geometrical divergence – attenuation due to spherical spreading from the sound source
- Atmospheric absorption – attenuation due to absorption by the atmosphere
- Ground absorption – attenuation due to the acoustical properties of the ground

The ISO 9613 standard calculates attenuation under meteorological conditions favorable to propagation from sources of sound emission. These conditions are for downwind propagation or, equivalently, propagation under a well-developed moderate ground-based temperature inversion, such as it commonly occurs at night. In other words, though a physical impracticality, the ISO 9613-2 standard treats every receptor as being downwind from every source of sound emission (in this case, turbines and transformers).

The ISO 9613-2 standard accounts for ground effect by assigning a numerical coefficient (G) with a value ranging from 0 to 1. A $G = 0$ equates to hard ground (paving, water, ice, concrete, tamped ground, and other ground surfaces with a low porosity), while a $G = 1$ equates to porous ground (ground covered by grass, trees, or other vegetation, and other ground surfaces suitable for the growth of vegetation such as farming land). Though the ground use on and around the site is farming, a mixed (semi-reflective) global ground factor of $G = 0.5$ was used in this assessment, with the exception of $G = 0$ for water bodies.

Additionally, temperature, barometric pressure, and humidity parameters were selected to represent conditions favorable to sound propagation, and topographical information to accurately represent terrain in three-dimensions was included in this assessment.

Specifically, the ISO 9613-2 parameters were set as follows:

- Ambient air temperature: 50°F (10°C)
- Ambient barometric pressure: 101.32 kPa
- Humidity: 70%
- Overall ground factor: 0.5
- Topography included

Additional attenuation from foliage was not considered in this assessment, implying that the lower sound levels are expected in areas where there is foliage present in the line of sight between any turbine and a sound receptor. Similarly, because the model assumes every receptor is downwind of every sound source at all times, lower sound levels are expected at times when a receptor is upwind of any sound source [1].

The wind turbine and transformer sound emission ratings used for each octave band were those specified in Table 5-1 to Table 5-6. The sound impact was calculated for each receptor and the calculated sound level was then compared with the applicable sound limit.

No distinction was made between daytime or night time sound emissions in the simulation because the project is assumed to be operating at maximum capacity at all times.




6 RESULTS

Detailed maps illustrating predicted sound pressure levels at receptors located in the vicinity of the Project is presented in Figure 6-1 to Figure 6-8.

The results of the sound study are presented for all sound receptors in tabular format in Appendix B. For each receptor, the following information is provided:

- ID;
- Coordinates in UTM projection and NAD83 Datum;
- Sound levels in dBA at the receptor location at 4.9 feet (1.5 m) above ground level. The results presented are for the highest value within 100 feet (30.5 m) of a given receptor, in order to comply with [2];
- Closest wind turbine; and
- Distance to the closest wind turbine.

The sound pressure levels at each of the 49 receptors located within 1 mile (approximately 1,600 m) of a project turbine are within the allowable limits under the applicable regulations. The highest modelled result is 48.3 dBA at receptor ID 57.



Legend

Project Components

- ▲ Glacier Ridge Wind Turbine (99)
- Glacier Ridge Transformer
- Receptor

Other Components

- Ashtabula Wind Turbine
- Ashtabula Transformer
- Primary Road
- Secondary Road
- Local Road, Rural Road

Contour (Interval: 20 ft)

Predicted Sound Level*

- 40 dB(A)
- 45 dB(A)
- 50 dB(A)

* Predicted Sound Level modelled at 4.92 ft (1.5 m) above ground level



RES AMERICAS
powering change®

Glacier Ridge


Noise Impact Assessment
Map 6-1

10026534-160811-RS
August 11, 2016

DNV·GL

Projection: UTM Zone 14, NAD83
Sources: NED, TIGER, ArcGIS Online

Figure 6-1 Modeled sound levels at Glacier Ridge Wind Project



Legend

Project Components

- ▲ Glacier Ridge Wind Turbine (99)
- Glacier Ridge Transformer
- Receptor

Other Components

- Ashtabula Wind Turbine
- Ashtabula Transformer
- Primary Road
- Secondary Road
- Local Road, Rural Road

Contour (Interval: 20 ft)

Predicted Sound Level*

- 40 dB(A)
- 45 dB(A)
- 50 dB(A)

* Predicted Sound Level modelled at 4.92 ft (1.5 m) above ground level



RES AMERICAS
powering change®

Glacier Ridge

Noise Impact Assessment
Map 6-2

10026534-160811-RS
August 11, 2016

DNV·GL

Projection: UTM Zone 14, NAD83
Sources: NED, TIGER, ArcGIS Online

Figure 6-2 Key Map for Detailed Figures




Figure 6-3 Detailed Isocontour Map 1




Figure 6-4 Detailed Isocontour Map 2




Figure 6-5 Detailed Isocontour Map 3




Figure 6-6 Detailed Isocontour Map 4





Figure 6-7 Detailed Isocontour Map 5



Legend

Project Components

- Glacier Ridge Wind Turbine (99)
- Glacier Ridge Transformer
- Receptor

Other Components


- Ashtabula Wind Turbine
- Ashtabula Transformer
- Primary Road
- Secondary Road
- Local Road, Rural Road

Contour (Interval: 20 ft)

Predicted Sound Level*

- 40 dB(A)
- 45 dB(A)
- 50 dB(A)

* Predicted Sound Level modelled at 4.92 ft (1.5 m) above ground level



RES AMERICAS
powering change®

Glacier Ridge

Noise Impact Assessment
Figure 6-8

10026534-160811-RS
August 11, 2016

DNV·GL

Projection: UTM Zone 14, NAD83
Sources: NED, TIGER, ArcGIS Online

Figure 6-8 Detailed Isocontour Map 6



7 CONCLUSION

An analysis has been conducted to determine the maximum sound levels predicted to be experienced at sound receptors in the vicinity of the Glacier Ridge Wind Project in Barnes County, North Dakota. This analysis was undertaken specifically for the Vestas V126 3.45 MW STE Mode 0 wind turbine generator at a hub height of 285 feet (87 m). 99 turbines (including 12 alternate locations), one transformer, and the adjacent Ashtabula I and III wind projects were included in the model.

The results indicate that the calculated sound levels are within the allowable limits under the North Dakota Administrative Code Energy Conversion Facility Siting Criteria regulations and the Barnes County regulations at each of the 49 receptors located within a mile (approximately 1,600 m) of the project turbines.

8 REFERENCES


- [1] International Organization for Standardization. ISO 9613-2: Acoustics – Attenuation of Sound During Propagation Outdoors – Part 2: General Method of Calculation. 15 December 1996.
- [2] North Dakota Administrative Code. Chapter 69-06-08-01. Energy conversion facility siting criteria.
- [3] Barnes County Development Code. Section 6.10. Noise. Barnes County, North Dakota. 2016.
- [4] Turbine layout locations sent by email, by RES, to B. Moreira, DNV GL, 15 August 2016, "pUSAavg144_wAlternates_NorthDakota_NAD83_USft.csv".
- [5] Tetrattech EC, INC. Ashtabula III Wind Energy Center Acoustic Assessment Barnes County, North Dakota, NextEra Energy Resources, July 2010.
- [6] Receptor locations sent by email, by RES, to B. Moreira, DNV GL, 20 June 2016, "houses 5_31_16".
- [7] Turbine acoustic specifications sent by email, by RES, to B. Moreira, DNV GL, 13 June 2016, "Vestas_-_3MW_Platform_General_Description_r2.pdf" and "0055-1400_V00 - V126-3_45MW Low Torque Third Octaves.pdf".
- [8] International Electrotechnical Commission. IEC 61400-11 Wind Turbine Generator Systems – Part 11: Acoustic Measurement Techniques. 07 November 2012.
- [9] National Electrical Manufacturers Association. NEMA Standards Publication No TR 1-1993 (R2000): Transformers, Regulators, and Reactors. 2000.
- [10] C57.12.90-2006 IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers.

APPENDIX A – WIND TURBINE GENERATOR AND TRANSFORMER COORDINATES

Glacier Ridge Wind Project wind turbine and transformer coordinates given in UTM Zone 14, NAD 83 Datum.

| Customer ID | Easting [m] | Northing [m] |
|-------------|-------------|--------------|
| A1 | 590076 | 5206196 |
| A2 | 590981 | 5207795 |
| A3 | 591439 | 5207934 |
| A4 | 582849 | 5209629 |
| A5 | 583584 | 5209635 |
| A8 | 587150 | 5219922 |
| A9 | 587524 | 5220163 |
| A15 | 589971 | 5214442 |
| A16 | 585134 | 5210160 |
| A17 | 585288 | 5210512 |
| A18 | 587730 | 5207044 |
| A20 | 588406 | 5207838 |
| T1 | 584691 | 5201066 |
| T2 | 585268 | 5201144 |
| T3 | 584526 | 5201860 |
| T4 | 585247 | 5202145 |
| T5 | 586148 | 5202000 |
| T6 | 586861 | 5201974 |
| T7 | 586290 | 5202798 |
| T8 | 586821 | 5203209 |
| T9 | 587992 | 5202713 |
| T10 | 588380 | 5202851 |
| T11 | 588737 | 5203096 |
| T12 | 583173 | 5202575 |
| T13 | 583626 | 5202581 |
| T14 | 584061 | 5202873 |
| T15 | 584510 | 5203216 |
| T16 | 585095 | 5203673 |
| T17 | 585763 | 5203813 |
| T18 | 587646 | 5204166 |
| T19 | 588117 | 5204521 |
| T20 | 588513 | 5204705 |
| T21 | 584292 | 5204315 |
| T22 | 584515 | 5204835 |
| T23 | 584354 | 5205304 |
| T24 | 584587 | 5205613 |
| T25 | 584913 | 5205936 |
| T26 | 584956 | 5206337 |
| T27 | 585852 | 5205522 |
| T28 | 586096 | 5205960 |
| T29 | 586058 | 5207046 |
| T30 | 587407 | 5205414 |

| Customer ID | Easting [m] | Northing [m] |
|-------------|-------------|--------------|
| T31 | 587750 | 5205710 |
| T32 | 588027 | 5206010 |
| T33 | 588256 | 5206335 |
| T35 | 588827 | 5206922 |
| T36 | 589136 | 5207175 |
| T37 | 589425 | 5207453 |
| T38 | 589657 | 5207903 |
| T39 | 590041 | 5208102 |
| T40 | 590586 | 5208607 |
| T41 | 590902 | 5208814 |
| T42 | 591247 | 5208969 |
| T43 | 584793 | 5206931 |
| T44 | 585178 | 5207338 |
| T45 | 585273 | 5207795 |
| T46 | 585749 | 5208090 |
| T47 | 586053 | 5208401 |
| T48 | 586364 | 5208835 |
| T49 | 586685 | 5209034 |
| T50 | 587313 | 5209079 |
| T51 | 587708 | 5209332 |
| T52 | 588051 | 5209527 |
| T53 | 588391 | 5209693 |
| T54 | 588900 | 5210177 |
| T55 | 584516 | 5208832 |
| T56 | 584714 | 5209233 |
| T57 | 584898 | 5209633 |
| T58 | 587395 | 5210877 |
| T59 | 587807 | 5210994 |
| T60 | 587285 | 5212419 |
| T61 | 587554 | 5212735 |
| T62 | 587925 | 5212919 |
| T63 | 588559 | 5212869 |
| T64 | 588889 | 5213074 |
| T65 | 589041 | 5213426 |
| T66 | 589298 | 5213703 |
| T67 | 589180 | 5215042 |
| T68 | 589331 | 5215446 |
| T69 | 587217 | 5214981 |
| T70 | 587494 | 5215412 |
| T71 | 587614 | 5215885 |
| T72 | 585554 | 5214964 |
| T73 | 585717 | 5215393 |
| T74 | 586001 | 5215847 |
| T75 | 586517 | 5216070 |
| T76 | 584083 | 5215171 |
| T77 | 584221 | 5215618 |



| Customer ID | Easting [m] | Northing [m] |
|--------------------|--------------------|---------------------|
| T78 | 584475 | 5215910 |
| T79 | 585585 | 5216917 |
| T80 | 585730 | 5217440 |
| T81 | 585888 | 5218030 |
| T82 | 586321 | 5218182 |
| T83 | 587027 | 5218200 |
| T84 | 587333 | 5218498 |
| T85 | 588794 | 5218350 |
| T86 | 589109 | 5218643 |
| T87 | 589415 | 5218939 |
| T88 | 587977 | 5218917 |
| Transformer | 587210 | 5211751 |

Ashtabula I Wind Project wind turbine and transformer coordinates given in UTM Zone 14, NAD 83 Datum.

| ID | Easting [m] | Northing [m] |
|-----------|--------------------|---------------------|
| Ash-N1 | 580537 | 5226982 |
| Ash-N2 | 580888 | 5227010 |
| Ash-N3 | 581367 | 5227242 |
| Ash-N4 | 581624 | 5227421 |
| Ash-N5 | 583912 | 5226912 |
| Ash-N6 | 584200 | 5227141 |
| Ash-N7 | 584487 | 5227433 |
| Ash-N8 | 579706 | 5224510 |
| Ash-N9 | 579914 | 5224736 |
| Ash-N10 | 580007 | 5225014 |
| Ash-N11 | 579929 | 5225549 |
| Ash-N12 | 579983 | 5225833 |
| Ash-N13 | 580147 | 5226374 |
| Ash-N14 | 583881 | 5225080 |
| Ash-N15 | 584164 | 5225180 |
| Ash-N16 | 584445 | 5225233 |
| Ash-N17 | 580696 | 5223928 |
| Ash-N18 | 581004 | 5223927 |
| Ash-N19 | 581323 | 5223937 |
| Ash-N20 | 581854 | 5224128 |
| Ash-N21 | 582085 | 5224209 |
| Ash-N22 | 582406 | 5223456 |
| Ash-N23 | 582726 | 5223588 |
| Ash-N24 | 582984 | 5223776 |
| Ash-N25 | 583153 | 5223970 |
| Ash-N26 | 583269 | 5224217 |
| Ash-N27 | 583802 | 5223762 |
| Ash-N28 | 584041 | 5223879 |
| Ash-N29 | 584233 | 5224021 |
| Ash-N30 | 584452 | 5224241 |
| Ash-N31 | 580874 | 5222381 |
| Ash-N32 | 581159 | 5222395 |
| Ash-N33 | 581488 | 5222534 |
| Ash-N34 | 579983 | 5218061 |
| Ash-N35 | 580096 | 5218334 |
| Ash-N36 | 580247 | 5218585 |
| Ash-N37 | 581060 | 5218914 |
| Ash-N38 | 581292 | 5219058 |
| Ash-N39 | 581574 | 5219205 |
| Ash-N40 | 581907 | 5219363 |
| Ash-N41 | 582123 | 5219693 |
| Ash-N42 | 582470 | 5219845 |
| Ash-N43 | 582789 | 5219965 |
| Ash-N44 | 583100 | 5220014 |
| Ash-N45 | 580742 | 5216963 |
| Ash-N46 | 580950 | 5217211 |
| Ash-N47 | 581173 | 5217446 |
| Ash-N48 | 581357 | 5217709 |
| Ash-N49 | 581499 | 5218081 |

| ID | Easting [m] | Northing [m] |
|-----------|--------------------|---------------------|
| Ash-N50 | 581675 | 5218299 |
| Ash-N51 | 582553 | 5218083 |
| Ash-N52 | 582819 | 5218175 |
| Ash-N53 | 583022 | 5218332 |
| Ash-N54 | 583211 | 5218617 |
| Ash-N55 | 581976 | 5216395 |
| Ash-N56 | 582327 | 5216468 |
| Ash-N57 | 582680 | 5216587 |
| Ash-N58 | 583018 | 5216808 |
| Ash-N59 | 582380 | 5215632 |
| Ash-N60 | 582618 | 5215692 |
| Ash-N61 | 583142 | 5215877 |
| Ash-N62 | 579415 | 5214123 |
| Ash-N63 | 579680 | 5214126 |
| Ash-N64 | 580013 | 5214115 |
| Ash-N65 | 580299 | 5214132 |
| Ash-N66 | 580751 | 5214134 |
| Ash-N67 | 581022 | 5214151 |
| Ash-N68 | 581252 | 5214214 |
| Ash-N69 | 581507 | 5214280 |
| Ash-N70 | 582758 | 5214852 |
| Ash-N71 | 583044 | 5214877 |
| Ash-N72 | 583459 | 5214924 |
| Ash-N73 | 579433 | 5212373 |
| Ash-N74 | 579702 | 5212377 |
| Ash-N75 | 580289 | 5212686 |
| Ash-N76 | 580436 | 5212895 |
| Ash-N77 | 582499 | 5213306 |
| Ash-N78 | 582804 | 5213457 |
| Ash-N79 | 583047 | 5213661 |
| Ash-N80 | 583246 | 5213835 |
| Ash-N81 | 583361 | 5214109 |
| Ash-N82 | 582098 | 5210503 |
| Ash-N83 | 582472 | 5210787 |
| Ash-N84 | 582713 | 5211052 |
| Ash-N85 | 583054 | 5211258 |
| Ash-N86 | 582923 | 5212043 |
| Ash-N87 | 583132 | 5212162 |
| Ash-N88 | 583326 | 5212357 |
| Ash-N89 | 583579 | 5212501 |
| Ash-N90 | 584344 | 5213323 |
| Ash-N91 | 584672 | 5213493 |
| Ash-N92 | 584968 | 5213529 |
| Ash-N93 | 585684 | 5210929 |
| Ash-N94 | 585917 | 5211147 |
| Ash-N95 | 586094 | 5211342 |
| Ash-N96 | 586195 | 5211647 |
| Ash-N97 | 586518 | 5211770 |
| Ash-N98 | 586711 | 5211924 |
| Ash-N99 | 586914 | 5212076 |
| Ash-O1 | 578930 | 5221996 |

| ID | Easting [m] | Northing [m] |
|-----------------|--------------------|---------------------|
| Ash-O2 | 579266 | 5222012 |
| Ash-O3 | 579553 | 5222037 |
| Ash-O4 | 579906 | 5222084 |
| Ash-O5 | 580200 | 5222143 |
| Ash-O6 | 577033 | 5219922 |
| Ash-O7 | 577389 | 5220017 |
| Ash-O8 | 577753 | 5220106 |
| Ash-O9 | 578091 | 5220200 |
| Ash-O10 | 578369 | 5220348 |
| Ash-O11 | 578646 | 5220335 |
| Ash-O12 | 579134 | 5220454 |
| Ash-O13 | 579420 | 5220464 |
| Ash-O14 | 580006 | 5220454 |
| Ash-O15 | 580278 | 5220467 |
| Ash-O16 | 580674 | 5220501 |
| Ash-O17 | 581039 | 5220915 |
| Ash-O18 | 581095 | 5221368 |
| Ash-O19 | 581398 | 5221458 |
| Ash-O20 | 581678 | 5221621 |
| Ash-O21 | 581942 | 5221805 |
| Ash-O22 | 582167 | 5221907 |
| Ash-O23 | 582403 | 5222119 |
| Ash-O24 | 582678 | 5222333 |
| Ash-O25 | 580959 | 5220110 |
| Ash-O26 | 581279 | 5220146 |
| Ash-O27 | 581595 | 5220166 |
| Ash-O28 | 582192 | 5220403 |
| Ash-O29 | 582384 | 5220560 |
| Ash-O30 | 584199 | 5219835 |
| Ash-O31 | 584402 | 5219980 |
| Ash-O32 | 584668 | 5220042 |
| AshI-Tranformer | 583763 | 5219639 |

Ashtabula III Wind Project wind turbine and transformer coordinates given in UTM Zone 14, NAD 83 Datum.

| ID | Easting [m] | Northing [m] |
|-------------------|--------------------|---------------------|
| AshIII-T1 | 581721 | 5229602 |
| AshIII-T2 | 582016 | 5229633 |
| AshIII-T3 | 582186 | 5229853 |
| AshIII-T4 | 582168 | 5230781 |
| AshIII-T5 | 582340 | 5231145 |
| AshIII-T6 | 582519 | 5231456 |
| AshIII-T7 | 582928 | 5230353 |
| AshIII-T8 | 583123 | 5230550 |
| AshIII-T9 | 583307 | 5230758 |
| AshIII-T10 | 583770 | 5230782 |
| AshIII-T11 | 584067 | 5230996 |
| AshIII-T12 | 584319 | 5231298 |
| AshIII-T13 | 581041 | 5227910 |
| AshIII-T14 | 581212 | 5228164 |
| AshIII-T15 | 582159 | 5228049 |
| AshIII-T16 | 582521 | 5228018 |
| AshIII-T17 | 582918 | 5228061 |
| AshIII-T18 | 583316 | 5228276 |
| AshIII-T19 | 583679 | 5228371 |
| AshIII-T20 | 583931 | 5228483 |
| AshIII-T21 | 584656 | 5227984 |
| AshIII-T22 | 584973 | 5228196 |
| AshIII-T23 | 586052 | 5228815 |
| AshIII-T24 | 586340 | 5228838 |
| AshIII-T25 | 575909 | 5213922 |
| AshIII-T26 | 576276 | 5214162 |
| AshIII-T27 | 576564 | 5214424 |
| AshIII-T28 | 576228 | 5215256 |
| AshIII-T29 | 576203 | 5215966 |
| AshIII-T30 | 576526 | 5215948 |
| AshIII-T31 | 576825 | 5215990 |
| AshIII-T32 | 577065 | 5216137 |
| AshIII-T33 | 577355 | 5216291 |
| AshIII-T34 | 577522 | 5216565 |
| AshIII-T35 | 577858 | 5216655 |
| AshIII-T36 | 578330 | 5217223 |
| AshIII-T37 | 578594 | 5217617 |
| AshIII-T38 | 578679 | 5218712 |
| AshIII-T39 | 578882 | 5218888 |
| AshIII-Tranformer | 583767 | 5219495 |

APPENDIX B – RECEPTOR LOCATIONS AND ASSOCIATED SOUND LEVELS

| Receptor ID | UTM Coordinates ¹ | | Calculated SPL at Receptor [dBA] ² | Nearest Turbine [ID] | Distance to Nearest Turbine [feet] |
|-------------|------------------------------|--------------|---|----------------------|------------------------------------|
| | Easting [m] | Northing [m] | | | |
| R014 | 587562 | 5221104 | 40.0 | A9 | 3089 |
| R021 | 588531 | 5220177 | 40.8 | A9 | 3304 |
| R022 | 590255 | 5217954 | 38.7 | T87 | 4247 |
| R023 | 590572 | 5217874 | 37.1 | T87 | 5159 |
| R024 | 585578 | 5219533 | 41.2 | T81 | 5034 |
| R025 | 585118 | 5217293 | 46.1 | T79 | 1966 |
| R028 | 584354 | 5216931 | 43.1 | T78 | 3372 |
| R029 | 584690 | 5214845 | 45.6 | T76 | 2262 |
| R030 | 583869 | 5214113 | 45.7 | T76 | 3542 |
| R031 | 587158 | 5216301 | 45.9 | T71 | 2025 |
| R032 | 586878 | 5213678 | 42.9 | T61 | 3808 |
| R033 | 588565 | 5214953 | 45.0 | T67 | 2039 |
| R034 | 587238 | 5209958 | 46.4 | T51 | 2568 |
| R035 | 586989 | 5209860 | 46.1 | T50 | 2774 |
| R036 | 588612 | 5210827 | 45.4 | T54 | 2334 |
| R037 | 590176 | 5209874 | 41.5 | T41 | 4216 |
| R038 | 591832 | 5209102 | 44.1 | T42 | 1969 |
| R042 | 583918 | 5208982 | 45.9 | T55 | 2022 |
| R043 | 588721 | 5208679 | 44.7 | A20 | 2947 |
| R045 | 587501 | 5203580 | 45.9 | T18 | 1981 |
| R046 | 587109 | 5204862 | 45.7 | T30 | 2057 |
| R047 | 587199 | 5204831 | 46.0 | T30 | 2032 |
| R048 | 587383 | 5202578 | 45.7 | T9 | 2047 |
| R049 | 585767 | 5202491 | 47.1 | T7 | 1990 |
| R050 | 585108 | 5204313 | 46.5 | T16 | 2100 |
| R051 | 585569 | 5204380 | 45.8 | T17 | 1967 |
| R052 | 586360 | 5206498 | 46.6 | T28 | 1968 |
| R053 | 587162 | 5207247 | 45.5 | A18 | 1980 |
| R054 | 587053 | 5207619 | 44.4 | A18 | 2914 |
| R055 | 583742 | 5205228 | 45.2 | T23 | 2022 |
| R057 | 585372 | 5206769 | 48.3 | T26 | 1968 |
| R059 | 583799 | 5208374 | 42.8 | T55 | 2792 |
| R060 | 584400 | 5208230 | 45.5 | T55 | 2011 |
| R061 | 581643 | 5209458 | 39.0 | A4 | 3997 |
| R062 | 581835 | 5209785 | 41.0 | A4 | 3365 |
| R063 | 581753 | 5209984 | 41.5 | A4 | 3779 |
| R070 | 585680 | 5211529 | 47.7 | A17 | 3574 |
| R073 | 584021 | 5203718 | 46.2 | T21 | 2152 |
| R074 | 584004 | 5203615 | 46.1 | T15 | 2113 |
| R075 | 583392 | 5203391 | 44.2 | T13 | 2769 |
| R076 | 583205 | 5203338 | 43.8 | T12 | 2506 |
| R083 | 585526 | 5200014 | 38.6 | T2 | 3804 |
| R100 | 588329 | 5202120 | 44.3 | T9 | 2238 |

| Receptor ID | UTM Coordinates ¹ | | Calculated SPL at Receptor [dBA] ² | Nearest Turbine [ID] | Distance to Nearest Turbine [feet] |
|-------------|------------------------------|--------------|---|----------------------|------------------------------------|
| | Easting [m] | Northing [m] | | | |
| R111 | 591834 | 5206916 | 40.0 | A3 | 3581 |
| R112 | 588722 | 5214037 | 46.0 | T66 | 2185 |
| R119 | 583617 | 5215549 | 47.6 | T76 | 1967 |
| R124 | 588614 | 5217226 | 40.9 | T85 | 3735 |
| R127 | 584738 | 5200004 | 39.2 | T1 | 3487 |
| R128 | 587393 | 5203011 | 46.1 | T8 | 1986 |

Note 1: Coordinates given in UTM Zone 14, NAD83 Datum

Note 2: Highest value within 100 feet from the receptor center



ABOUT DNV GL

Driven by our purpose of safeguarding life, property and the environment, DNV GL enables organizations to advance the safety and sustainability of their business. We provide classification and technical assurance along with software and independent expert advisory services to the maritime, oil and gas, and energy industries. We also provide certification services to customers across a wide range of industries. Operating in more than 100 countries, our 16,000 professionals are dedicated to helping our customers make the world safer, smarter, and greener.