



APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY
 Public Service Commission
 SFN 51277 (2/2014)



TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED

Name of Company CMS Petroleum Equip Co	Email Address jschultz004@msn.com	Application Date 12-11-16	
Mailing Address PO Box 85	City Morris	State MN	Zip Code 56267
Telephone Number 320-589-9017	Cell Phone Number 320-760-4146	Fax Number 320-589-9010	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List: <p style="text-align: center;">N/A</p>	<input type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: _____ <input type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: _____ <input checked="" type="checkbox"/> 5. LPG <input checked="" type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
e.g. 1001	e.g. John Doe	e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6
	John Schultz	256
	Joe McNally	256
	Jeff Finke	256
	Tyler McNally	256



List below all field standards (attach current calibration reports):

See attached	


Additional Application Items (initial where appropriate):

Standardized Test Report	js	<input checked="" type="checkbox"/> Copy enclosed	<input type="checkbox"/> No change in report filed previously
Tested and Approved Sticker	js	<input checked="" type="checkbox"/> Copy enclosed	<input type="checkbox"/> No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal	js	<input checked="" type="checkbox"/> Copy enclosed	<input type="checkbox"/> No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.
 Yes No

I am John Schultz, and have authority to represent this company.
By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.




Signature

Send Completed Application and Related Documents To:

Public Service Commission
600 E Boulevard Ave Dept 408
Bismarck ND 58505-0480
Telephone: (701) 328-2400
Fax: (701) 328-2410

North Dakota

nd.gov | Official Portal for
North Dakota State GovernmentNorth Dakota
LEGENDARY

SECRETARY OF STATE NORTH DAKOTA

[Home](#) | [Business Records Search](#)

CMS PETROLEUM EQUIPMENT CO.

Corporation Details

System ID: 12648800 **Phone:** (320) 589-9017
Type: FOREIGN BUSINESS CORPORATION
Status: Active & Good Standing
Original File Date: 04/07/1999 **Effective Date:** 04/07/1999
State of Origin: Minnesota

Nature of Business

PETROLEUM EQUIPMENT SALES & SERVICE

Principal Office

48505 210TH ST PO BOX 85 MORRIS, MN 56267-0085

Registered Agent

QUAM PETROLEUM SERVICE, INC.
4720 HWY 6 S
MANDAN, ND 58554-8513
Established Date: Jun 06, 2005

Generate an Annual Report To File

To Generate a Annual Report form to be filed with the Secretary of State, select the appropriate year of the report you intend to file. This report does not contain details of a report previously filed with the Secretary of State. The annual report years reflected are an indication of the various report forms available in this site and is not an indication that an entity needs to file reports for all years. Missing years indicate that the forms for the missing year have not yet been deployed to the website, or have already been removed, and can be obtained by contacting the Secretary of State.

[2016](#) (generates a forms-fillable pdf in a new pop-up window)

[Return to Search Results](#)

[Contact Us](#)[Disclaimer](#) | [Privacy Policy](#)

We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.



Receipt Date: November 28, 2016
Cal. Date: November 29, 2016
Report Date: November 30, 2016

Report No.: 336824
Serial No.: 102
Barcode: 017450

Calibration Certificate

CMS PETROLEUM EQUIPMENT
48150 210TH ST
MORRIS, MN 56267
Contact: Joel McNally
Phone: 320-589-9017
PO Number: None
SOP: 19
Technician ID: 19

Item(s) Submitted: 100 Gallon Prover
Manufacturer: Kleespie
Material: Mild Steel
Type: No Bottom Zero
Condition: Good*
Temperature: 18.7 °C
Pressure: 720.4 mmHg
Relative Humidity: 49.4 %
Standard H₂O Temp.: 13.8 °C
Artifact H₂O Temp.: 14.0 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
100	As Found	100.005	1.2	2.01	3.3	0.0000186
	As Left	100.005	1.2			

Neck Calibration: No neck calibration was performed at this time.

***Levels are not accurate or adjustable, level prover to the neck. Levels must be adjustable and sealable to meet NIST Handbook 105-3 section 4.5.23 by next calibration cycle.**

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow.

The vessel listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F
Conversion to SI unit: 1 gallon = 231 in³ = 0.00378541 m³.

Erik Alfvin

Metrologist

Reviewed by:
Mark Nicollet

Quality Manager



Receipt Date: November 28, 2016
Cal. Date: November 30, 2016
Report Date: December 1, 2016

Report No.: 336825
Serial No.: 33011
Barcode: 018524

Calibration Certificate

CMS PETROLEUM EQUIPMENT
48150 210TH ST
MORRIS, MN 56267
Contact: Joel McNally
Phone: 320-589-9017
PO Number: None
SOP: 21
Technician ID: 19

Item(s) Submitted: 100 Gallon LPG Prover
Manufacturer: Arrow Tank & Eng
Material: Mild Steel
Description: Zero Bottom
Condition: Good
Temperature: 20.2 °C
Pressure: 723.8 mmHg
Relative Humidity: 38.7 %
Standard H₂O Temp. 14.0 °C
Artifact H₂O Temp.: 14.5 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (1/°F)
100	As Found (at 100 psig)	99.992	-1.9	2.02	5.3	0.0000186
	As Left (at 100 psig)	99.992	-1.9			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow. The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-4 (2010). Uncertainty calculations contain the components in NIST SOP 21 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F.

Erik Alfvjn

Metrologist

Reviewed by:

Mark Nicollet

Quality Manager



Receipt Date: November 28, 2016
Cal. Date: November 30, 2016
Report Date: December 1, 2016


Report No.: 336825
Serial No.: 33011
Barcode: 018524

Pressure Correction Chart

CMS PETROLEUM EQUIPMENT
48150 210TH ST
MORRIS, MN 56267
Contact: Joel McNally
Phone: 320-589-9017
PO Number: None
SOP: 21
Technician ID: 19

Item(s) Submitted: 100 Gallon LPG Prover
Manufacturer: Arrow Tank & Eng
Material: Mild Steel
Description: Zero Bottom
Condition: Good
Temperature: 20.2 °C
Pressure: 723.8 mmHg
Relative Humidity: 38.7 %

Pressure Gauge Reading (psig)	Corrected Volume (gal)
0	99.894
10	99.905
20	99.915
30	99.926
40	99.936
50	99.947
60	99.956
70	99.965
80	99.974
90	99.983
100	99.992
110	100.000
120	100.009
130	100.017
140	100.026
150	100.034
160	100.042
170	100.049
180	100.057
190	100.064
200	100.072

Erik Alfvin

Metrologist

United States Department of Commerce
National Institute of Standards and Technology

Certificate of Metrological Traceability For:

Minnesota

This laboratory has demonstrated evidence of an unbroken chain of metrological traceability of its standards to the international system of units (SI), documented measurement uncertainties, uses documented measurement procedures, successfully completed training and proficiency tests, documented calibration intervals, submitted a quality management system, and demonstrated suitable measurement assurance for the Scope listed on this certificate.

The Office of Weights and Measures Program assesses laboratories to NIST Handbook 143 - Program Handbook for State Weights and Measures Laboratories and ISO/IEC 17025:2005.

Scope

Mass Echelon II	Weight Carts	Volume Gravimetric, I
50 kg to 1 mg	10 000 lb to 2000 lb	20 L to 10 ml
1000 lb to 0.001 lb	Wheel Load Weighers	100 gal to 0.25 qt
4 oz to 0.03125 oz	20 000 lb to 2000 lb	Volume Transfer, II
Mass Echelon III	Railroad Test Cars	1500 gal to 5 gal
50 kg to 1 mg	110 000 lb to 80 000 lb	100 gal to 25 gal LPG
5000 lb to 0.001 lb		
4 oz to 0.03125 oz		



2016 to 2017

A handwritten signature in black ink, appearing to read "Carol T. Hockert".

Carol T. Hockert, Chief
NIST Office of Weights and Measures

Effective Dates: 2016-01-01 to 2017-12-31