



APPLICATION FOR REGISTRATION AS A REGISTERED SERVICE COMPANY
 Public Service Commission
 SFN 51277 (2/2014)



TYPE OR PRINT - AN INCOMPLETE OR ILLEGIBLE APPLICATION WILL BE REJECTED

Name of Company Midwest Pump and Tank	Email Address mpt@midwestpump.com	Application Date Jan 12, 2017	
Mailing Address PO Box 2105	City Aberdeen	State SD	Zip Code 57402
Telephone Number 605-225-0577	Cell Phone Number 605-380-5185	Fax Number 605-225-0516	

Select below all device types your company will certify:

Scales (include maximum capacity, if applicable)	Liquid (include maximum flow rate, if applicable)
<input type="checkbox"/> 1. Rail <input type="checkbox"/> 2. Truck <input type="checkbox"/> 3. Livestock <input type="checkbox"/> 4. Hopper: Max. Capacity: _____ <input type="checkbox"/> 5. Belt <input type="checkbox"/> 6. Over 30 lbs.: Max. Capacity: _____ <input type="checkbox"/> 7. 30 lbs. or less <input type="checkbox"/> 8. Class II (indicate on your calibration report which weight kit is Class II certified) <input type="checkbox"/> 9. Other: Please List:	<input checked="" type="checkbox"/> 1. Retail Fuel (less than 20 gal. per minute) <input checked="" type="checkbox"/> 2. High Flow Retail Fuel (20 gal. per minute or greater) <input checked="" type="checkbox"/> 3. Vehicle Tank: Max. Flow Rate: <u>100</u> <input checked="" type="checkbox"/> 4. Stationary Bulk (fuel or oil): Max. Flow Rate: <u>100</u> <input type="checkbox"/> 5. LPG <input type="checkbox"/> 6. Stationary LPG <input type="checkbox"/> 7. Fertilizer: Max. Flow Rate: _____ <input type="checkbox"/> 8. Chemical <input type="checkbox"/> 9. Anhydrous <input type="checkbox"/> 10. Loading Rack <input type="checkbox"/> 11. Other: Please List:

List below all persons employed by your company as a North Dakota Registered Service Person and the device types they are registered to certify (attach a separate sheet to list additional employees):

Permit No.	Employee	Device Types Registered to Certify (list using device type numbers from above)
<i>e.g. 1001</i>	<i>e.g. John Doe</i>	<i>e.g. Scales - 2, 3, 6, 8; e.g. Liquid - 1, 2, 6</i>
1415	Joe Juve	1, 2, 3, 4 Liquid
1533	Jerry Sjerven	1, 2, 3, 4 Liquid




Continued on Page 2

Application for Registration as a Registered Service Company
Page 2

List below all field standards (attach current calibration reports):

Seraphin	5 gallon	S# 07-05607
Ellisco	5 gallon	No S#
Gas Service & Supply	100 gallon	S# 1221


Additional Application Items (initial where appropriate):

Standardized Test Report		Copy enclosed No change in report filed previously
Tested and Approved Sticker		Copy enclosed No change in sticker filed previously
Photocopy of Crimped Lead Wire Seal		Copy enclosed No change in crimped lead wire seal filed previously

Public Company Listing:

Include my company information on your registered service company list for public contact.
 Yes No

I am Jerry Sjerven, and have authority to represent this company.
 By signing this application, I declare that I have examined this form and accompanying documentation, and to the best of my knowledge and belief, the facts stated and documentation provided is true, correct, and complete.


Signature

Send Completed Application and Related Documents To:

Public Service Commission
 600 E Boulevard Ave Dept 408
 Bismarck ND 58505-0480
 Telephone: (701) 328-2400
 Fax: (701) 328-2410

North Dakota

nd.gov Official Portal for North Dakota State Government



SECRETARY OF STATE NORTH DAKOTA



[Home](#) | [Business Records Search](#)

MIDWEST PUMP & TANK

Trade Name

System ID: 9979400	Phone: (605) 225-0577
Status: Active	
Original File Date: 10/06/1995	Last Renewal Date: 10/06/2015

Nature of Business

SALES, SERVICE, REPAIR AND INSTALLATION OF PETROLEUM RELATED EQUIPMENT SUCH AS GAS PUMPS AND DISPENSERS, HOSES, NOZZLES, BULK TRUCKS, METERS, TANKS A ND TANK EQUIPMENT

Owners

J.W. PETRO SERVICE, INC.
820 S HWY 281
PO BOX 2105
ABERDEEN, SD 57402-2105

[Return to Search Results](#)

[Contact Us](#)

[Disclaimer](#) | [Privacy Policy](#)

We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.

North Dakota

nd.gov Official Portal for
North Dakota State GovernmentNorth Dakota
LEGENDARY

SECRETARY OF STATE NORTH DAKOTA

[Home](#) | [Business Records Search](#)

J.W. PETRO SERVICE, INC.

Corporation Details

System ID: 33694800**Phone:** (800) 874-9231**Type:** FOREIGN BUSINESS CORPORATION**Status:** Active & Good Standing**Original File Date:** 02/22/2013**Effective Date:** 02/22/2013**State of Origin:** South Dakota

Nature of Business

SERVICE/REPAIR/SALES/INSTALL OF PETROLEUM RELATED EQUIPMENT

Principal Office

820 S HWY 281 PO BOX 2105 ABERDEEN, SD 57402-2105

Registered Agent

GIMBEL BUSINESS SERVICE LLC

147 MAIN ST

PO BOX 265

HAZELTON, ND 58544-0265

Established Date: Feb 22, 2013

Generate an Annual Report To File

To Generate a Annual Report form to be filed with the Secretary of State, select the appropriate year of the report you intend to file. This report does not contain details of a report previously filed with the Secretary of State. The annual report years reflected are an indication of the various report forms available in this site and is not an indication that an entity needs to file reports for all years. Missing years indicate that the forms for the missing year have not yet been deployed to the website, or have already been removed, and can be obtained by contacting the Secretary of State.

[2016](#) (generates a forms-fillable pdf in a new pop-up window)[Return to Search Results](#)[Contact Us](#)[Disclaimer](#)[Privacy Policy](#)

We use Secure Sockets Layer (SSL) encryption technology to ensure your information is secure and protected.

Will open a new window (pop-up).

W3C WAI AA, CSS, XHTML Compliant | Copyright 2006. All Rights Reserved. The State of North Dakota.

Receipt Date: June 3, 2016
 Cal. Date: June 3, 2016
 Report Date: June 3, 2016

Report No.: 336033
 Serial No.: None
 Barcode: 013146

Calibration Certificate

MIDWEST PUMP & TANK
 820 S HWY 281
 ABERDEEN, SD 57402-2105
 Contact: JERRY
 Phone: 605-380-5185
 PO Number: NONE
 SOP: 19
 Technician ID: 07

Item(s) Submitted: 5 Gallon Measure
 Manufacturer: Seraphin
 Material: Mild Steel
 Type: Measure
 Condition: Good
 Temperature: 23.2 °C
 Pressure: 735.8 mmHg
 Relative Humidity: 53.1 %
 Standard H₂O Temp.: 20.8 °C
 Artifact H₂O Temp.: 20.7 °C

Nominal		Calibrated				
Volume (gal)		Volume (gal)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
5	As Found	4.9996	-0.10	2.06	0.24	0.0000186
	As Left	4.9996	-0.10			

Neck Calibration: No neck calibration was performed at this time.


This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Mark Nicollet


 Quality Manager

Reviewed by:

Erik Alfvin


 Metrologist

Receipt Date: June 3, 2016
 Cal. Date: June 3, 2016
 Report Date: June 3, 2016

Report No.: 336034
 Serial No.: 07-05607
 Barcode: 013144

Calibration Certificate

MIDWEST PUMP & TANK
 820 S HWY 281
 ABERDEEN, SD 57402-2105
 Contact: JERRY
 Phone: 605-380-5185
 PO Number: NONE
 SOP: 19
 Technician ID: 07

Item(s) Submitted: 5 Gallon Measure
 Manufacturer: Seraphin
 Material: Stainless Steel
 Type: Measure
 Condition: Excellent
 Temperature: 23.2 °C
 Pressure: 735.8 mmHg
 Relative Humidity: 53.1 %
 Standard H₂O Temp.: 20.8 °C
 Artifact H₂O Temp.: 20.7 °C

Nominal	Calibrated		<i>k</i>	U (in ³)	CCE (°F)
Volume (gal)	Volume (gal)	Error (in ³)			
5	As Found	4.9993	-0.17	2.06	0.24 0.0000265
	As Left	4.9993	-0.17		

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a pour time of 30 seconds followed by a drain time of 10 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Mark Nicollet


 Quality Manager

Reviewed by:

Erik Alfvin


 Metrologist

Receipt Date: June 3, 2016
 Cal. Date: June 3, 2016
 Report Date: June 3, 2016

Report No.: 336035
 Serial No.: 1221
 Barcode: 201254

Calibration Certificate

MIDWEST PUMP & TANK
 820 S HWY 281
 ABERDEEN, SD 57402-2105
 Contact: JERRY
 Phone: 605-380-5185
 PO Number: NONE
 SOP: 19
 Technician ID: 07

Item(s) Submitted: 100 Gallon Prover
 Manufacturer: Gas Service & Supply
 Material: Stainless Steel (304)
 Type: Bottom Zero
 Condition: Excellent
 Temperature: 23.1 °C
 Pressure: 735.6 mmHg
 Relative Humidity: 50.4 %
 Standard H₂O Temp.: 13.8 °C
 Artifact H₂O Temp.: 14.0 °C

Nominal		Calibrated				
Volume (gal)		Volume (gai)	Error (in ³)	<i>k</i>	U (in ³)	CCE (°F)
100	As Found	99.996	-0.9	2.01	3.3	0.0000288
	As Left	99.996	-0.9			

Neck Calibration: No neck calibration was performed at this time.

This prover has been calibrated as a "to contain after wet down" vessel with a drain time of 30 seconds after cessation of full flow.

The prover listed above has been compared by volumetric transfer methods to the standards of the State of Minnesota using water as the calibration medium. The standards are traceable to the SI through NIST. Statistical process control charts indicate standards are currently in control. All gauges were sealed in place.

All tolerances and specifications were evaluated according to NIST Handbook 105-3 (2010). Uncertainty calculations contain the components in NIST SOP 19 and conform to the ISO/IEC Guide to the Expression of Uncertainty in Measurement (2008), including coverage factors (*k*) calculated at the approximate 95.45 % confidence level. Results apply to item identified in this report only.

CCE is the cubical coefficient of thermal expansion, and the reference temperature is 60 °F

Mark Nicollet

Mark Nicollet
 Quality Manager

Reviewed by:

Pete Whebbe

Pete Whebbe
 Metrologist

United States Department of Commerce

National Institute of Standards and Technology

Certificate of Metrological Traceability For:

Minnesota

This laboratory has demonstrated evidence of an unbroken chain of metrological traceability of its standards to the international system of units (SI), documented measurement uncertainties, uses documented measurement procedures, successfully completed training and proficiency tests, documented calibration intervals, submitted a quality management system, and demonstrated suitable measurement assurance for the Scope listed on this certificate.

The Office of Weights and Measures Program assesses laboratories to NIST Handbook 143 - Program Handbook for State Weights and Measures Laboratories and ISO/IEC 17025:2005.

Scope

Mass Echelon II	Weight Carts	Volume Gravimetric, I
50 kg to 1 mg	10 000 lb to 2000 lb	20 L to 10 mL
1000 lb to 0.001 lb	Wheel Load Weighers	100 gal to 0.25 qt
4 oz to 0.03125 oz	20 000 lb to 2000 lb	Volume Transfer, II
Mass Echelon III	Railroad Test Cars	1500 gal to 5 gal
50 kg to 1 mg	110 000 lb to 80 000 lb	100 gal to 25 gal LPG
5000 lb to 0.001 lb		
4 oz to 0.03125 oz		



2016 to 2017

A handwritten signature in black ink, appearing to read "Carol T. Hockett".

Carol T. Hockett, Chief
NIST Office of Weights and Measures

Effective Dates: 2016-01-01 to 2017-12-31