

LF - 5  
DVEC  
Exhibit  
*REDACTED*

Elevator 1				Elevator 2				Elevator 3				Elevator 4				Elevator 5			
Date	kWh	kW	Load Factor	Date	kWh	kW	Load Factor	Date	kWh	kW	Load Factor	Date	kWh	kW	Load Factor	Date	kWh	kW	Load Factor
Sep-17	77,200	505	21.2%	Sep-17	108,500	834	18.1%	Sep-17	119,360	361.6	45.8%	Sep-17	105,300	659	22.9%	Sep-17	148,800	614.7	33.6%
Aug-17	105,300	672	21.1%	Aug-17	154,900	696	29.9%	Aug-17	177,760	355.2	67.3%	Aug-17	116,100	666	23.4%	Aug-17	193,200	792.6	32.8%
Jul-17	99,200	728	18.3%	Jul-17	100,100	708	19.0%	Jul-17	174,960	372	68.2%	Jul-17	76,500	675	15.2%	Jul-17	173,400	999.3	24.8%
Jun-17	82,700	651	17.6%	Jun-17	76,000	855	12.3%	Jun-17	194,480	388.4	52.1%	Jun-17	55,800	522	14.8%	Jun-17	228,600	920.4	34.5%
May-17	71,200	578	16.6%	May-17	35,200	534	8.9%	May-17	112,960	477.2	35.5%	May-17	54,000	531	13.7%	May-17	170,100	843	27.1%
Apr-17	103,400	678	21.2%	Apr-17	72,700	612	16.5%	Apr-17	129,840	421.6	42.8%	Apr-17	52,200	513	14.1%	Apr-17	158,400	866.1	25.4%
Mar-17	115,100	649	23.8%	Mar-17	94,300	650	19.5%	Mar-17	125,360	320	52.7%	Mar-17	86,200	567	20.9%	Mar-17	240,900	1,019.10	31.8%
Feb-17	165,000	750	32.7%	Feb-17	115,200	773	22.2%	Feb-17	127,200	453.6	41.7%	Feb-17	81,000	675	17.9%	Feb-17	243,600	987.9	36.7%
Jan-17	126,300	824	20.6%	Jan-17	137,500	941	19.6%	Jan-17	143,280	441.6	43.6%	Jan-17	101,700	567	24.1%	Jan-17	318,600	1,056.00	40.6%
Dec-16	118,300	788	20.2%	Dec-16	71,700	656	14.7%	Dec-16	112,000	311.2	48.4%	Dec-16	83,700	585	19.2%	Dec-16	345,900	1,109.70	41.9%
Nov-16	315,900	842	52.1%	Nov-16	190,400	820	32.2%	Nov-16	128,880	360.8	49.6%	Nov-16	134,100	891	20.9%	Nov-16	345,300	1,110.00	43.2%
Oct-16	313,700	904	46.6%	Oct-16	229,800	951	32.5%	Oct-16	139,360	406.4	46.1%	Oct-16	128,700	828	20.9%	Oct-16	214,200	1,111.80	25.9%
<b>Average</b>			<b>26.0%</b>	<b>Average</b>			<b>20.5%</b>	<b>Average</b>			<b>49.1%</b>	<b>Average</b>			<b>19.0%</b>	<b>Average</b>			<b>33.2%</b>

Minnesota Ag Riverside (Dih Prosser)			
Date	kWh	kW	Load Factor
Sep-12	66,720	471.12	19.7%
Aug-12	92,800	488.48	25.6%
Jul-12	68,880	436.08	21.2%
Jun-12	16,560	401.92	5.7%
May-12	11,760	409.44	3.9%
Apr-12	13,440	432.48	4.3%
Mar-13	24,240	433.2	7.5%
Feb-13	24,960	405.36	9.2%
Jan-13	74,640	502.8	20.0%
Dec-12	84,240	533.28	21.2%
Nov-12	82,800	492.48	23.4%
Oct-12	60,000	480.48	16.8%
<b>Average</b>			<b>14.9%</b>

Elevator 6			
Date	kWh	kW	Load Factor
Sep-17	66,600	459	20.2%
Aug-17	66,600	324	27.6%
Jul-17	30,600	306	13.4%
Jun-17	30,600	324	13.1%
May-17	24,300	225	14.5%
Apr-17	45,900	405	15.7%
Mar-17	153,900	549	37.7%
Feb-17	138,600	531	38.8%
Jan-17	66,600	477	18.8%
Dec-16	32,400	414	10.5%
Nov-16	148,500	594	34.7%
Oct-16	306,000	882	46.6%
<b>Average</b>			<b>24.3%</b>