

STATE OF NORTH DAKOTA

PUBLIC SERVICE COMMISSION

Harmony Solar ND, LLC  
Harmony Solar Project – Cass County  
Siting Application

Case No. PU-18-219

AFFIDAVIT OF SERVICE BY CERTIFIED MAIL

STATE OF NORTH DAKOTA  
COUNTY OF BURLEIGH

**Geralyn R. Schmaltz** deposes and says that:

she is over the age of 18 years and not a party to this action and, on the **19th day of March 2026**, she deposited in the United States Mail, at Bismarck, North Dakota, **one** envelope with certified postage, return receipt requested, fully prepaid, securely sealed and containing a photocopy of:


- Notice of Filing and Notice of Opportunity for Hearing

The envelope was addressed as follows:

Mollie Smith  
Attorney for Harmony Solar ND, LLC  
Fredrikson & Byron, P. A.  
60 S 6<sup>th</sup> Street Suite 1500  
Minneapolis, MN 55402-1425  
**Cert. No. 9589 0710 5270 2708 2432 98**

Each address shown is the respective addressee's last reasonably ascertainable post office address.

Subscribed and sworn to before me  
this **19th day of March 2026**.



SEAL

**STATE OF NORTH DAKOTA  
PUBLIC SERVICE COMMISSION**

**Harmony Solar ND, LLC  
Harmony Solar Project – Cass County  
Siting Application**

**Case No. PU-18-219**

**NOTICE OF FILING AND NOTICE OF OPPORTUNITY FOR HEARING**

On June 29, 2018, Harmony Solar ND, LLC (Harmony Solar) filed an Application for a Certificate of Site Compatibility for a 200 megawatt (MW) solar energy conversion facility to be located in Cass County, North Dakota.

On February 26, 2019, the North Dakota Public Service Commission (Commission) adopted its Findings of Fact, Conclusions of Law and Order (Order) issuing Certificate of Site Compatibility Number 58 (Certificate) to Harmony Solar for the construction, operation and maintenance of a solar energy conversion facility with a nameplate capacity up to 200 MW in Cass County, North Dakota (Project).

On February 23, 2026, Harmony Solar filed an application to amend the Order and Certificate. Harmony Solar's amendment request is to modify paragraph 14 of the Certification Relating to Order Provisions to authorize direct current cables to be buried to a depth of at least 24 inches rather than the current language in that paragraph which requires burial to a depth of at least 48 inches.

The issues to be considered in this proceeding are:

1. Will the location, construction, and operation of the proposed facilities produce minimal adverse effects on the environment and upon the welfare of the citizens of North Dakota?
2. Are the proposed facilities compatible with the environmental preservation and the efficient use of resources?
3. Will the proposed facility locations minimize adverse human and environmental impact while ensuring continuing system reliability and integrity and ensuring that energy needs are met and fulfilled in an orderly and timely fashion?


Those interested are invited to comment on the application in writing. Persons desiring a hearing must file a written request identifying their interest in the proceeding and the reasons for requesting a hearing. **Comments and requests for hearings must be received by April 27, 2026.** If deemed appropriate, the Commission can determine the matter without a formal hearing.

For more information contact the Public Service Commission, State Capitol, Bismarck, North Dakota 58505, 701-328-2400; or Relay North Dakota 1-800-366-6888

TTY. If you require any auxiliary aids or services, such as readers, signers, or Braille materials please notify the Commission.

Issued: March 18, 2026

**PUBLIC SERVICE COMMISSION**



Sheri Haugen-Hoffart  
Commissioner



Randy Christmann  
Chair



Jill Kringstad  
Commissioner