




October 15, 2018

ND Public Service Commission
600 E. Boulevard Ave., Dept. 408
Bismarck, ND 58505-0480



Re: Emmons-Logan Wind Energy Center and 230 kV Transmission Line
Case No. PU-18-280, Emmons and Logan Counties
Case No. PU-18-281, Emmons County

Dear Commissioners:

This department has reviewed the information concerning the above-referenced project submitted under date of October 10, 2018, with respect to possible environmental impacts.

This department believes that environmental impacts from the proposed construction will be minor and can be controlled by proper construction methods. With respect to construction, our comments remain the same as those in our May 29, 2018 response to Dr. Lindsay Churchill of AECOM (copy attached).

If you have any questions regarding our comments, please feel free to contact this office.

Sincerely,

L. David Glatt, P.E., Chief
Environmental Health Section

LDG:cc
Attach.

75 **PU-18-280** Filed: 12/7/2018 Pages: 4
Exhibit 27 – Agency Comments – ND Dept. of Health

Emmons-Logan Wind, LLC

19 **PU-18-280** Filed: 10/17/2018 Pages: 4
Comments

North Dakota Department of Health
L. David Glatt, P.E., Chief



53 **PU-18-281** Filed: 12/7/2018 Pages: 4
Exhibit 27 – Agency Comments – ND Dept. of Health

Emmons-Logan Wind, LLC

Division of
Municipal Facilities
701.328.5211

Division of
Waste Management
701.328.5166

Division of
Water Quality
701.328.5210



May 29, 2018

Dr. Lindsey Churchill, PhD, PWS
Environmental Project Manager
AECOM
1000 East Calgary Avenue, Suite 1
Bismarck, ND 58503

Re: Emmons-Logan Wind Energy Center & Transmission Line Project
Emmons and Logan Counties

Dear Dr. Churchill:

This department has reviewed the information concerning the above-referenced project submitted under date of May 3, 2018, with respect to possible environmental impacts.

This department believes that environmental impacts from the proposed construction will be minor and can be controlled by proper construction methods. With respect to construction, we have the following comments:

1. Care is to be taken during construction activity near any water of the state to minimize adverse effects on a water body. This includes minimal disturbance of stream beds and banks to prevent excess siltation, and the replacement and revegetation of any disturbed area as soon as possible after work has been completed. Caution must also be taken to prevent spills of oil and grease that may reach the receiving water from equipment maintenance, and/or the handling of fuels on the site. Guidelines for minimizing degradation to waterways during construction are attached.
2. Projects disturbing one or more acres are required to have a permit to discharge storm water runoff until the site is stabilized by the reestablishment of vegetation or other permanent cover. Further information on the storm water permit may be obtained from the Department's website or by calling the Division of Water Quality (701-328-5210). Also, cities may impose additional requirements and/or specific best management practices for construction affecting their storm drainage system. Check with the local officials to be sure any local storm water management considerations are addressed.
3. The northeaster portion of the proposed construction project overlies the Braddock glacial drift aquifer, which is a designated sensitive aquifer. Numerous stock watering and domestic water wells are located within the proposed project area. Care should be taken to avoid spills of any materials that may have an adverse effect on groundwater quality. All spills must be immediately reported to this Department and appropriate remedial actions performed.

Dr. Lindsey Churchill


2.

May 29, 2018

The department owns no land in or adjacent to the proposed improvements, nor does it have any projects scheduled in the area. In addition, we believe the proposed activities are consistent with the State Implementation Plan for the Control of Air Pollution for the State of North Dakota.

If you have any questions regarding our comments, please feel free to contact this office.

Sincerely,



L. David Glatt, P.E., Chief
Environmental Health Section

LDG:cc
Attach.



Construction and Environmental Disturbance Requirements

These represent the minimum requirements of the North Dakota Department of Health. They ensure that minimal environmental degradation occurs as a result of construction or related work which has the potential to affect the waters of the State of North Dakota. All projects will be designed and implemented to restrict the losses or disturbances of soil, vegetative cover, and pollutants (chemical or biological) from a site.

Soils

Prevent the erosion of exposed soil surfaces and trapping sediments being transported. Examples include, but are not restricted to, sediment dams or berms, diversion dikes, hay bales as erosion checks, riprap, mesh or burlap blankets to hold soil during construction, and immediately establishing vegetative cover on disturbed areas after construction is completed. Fragile and sensitive areas such as wetlands, riparian zones, delicate flora, or land resources will be protected against compaction, vegetation loss, and unnecessary damage.

Surface Waters

All construction which directly or indirectly impacts aquatic systems will be managed to minimize impacts. All attempts will be made to prevent the contamination of water at construction sites from fuel spillage, lubricants, and chemicals, by following safe storage and handling procedures. Stream bank and stream bed disturbances will be controlled to minimize and/or prevent silt movement, nutrient upsurges, plant dislocation, and any physical, chemical, or biological disruption. The use of pesticides or herbicides in or near these systems is forbidden without approval from this Department.

Fill Material

Any fill material placed below the high water mark must be free of top soils, decomposable materials, and persistent synthetic organic compounds (in toxic concentrations). This includes, but is not limited to, asphalt, tires, treated lumber, and construction debris. The Department may require testing of fill materials. All temporary fills must be removed. Debris and solid wastes will be removed from the site and the impacted areas restored as nearly as possible to the original condition.