

Ruso Wind Partners, LLC
Ruso Wind Project and Gen-Tie Line Project
Docket Nos. PU-19-28/PU-19-29

Late-Filed Exhibit No. 59 – Update on Interconnection Request

At the public hearing, Ruso Wind Partners, LLC (“Ruso Wind”) presented testimony regarding the status of its interconnection request in the Midcontinent Independent System Operator, Inc.’s (“MISO”) queue. At that time, Ruso Wind anticipated completing MISO’s Detailed Planning Phase 2 in July and moving into MISO’s Detailed Planning Phase 3.

After the public hearing, Ruso Wind received MISO’s final Detailed Planning Phase 2 network upgrade cost determination, which was greater than \$500 million. As a result of the upgrade cost determination, Ruso Wind has withdrawn its interconnection request from the MISO queue effective as of August 9, 2019 and is exploring other interconnection options for the Project, including potentially interconnecting at the same location via the Southwest Power Pool. Since the MISO interconnection request was discussed in written and oral testimony presented at the public hearing, Ruso Wind is providing this update to ensure an accurate record.