

Hamre, John G.

From: Schock, Victor F.
Sent: Wednesday, February 2, 2022 1:43 PM
To: Hamre, John G.
Subject: FW: MDU water line siting PU-22-34

John,

Can you please file the email below as responses to data requests?

Thanks,

Victor Schock

From: Jacobson, Travis <travis.jacobson@mdu.com>
Sent: Friday, January 28, 2022 11:12 AM
To: Schock, Victor F. <vschock@nd.gov>
Subject: RE: MDU water line siting PU-22-34

******* CAUTION:** This email originated from an outside source. Do not click links or open attachments unless you know they are safe. *********

Victor,

Please see my comments in red following your requests.

From: Schock, Victor F. <vschock@nd.gov>
Sent: Thursday, January 27, 2022 3:10 PM
To: Jacobson, Travis <travis.jacobson@mdu.com>
Subject: MDU water line siting PU-22-34

**** WARNING: EXTERNAL SENDER. NEVER click links or open attachments without positive sender verification of purpose. DO NOT provide your user ID or password on sites or forms linked from this email. ****

Travis,

Please see below questions for this case.

1. Please provide MDU's updated corporate papers. Last update was 2019 in case PU-08-710. **Attached.**
2. Please provide the maximum design operating pressure. **144 psi**
3. Please provide the maximum design operating temperature. **Operating temperature will vary with river temperature. (33 to 65 degrees)**
4. Please provide the maximum design flow rate. **1395 GPM**
5. Please provide contact info for: Morton County commission chair and the Mayor of Mandan. **See below for contact info. Also included is Justin Froseth, who has been Montana-Dakota's direct contact for this project.**

Nathan Boehm
Morton County Commission Chair

9 PU-22-34 Filed 01/28/2022 Pages: 2
PSC request for information with MDU responses
Montana-Dakota Utilities Co.
Travis Jacobson

701-220-8174 (cell)
nathan.boehm@mortonnd.org

Tim Helbling
Title: Mayor and President, Board of City Commissioners
Phone: (701) 667-7460
Address: c/o Mandan City Hall, 205 Second Ave. NW
E-mail: tim.helbling@cityofmandan.com

Justin Froseth, PE
Planning and Engineering Director
City of Mandan
205 2nd Ave NW
Mandan ND 58554
Office ☎: 701.667.3227
✉: jfroseth@cityofmandan.com

6. Has the Morton County Auditor been served with a copy of this application? **Yes**
7. When will we receive the remaining \$160 application fee? **Mailed yesterday**
8. Please provide dates for a hearing in the April-May timeframe. **The only date that has been highlighted and will not work is the morning of May 3. Is there a reason that this cannot be held in March? I know the notice needs to be out for a number of days but the engineers were hoping to have the construction completed shortly after the closure of Heskett 1 & 2 and would like to begin construction as soon as possible. Thoughts?**

Thanks,

Victor Schock
Public Utility Analyst
North Dakota Public Service Commission
600 E Boulevard Ave, Dept 408
Bismarck, ND 58505-0480
(701)328-3397
vschock@nd.gov

This transmission, email and any files transmitted with it, may be: (1) subject to the Attorney-Client Privilege, (2) an attorney work product, or (3) strictly confidential under federal or state law. If you are not the intended recipient of this message, you may not use, disclose, print, copy or disseminate this information. If you have received this transmission in error, notify the sender (only) and delete the message. This message may also be subject to disclosure under the North Dakota Open Records Laws.