

2017					
Description	Power Supply	Major Event	Planned	All Other	Total
Number of Outages	154	8	95	964	1221
Number of Consumers Affected	5400	738	2371	3166	11675
Average Number of Consumers	6574	6574	6574	6574	6574
SAIDI	58	46.1	37.8	59.8	201.8

SAIDI with no major event - 155.7

SAIDI less the power supply - 143.8

2018					
Description	Power Supply	Major Event	Planned	All Other	Total
Number of Outages	12	135	71	494	712
Number of Consumers Affected	2393	1680	854	5190	10117
Average Number of Consumers	6608	6608	6608	6608	6608
SAIDI	27.2	168	10.3	75.5	280.9

SAIDI with no major event - 112.9

SAIDI less the power supply - 253.7

2019					
Description	Power Supply	Major Event	Planned	All Other	Total
Number of Outages	12	147	129	432	720
Number of Consumers Affected	2351	2561	1705	5088	11705
Average Number of Consumers	6651	6651	6651	6651	6651
SAIDI	27.5	396.3	9.3	97.8	531

SAIDI with no major event - 134.7

SAIDI less the power supply - 503.5

2020					
Description	Power Supply	Major Event	Planned	All Other	Total
Number of Outages	21	5	343	720	1089
Number of Consumers Affected	5362	137	1868	6431	13798
Average Number of Consumers	6696	6696	6696	6696	6696
SAIDI	48.3	197	15.9	148.6	409.8

SAIDI with no major event - 212.8

SAIDI less the power supply - 361.5

2021					
Description	Power Supply	Major Event	Planned	All Other	Total
Number of Outages	29	256	399	966	1650
Number of Consumers Affected	387	321	619	1448	2775
Average Number of Consumers	6756	6756	6756	6756	6756
SAIDI	6.7	27.2	12.4	58.3	104.5

SAIDI with no major event - 77.3

SAIDI less the power supply - 97.8

2022 To December					
Description	Power Supply	Major Event	Planned	All Other	Total
Number of Outages	68	123	368	1012	1571
Number of Consumers Affected	2277	442	704	1920	5343
Average Number of Consumers	6817	6817	6817	6817	6817
SAIDI	28	78.9	10.2	76.5	193.5

SAIDI with no major event - 114.6

SAIDI less the power supply - 165.5

System Average Interruption Duration Index (SAIDI)

SAIDI is the average duration of interruptions per consumers during the year. It is the ratio of the annual duration of interruptions (sustained) to the number of consumers. If duration is specified in minutes, SAIDI is given as consumer minutes.