

Invoice

North Dakota Public Service Commission - Tax ID 450309764

Invoice# **TR11792**

Testing and Safety Division

SFN 19242 (5/2002)

Operator# 7255
J Starr Oil
17050 Hwy 11
Hankinson ND 58041
 Phone: 242-7014
 Contact:
 E Mail:

Billed To: 7255
J Starr Oil
17050 Hwy 11
Hankinson ND 58041
 Phone: 242-7014
 Contact:
 E Mail:

Time In: 3/15/2022 11:57 am Out: 4:40 pm
 Approval Seals: 14588 to 14597

Inspection Record					Device Comments	
	Status	Fee	Qty.	Fee Total	Serial Number:	Seal Number:
Liquid or Computing Pump	Approved	20.00	10	\$200.00	Liquid or Computing Pump NA - Multi	C 0
Liquid or Computing Pump	30 Day Caution	20.00	8	\$160.00	REJECTED: YELLOW TAGGED. Out of tolerance 1 D. 60 Days to repair. Pump 1, 87 octane	
Liquid or Computing Pump	Rejected	20.00	2	\$40.00	Liquid or Computing Pump NA - Multi	C 0
				\$400.00	REJECTED: YELLOW TAGGED. Out of tolerance 2 D. 60 Days to Repair. Pump 2, 87 octane	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Out of tolerance 2 D. 60 Days to Repair. Pump 3, 87 Octane	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Out of tolerance 2 D. 60 Days to Repair. Pump 4, 91 octane.	
					Liquid or Computing Pump NA - Multi	R 0
					REJECTED: RED TAGGED. 90 degree elbow on pump leaking cannot be used commercially until repaired. Pump 7 Diesel	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Out of tolerance 1 D and needs new swivel. 60 Days to Repair. Pump 8, Diesel	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Needs new swivel. 60 Days to Repair. Pump 10, Diesel	
					Liquid or Computing Pump NA - Multi	R 0
					REJECTED: RED TAGGED. New Hose, Metal sticking out. Cannot be used until repaired by registered service. Pump 11	
					Liquid or Computing Pump NA	C 14598
					REJECTED: YELLOW TAGGED. Replace Swivel. 60 Days to Repair. Pump 13, Diesel	

1 WM-23-63 Filed 02/03/2023 Pages: 22
 Compiled Violation Documentation
 Public Service Commission

Please remit payment to : Public Service Commission
 600 E. Boulevard Ave Dept 408
 Bismarck ND 58505-0480

Invoice

North Dakota Public Service Commission - Tax ID 450309764

Invoice# **TR11792**

Testing and Safety Division

SFN 19242 (5/2002)

Operator# 7255

Billed To: 7255

J Starr Oil

J Starr Oil

17050 Hwy 11

17050 Hwy 11

Hankinson ND 58041

Hankinson ND 58041

Phone: 242-7014

Phone: 242-7014

Contact:

Contact:

E Mail:

E Mail:

Time In: 3/15/2022 11:57 am Out: 4:40 pm

Approval Seals: 14588 to 14597

Inspection Record	Device Comments	
	Serial Number: Liquid or Computing Pump NA	Seal Number: C 0 REJECTED: YELLOW TAGGED. Replace Swivel. 60 Days to Repair. Pump 14, Diesel

Amount Due: \$400.00

Accounts are due in thirty days. This account is due on April 14, 2022.

Note: Talked to Heather. Red Tagged Pump 7 elbow leak and 11 Hose Metal sticking out. Yellow Tagged, Pump 1,2,3,4,8 for Calibration issues. Yellow Tags Pump 8,10,13,14 for repairs. Rejected Pumps Cannot use in Commerce. Thank You call with any questions

Inspected By: tracy

Please remit payment to : Public Service Commission
600 E. Boulevard Ave Dept 408
Bismarck ND 58505-0480

Liquid Test Report

North Dakota Public Service Commission

Testing and Safety Division

SFN 19838 (5/2002)

Invoice# TR 11792

Operator# 7255

Inspected Date: 3/15/2022

J Starr Oil

17050 Hwy 11

Hankinson ND 58041

Phone: 242-7014

Contact:

E Mail:

Remarks: **Talked to Heather. Red Tagged Pump 7 elbow leak and 11 Hose Metal sticking out. Yellow Tagged, Pump 1,2,3,4,8 for Calibration issues. Yellow Tags Pump 8,10,13,14 for repairs. Rejected Pumps Cannot use in Commerce. Thank You call with any questions**

Test Results

Device Code	Meter/Pump/Hose Group	Product	Serial Number	Test #	Variance		Units	Meterfactor/Before	Totalizer After	Money Error	Status	Seal Number
					As Found	As Left						
16	1	Pump 1 hose	LOW GRADE	NA - Multi	1 Fast	6.00	6.00in3				C	0
16	1	Pump 1 hose			1 Slow	6.00	6.00in3					
16	2	Pump 1 hose	High Grade	NA - Multi	1 Fast	5.00	5.00in3				A	14588
16	2	Pump 1 hose			1 Slow	5.00	5.00in3					
16	3	Pump 2 hose	Low Grade	NA - Multi	1 Fast	8.00	8.00in3				C	0
16	3	Pump 2 hose			1 Slow	7.00	7.00in3					
16	4	Pump 2 hose	High Grade	NA - Multi	1 Fast	1.00	1.00in3				A	14589
16	4	Pump 2 hose			1 Slow	1.00	1.00in3					
16	5	Pump 3 hose	Low Grade	NA - Multi	1 Fast	8.00	8.00in3				C	0
16	5	Pump 3 hose			1 Slow	7.00	7.00in3					
16	6	Pump 3 hose	High Grade	NA - Multi	1 Fast	4.00	4.00in3				A	14590
16	6	Pump 3 hose			1 Slow	4.00	4.00in3					
16	7	Pump 4 hose	Low Grade	NA - Multi	1 Fast	4.00	4.00in3				A	14591
16	7	Pump 4 hose			1 Slow	3.00	3.00in3					
16	8	Pump 4 hose	High Grade	NA - Multi	1 Fast	8.00	8.00in3				C	0
16	8	Pump 4 hose			1 Slow	7.00	7.00in3					
16	8	Pump 4 hose			2 Fast		in3					
16	8	Pump 4 hose			2 Slow		in3					
16	9	Pump 5 hose	Low Grade	NA - Multi	1 Fast	4.00	4.00in3				A	14592
16	9	Pump 5 hose			1 Slow	3.00	3.00in3					
16	10	Pump 5 hose	High Grade	NA - Multi	1 Fast	0	0in3				A	14593
16	10	Pump 5 hose			1 Slow	1.00	1.00in3					
16	11	Pump 6 Hose	Low Grade	NA - Multi	1 Fast	5.00	5.00in3				A	14494
16	11	Pump 6 Hose			1 Slow	4.00	4.00in3					
16	12	Pump 6 hose	High Grade	NA - Multi	1 Fast	0	0in3				A	14595
16	12	Pump 6 hose			1 Slow	2.00	2.00in3					
16	13	Pump 7 Hose	Diesel	NA - Multi	1 Fast	5.00	5.00in3				R	0
16	13	Pump 7 Hose			1 Slow	1.00	1.00in3					
16	14	Pump 8 Hose	Diesel	NA - Multi	1 Fast	7.00	7.00in3				C	0
16	14	Pump 8 Hose			1 Slow	5.00	5.00in3					
16	15	ump 9, Hose	Diesel	NA - Multi	1 Fast	4.00	4.00in3				A	14596
16	15	ump 9, Hose			1 Slow	3.00	3.00in3					
16	16	ump 10, Hose	Diesel	NA - Multi	1 Fast	2.00	2.00in3				C	0
16	16	ump 10, Hose			1 Slow	2.00	2.00in3					

Liquid Test Report

North Dakota Public Service Commission

Testing and Safety Division

SFN 19838 (5/2002)

Invoice# TR 11792

Device Code	Meter/Pump/Hose Group	Product	Serial Number	Test #	Variance As Found	As Left	Units	Meterfactor/Before	Totalizer/After	Money Error	Status	Seal Number
16	17	ump 11, Hose	Diesel	NA - Multi	1 Fast	3.00	3.00	in3			R	0
16	17	ump 11, Hose			1 Slow	1.00	1.00	in3				
16	18	ump 12, Hose	Diesel	NA - Multi	1 Fast	3.00	3.00	in3			A	14597
16	18	ump 12, Hose			1 Slow	1.00	1.00	in3				
16	19	ump 13, Hose	Diesel	NA	1 Fast	1.00	1.00	in3			C	14598
16	19	ump 13, Hose			1 Slow	1.00	1.00	in3				
16	19	ump 13, Hose			2 Fast			in3				
16	19	ump 13, Hose			2 Slow			in3				
16	20	ump 14, Hose	Diesel	NA	1 Fast	3.00	3.00	in3			C	0
16	20	ump 14, Hose			1 Slow	2.00	2.00	in3				

Inspected By **tracy**

Remarks and Adjustments Made

Device # Device Status Seal # Serial Number Inspection Comment

16 1 30 Day Caution 0 NA - Multi REJECTED: YELLOW TAGGED. Out of tol
60 Days to repair. Pump 1, 87 octane

16 3 30 Day Caution 0 NA - Multi REJECTED: YELLOW TAGGED. Out of tol
60 Days to Repair. Pump 2, 87 octane

16 5 30 Day Caution 0 NA - Multi REJECTED: YELLOW TAGGED. Out of tol
60 Days to Repair. Pump 3, 87 Octane

16 8 30 Day Caution 0 NA - Multi REJECTED: YELLOW TAGGED. Out of tol
60 Days to Repair. Pump 4, 91 octane.

16 13 Rejected 0 NA - Multi REJECTED: RED TAGGED. 90 degree elb
pump leaking cannot be used commercially
repaired. Pump 7 Diesel

16 14 30 Day Caution 0 NA - Multi REJECTED: YELLOW TAGGED. Out of tol
and needs new swivel. 60 Days to Repair.
Diesel

16 16 30 Day Caution 0 NA - Multi REJECTED: YELLOW TAGGED. Needs ne
60 Days to Repair. Pump 10, Diesel

Liquid Test Report

North Dakota Public Service Commission

Testing and Safety Division

SFN 19838 (5/2002)

Invoice# TR 11792

Device #	Device Status	Seal #	Serial Number	Inspection Comment
16 17	Rejected	0 NA - Multi		REJECTED: RED TAGGED. New Hose, Mt out. Cannot be used until repaired by regis service. Pump 11
16 19	30 Day Caution	14598 NA		REJECTED: YELLOW TAGGED. Replace Days to Repair. Pump 13, Diesel
16 20	30 Day Caution	0 NA		REJECTED: YELLOW TAGGED. Replace Days to Repair. Pump 14, Diesel

Invoice

North Dakota Public Service Commission - Tax ID 450309764

Invoice# **AH63278**

Testing and Safety Division

SFN 19242 (5/2002)

Operator# 7255

Billed To: 9884

J Starr Oil

J Starr

17050 Hwy 11

PO Box 279

Hankinson ND 58041

Horace ND 58047

Phone: 242-7014

Phone:

Contact:

Contact:

E Mail:

E Mail:

Time In: 5/3/2022 12:00 am Out:

Approval Seals:

Inspection Record					Device Comments
	Status	Fee	Qty.	Fee Total	
Liquid or Computing Pump	Approved	20.00	4	\$80.00	
				\$80.00	

Amount Due: \$0.00

Accounts are due in thirty days. This account is due on June 2, 2022.

Note: Luke C. A. Roberts

Inspected By:

Please remit payment to : Public Service Commission
600 E. Boulevard Ave Dept 408
Bismarck ND 58505-0480



LIQUID TEST REPORT

1301 40th Street NW • Fargo, ND 58102 • (701) 282-9260
635 31st Street SE • Minot, ND 58701 • (701) 852-3145

Work Order Number **118 134**

Invoice Number _____

Operator No.	Date 5/3/22	Date Last Tested UNK	Check All That Apply <input type="checkbox"/> Self-Certification <input type="checkbox"/> New Installation <input type="checkbox"/> Routine Service <input type="checkbox"/> Annual <input checked="" type="checkbox"/> Equipment Repaired <input type="checkbox"/> Rejected Equipment Tag # (Attach _____) <input type="checkbox"/> Non-Commercial <input type="checkbox"/> Service Contract? <input type="checkbox"/> Variance Posted?		
Name of Business J Starr Oil					
Location of Device 17050 Highway 11					
Mailing Address P.O. Box 176					
City Hankinson	State ND	Zip Code 58041			
County		Telephone Number (701) 247-7014			

Standard Use Prover	Size 5 gallon	Last Cal. Date 06/21
-------------------------------	-------------------------	--------------------------------

TYPE OF DEVICE/PSC CODE						
Retail Pump 16	Mobile Delivery 19	LPG Propane 21G	Liquid Fert./Agri Chemical 21F	Pipeline/Transport 20	CNG 21C	Other

Fill out all that apply:

Device Code	Meter/Pump/Hose #	Product	Serial #	Variance		Meter Factor/Totalizer Readings		Money Error	Approved (A) Rejected (R)
				As Found	As Left	Before	After		
				(State Units)					
	1	87	EN00102601	+6in ³	0in ³	—	—	—	A
	2	87	+	+8in ³	-0.5in ³	—	—	—	A
	3	87	EN00102600	+7.5in ³	-0.5in ³	—	—	—	A
	4	91	L	+8in ³	0in ³	—	—	—	A

REMARKS & ADJUSTMENTS MADE

Performed E-Cal on (4) four products.

I hereby declare the statements made here are correct:

Are there any other jurisdictions' devices at this location that require testing? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Original — Mail to: Public Service Commission 600 E. Boulevard Avenue Bismarck, ND 58505 Yellow Copy — Leave with equipment owner or operator
HAS SECURITY SEAL AND STICKER BEEN APPLIED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Rejected Service Agency (Print) ODay Equipment	
Inspector/Permit Holder Signature: _____ Permit No. 1876 Owner - Operator Signature: _____	

Invoice

North Dakota Public Service Commission - Tax ID 450309764

Invoice# **KE17946**

Testing and Safety Division

SFN 19242 (5/2002)

Operator# 7255

J Starr Oil

17050 Hwy 11

Hankinson ND 58041

Phone: 242-7014

Contact:

E Mail:

Billed To: 9884

J Starr

PO Box 279

Horace ND 58047

Phone:

Contact:

E Mail:

Time In: 5/10/2022 10:38 am Out: 11:09 am

Approval Seals:

Inspection Record	Device Comments
-------------------	-----------------

Amount Due: \$0.00

Accounts are due in thirty days. This account is due on June 9, 2022.

Note: Gas pumps repaired May 2022 by Oday, diesel not repaired. Lead wire seals cut on pump 7 & 11, not repaired, lead wire seal for pump 7 was lying on the ground, took pictures. Will talk to Konrad before taking any further action.

Inspected By: kyle

Please remit payment to : Public Service Commission
600 E. Boulevard Ave Dept 408
Bismarck ND 58505-0480

Crockford, Konrad S.

From: Erickson, Kyle W.
Sent: Tuesday, May 10, 2022 22:01
To: Bauske, Shelly A.; Crockford, Konrad S.; Rohde, Tracy A.; Wahlfeldt, Brandon H.
Subject: J-Starr Oil, Hankinson, ND
Attachments: Broken lead wire seal pump #7 May 2022.jpg; Hose pump #11 March 2022.jpg; Hose pump #11 May 2022.jpg; J-Starr Invoice.pdf; Lead seal pump #7 as found May 2022.jpg; Lead Seal pump #7 March 2022.jpg; Lead Seal pump #11 March 2022.jpg; Missing lead wire seal pump #7 May 2022.jpg; Missing lead wire seal pump #11 May 2022.jpg

All,

Today, I went to Hankinson to follow up on the 30-day rejected tags and 60-day caution tags that Tracy and I placed on the pumps on March 15th, 2022. The gas pumps have been repaired by Oday in May 2022. The 2 hoses that received 30-day rejected tags, also were lead-wire sealed to the dispenser. One hose was worn very badly, so bad that we had major concerns of it bursting, and the other hose had fittings that were leaking a steady stream of fuel out. We both felt that lead wire seals were appropriate because of the imminent danger and potential hazard it posed to the consumer. Upon my inspection, I found that both lead-wire seals had been removed, both rejected stickers are on the pumps, the hose on pump #11 has not been replaced, see the photo evidence, and as far as I can tell, nothing has been replaced on pump #7 either.

Pump #11 said \$0.00 on the pump, so they're going to say they're not using it, to me, that does not negate the fact that they cut it, who is to say they didn't use it a month and a half ago. The lead-wire seal for pump #7 was lying on the ground right in front of the pump, it is pretty clear to me that they are using that one. I have the lead-wire seal with me.

I attached 8 pictures from our original inspection showing the lead-wire seals intact, and pictures from today showing the one cut seal and both handles with missing seals. I also included the original invoice from March 15th signed by Rex Roeder, he was just a kid working there after the manager left. The manager, Heather, had left for the day when Tracy and I were unloading fuel back into the bulk plant, she came and talked to us before she left and we did explain everything to her and she said to please leave the invoice and paperwork with the clerk that was working.

Where do we go from here?

Kyle W. Erickson

State Inspector, Weights & Measures

701-328-2400 (office)

701-220-4141 (cell)

kyerickson@nd.gov

www.psc.nd.gov



received this transmission in error, notify the sender (only) and delete the message. This message may also be subject to disclosure under the North Dakota Open Records Laws.

Invoice

North Dakota Public Service Commission
Testing and Safety Division
SFN 19242 (5/2002)

Invoice# **TR11792**

Operator# 7255
J Starr Oil
17050 Hwy 11
Hankinson ND 58041
Phone: 242-7014
Contact:
E Mail:

Billed To: 7255
J Starr Oil
17050 Hwy 11
Hankinson ND 58041
Phone: 242-7014
Contact:
E Mail:

Time In: 3/15/2022 11:57 am Out: 4:40 pm
Approval Seals: 14588 to 14597

Inspection Record					Device Comments	
Fee Code	Status	Fee	Qty	Fee Total	Serial Number:	Seal Number:
Liquid or Computing Pump	Approved	20.00	10	\$200.00	Liquid or Computing Pump NA - Multi	C 0
Liquid or Computing Pump	Caution	20.00	8	\$160.00	REJECTED: YELLOW TAGGED. Out of tolerance 1 D. 60 Days to repair. Pump 1, 87 octane	
Liquid or Computing Pump	Rejected	20.00	2	\$40.00	Liquid or Computing Pump NA - Multi	C 0
				\$400.00	REJECTED: YELLOW TAGGED. Out of tolerance 2 D. 60 Days to Repair. Pump 2, 87 octane	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Out of tolerance 2 D. 60 Days to Repair. Pump 3, 87 Octane	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Out of tolerance 2 D. 60 Days to Repair. Pump 4, 91 octane.	
					Liquid or Computing Pump NA - Multi	R 0
					REJECTED: RED TAGGED. 90 degree elbow on pump leaking cannot be used commercially until repaired. Pump 7 Diesel	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Out of tolerance 1 D and needs new swivel. 60 Days to Repair. Pump 8, Diesel	
					Liquid or Computing Pump NA - Multi	C 0
					REJECTED: YELLOW TAGGED. Needs new swivel. 60 Days to Repair. Pump 10, Diesel	
					Liquid or Computing Pump NA - Multi	R 0
					REJECTED: RED TAGGED. New Hose, Metal sticking out. Cannot be used until repaired by registerd service. Pump 11	
					Liquid or Computing Pump NA	C 14598
					REJECTED: YELLOW TAGGED. Replace Swivel. 60 Days to Repair. Pump 13, Diesel	

Rex Roeder
Ry Roeder

Please remit payment to : Public Service Commission
600 E. Boulevard Ave Dept 408
Bismarck ND 58505-0480
Phone 701-328-2400

Federal Tax ID 45-0309764

Invoice

North Dakota Public Service Commission
Testing and Safety Division
SFN 19242 (5/2002)

Invoice# **TR11792**

Operator# 7255

J Starr Oil

17050 Hwy 11

Hankinson ND 58041

Phone: 242-7014

Contact:

E Mail:

Billed To: 7255

J Starr Oil

17050 Hwy 11

Hankinson ND 58041

Phone: 242-7014

Contact:

E Mail:

Time In: 3/15/2022 11:57 am Out: 4:40 pm

Approval Seals: 14588 to 14597

Inspection Record

Device Comments

Serial Number:	Seal Number:
Liquid or Computing Pump NA	C 0
REJECTED: YELLOW TAGGED. Replace Swivel. 60 Days to Repair. Pump 14, Diesel	

Amount Due: \$400.00

Accounts are due in thirty days. This account is due on April 14, 2022.

Note: Talked to Heather. Red Tagged Pump 7 elbow leak and 11 Hose Metal sticking out. Yellow Tagged, Pump 1,2,3,4,8 for Calibration issues. Yellow Tags Pump 8,10,13,14 for repairs. Rejected Pumps Cannot use in Commerce. Thank You call with any questions

Inspected By: **tracy**

Please remit payment to : Public Service Commission
600 E. Boulevard Ave Dept 408
Bismarck ND 58505-0480
Phone 701-328-2400

Federal Tax ID 45-0309764

03-15-2022 - "Rejected for Repair" tag & lead wire seal installed on pump #7



03-15-2022 - "Rejected for Repair" tag & lead wire seal installed on pump #11



03-15-2022 - Pump #11 damaged hose.



05-10-2022 - Pump #11 damaged hose (not repaired).




05-10-2022 - "Rejected for Repair" tag present, & lead wire seal REMOVED on pump #11



05-10-2022 - "Rejected for Repair" tag present, & lead wire seal REMOVED on pump #7



05-10-2022 - Broken lead wire seal found by pump #7



Lead seal

05-10-2022 - Broken lead wire seal found by pump #7



Invoice

North Dakota Public Service Commission - Tax ID 450309764

Invoice# **AH63752**

Testing and Safety Division

SFN 19242 (5/2002)

Operator# 7255

Billed To: 9884

J Starr Oil

J Starr

17050 Hwy 11

PO Box 279

Hankinson ND 58041

Horace ND 58047

Phone: 242-7014

Phone:

Contact:

Contact:

E Mail:

E Mail:

Time In: 6/17/2022 12:00 am Out:

Approval Seals:

Inspection Record					Device Comments
	Status	Fee	Qty.	Fee Total	
Liquid or Computing Pump	Approved	20.00	5	\$100.00	
				\$100.00	

Amount Due: \$0.00

Accounts are due in thirty days. This account is due on July 17, 2022.

Note: MARK KASSON

Inspected By:

Please remit payment to : Public Service Commission
600 E. Boulevard Ave Dept 408
Bismarck ND 58505-0480



LIQUID TEST REPORT

1301 40th Street NW • Fargo, ND 58102 • (701) 282-9260
 635 31st Street NE • Minot, ND 58701 • (701) 852-3145

Work Order Number 118134
Invoice Number

Operator No.	Date 6-17-22	Date Last Tested 3-22	Check All That Apply <input type="checkbox"/> Self Certification <input type="checkbox"/> New Installation <input type="checkbox"/> Routine Service <input type="checkbox"/> Annual <input type="checkbox"/> Semi-Annual <input type="checkbox"/> Equipment Repaired <input checked="" type="checkbox"/> Rejected Equipment Tag # (attach) _____ <input type="checkbox"/> Non-Commercial <input type="checkbox"/> Service Contract? Expires _____ <input type="checkbox"/> Variance Posted? <input type="checkbox"/> Yes <input type="checkbox"/> No
Name of Business J Star			
Location of Device 17050 Hwy 11			
Mailing Address			
City Hankinson	State ND	Zip Code 58041	
County Richland	Telephone Number 701 242 7014		

Standard Use Scaphin	Size 5 gallon	Last Cal. Date 4-2022
--------------------------------	-------------------------	---------------------------------

TYPE OF DEVICE/PSC CODE						
Retail Pump	Mobile Delivery	LPG Propane	Liquid Fert./Agri Chemical	Pipeline/Transport	CNG	Other
16	19	21G	21F	20	21C	

Fill out all that apply:

Device Code	Meter/ Pump/ Hose#	Product	Serial #	Variance		Meter Factor/ Totalizer Readings		Money Error	Approved (A) Rejected (R)
				As Found	As Left	Before	After		
				(State Units)					
16	7	diesel	LA0000 3280	+8	+1 / -1				A
16	10	diesel	EN 00 102603	+5	-1 / -1				A
16	11	diesel	LA 00 00 3281	+3	0 / -1				A
16	13	diesel	EN 00 102602	+1	-1				A
16	14	diesel	EN 00 102602	-3	0 / -1				A

Remarks & Adjustments Made

#7 red tagged replaced swivel calibrated and adjusted #10,13,14 yellow tagged replaced swivel tested calibration and adjusted 10 and 14. #11 replaced hose (red tagged) checked calibration and made small adjustment. Pumps 8 and 9 still out of service

I hereby declare the statements made here are correct:

Are there any other jurisdictions' devices at this location that require testing? <input type="checkbox"/> Yes <input type="checkbox"/> No		Original—Mail To: Public Service Commission 600 E. Boulevard Avenue Bismarck, ND 58505 Yellow Copy— Leave with equipment owner or operator Blue Copy— For Registrant's Records
HAS SECURITY SEAL AND STICKER BEEN APPLIED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Rejected	Service Agency (print) O'Day Equipment	
Inspector/Permit Holder Signature <i>[Signature]</i>	Permit No. 1567	
Owner/Operator Signature		