

**Case Number:** PU-23-361

**Project:** Roundup to Kummer Ridge 345-kV Transmission Line

**Month Ending:** 4/30/2024



**BASIN ELECTRIC  
POWER COOPERATIVE**  
A Touchstone Energy® Cooperative

Title	Name	Company	Office Phone	Cell Phone	Email Address
Project Manager	Bobby Nasset	Basin Electric	701-557-5673	701-260-7443	rnasset@bepc.com
Project Engineer	Shane Vasbinder	Basin Electric	701-557-5779	701-226-2941	svasbinder@bepc.com
Field Coordinator	Darrel Slavick	Basin Electric		701-202-5418	dslavick@bepc.com

**Safety**

A rural water pipeline was struck on Saturday, April 27th 2024 during foundation hole drilling. The One-Call located the pipeline approximately 30 feet from where the pipeline actually was. The rural water company was immediately called and the pipeline was repaired and Basin Electric moved the structure location away from the pipeline. No injuries occurred.

**Environmental**

Per SWPPP, silt fence is being installed, as needed.

**Land Owner/Public Issues**

Nothing at this time

**Structure Move Requests**

A structure relocation request was submitted to NDPSC staff on April 23, 2024.

**Construction Progress**

- Material receiving and delivery
- Access road creation
- Tree removal and mulching
- Crane pad construction
- Foundation installation

**Scheduled Activities**

- Deliver poles to sites
- Continue foundation installation
- Structure framing

**Comments**