



Aug 6, 2025

Mr. Steve Kahl

Public Service Commission
600 East Boulevard Ave
Dept 408
Bismarck, North Dakota 58505-0480
ndpsc@nd.gov
701-328-2400

Dear Mr. Kahl,

This is in response to your request for a review of the environmental impacts associated with the Leonardite Products LLC Revision 12, Permit GRGR-0501, Renewal 4, Permit GRGR-0501, Case No. RC-25-169, Case No. RC-25-170, located in Williams County, North Dakota.

The proposed project has been reviewed by Department of Water Resources (DWR), and the following comments are provided:

- The DWR Regulatory Division's Engineering and Permitting Section reviewed the project location and based on the information provided, no drainage permits, or construction permits for dikes, diversions, or restorations are required.
- Initial review indicates the project does not require a conditional or temporary permit for water appropriation. However, if surface water or groundwater will be diverted for construction of any future projects identified in the plan, a water permit will be required per North Dakota Century Code § 61-04-02. Please consult with the DWR Water Appropriation Division if you have any questions at (701) 328-2754 or appropinfo@nd.gov.
- The DWR maintains a network of observation wells across the state for monitoring the water levels and quality in glacial and bedrock aquifers. These wells are often installed in road and highway rights-of-way to limit inconvenience to the adjacent landowners. DWR observation wells have a yellow protective casing extending between 1 and 3 feet above ground surface, and their locations are marked with a stake. If an observation well is encountered during project activities and must be removed, please contact the Water Appropriation Division. The DWR hopes to keep all observation wells, but otherwise will ensure the well is properly abandoned.
- There are no FEMA National Flood Insurance Program (NFIP) floodplains identified or mapped where the proposed project is to take place. No permits relative to the NFIP are likely required based on the current Flood Insurance Rate Map and State minimum standards. However, flood risk has been identified through the North Dakota Risk Assessment Mapservice and Base Level Engineering (BLE) (ndram.dwr.nd.gov). In the absence of FEMA NFIP data, BLE is often considered best available data and is recommended to be considered in the design process. The State of North Dakota has no formal NFIP permitting authority as all NFIP permitting decisions are considered by impacted NFIP participating communities, the community with zoning authority for the area in question. Please work directly with the local floodplain administrators of the zoning authorities impacted.

Thank you for the opportunity to provide review comments. Should you have further questions, please contact me at 701-328-4970 or kyrkoski@nd.gov.

16 RC-25-169 Filed 08/06/2025 Pages: 2
Revision 12 Department of Water Resources Review Letter

North Dakota Department of Water Resources (DWR)
Kyle Yrkoski

Sincerely,

A handwritten signature in black ink, appearing to read "Kyle Yrkoski". The signature is written in a cursive style with a large initial "K" and a long, sweeping underline.

Kyle Yrkoski
Planner III

KY:mg/1570