


from the grid and start the emergency generation prior to the entire grid or portions of the grid losing power. We believe this is a fair request that benefits MISO grid operations and helps to provide our neighbors with stability of electrical service.

6. MISO calling an EEA2 level is the prior step to when power interruptions are imminent or happening, as shown on [MISO's website](#):



Dark Orange

The grid is stable and MISO has issued an Energy Emergency Alert 2 (EEA2).

EEA2 is the second level of emergency action, triggered as operating reserves continue to decline. It means MISO is facing an energy shortage and needs to reduce energy demand.

By declaring EEA2, MISO operators can access emergency generation not available under normal conditions. They may also purchase emergency energy from neighboring grids (if available) and implement measures to reduce electricity demand. One option is for MISO to ask member utilities to encourage consumers to conserve power. However, an EEA2 declaration does not automatically mean this step will be taken.



Red


MISO has issued an Energy Emergency Alert 3 (EEA3).

EEA3 is the final level of emergency action, triggered to prevent cascading outages and ensure grid reliability for as many consumers as possible. It indicates that energy supply and demand are unbalanced, and power interruptions are imminent or already occurring.

Power interruptions are a last resort to protect the grid's stability. In these rare situations, MISO's role is to identify the areas where interruptions are needed and determine how much electricity must be reduced to balance supply and demand. MISO's member utilities are responsible for carrying out the interruptions and deciding which customers will temporarily lose power.

7. EEA2 events from 2021 through 2025 have resulted in approximately 31 hours of events. In 2021, Winter Storm Uri had [17 hours](#), Winter Storm Elliott required less than [4 hours](#) (see figure in Paragraph No. 8 below) and August high temperatures in 2023 required [no hours of LMR](#) for the northern tier but did require hours for others. Most recently an EEA2 was called for extreme cold on January 24, 2026, which was in effect for [less than 2 hours](#) from 4:36am to 6:01am.
8. An example of the actual amount of EEA2 declaration can be shown from Winter Storm Elliott below. The emergency was in effect from just before 6:00 p.m. to 9:00 p.m. MISO exercised 3.2 GW of LMR at that time that was called upon throughout their area. The spike in usage is also demonstrated in Figure 8 below as to how quickly demand decreases, as normal electricity usage for residents decreases during the night. These are mechanisms to handle spike in usage in a way that the Regional Transmission Organizations do not have to overbuild generation, which would increase the costs for all rate payers.

Figure 8: Winter Storm Elliott Emergency Declarations and Prices
December 23–24, 2022



2022 STATE OF THE MARKET REPORT

9. APLD can only use the backup generation up to the level of current facility demand for our operations. Typically, in the winter, our facilities do not operate at their peak load. Recently an EEA2 was called in January 2026 due to extreme cold. Even if we certified a significant amount of our backup generation as LMR BTMG to offset our load, the amount of generation cannot exceed the facility’s then current operating load. No excess generation would be used nor is it possible for excess generation to be put on the grid from the generators. APLD would be volunteering to comply with MISO directives in the event of a grid emergency and reduce power taken from the grid so that others who may not have backup generation can still have electricity.
10. LMR behind the meter generation (BTMG) is accomplished through an agreement with the utility provider as the balancing area authority within MISO to provide generation to replace an amount of its facility load when grid conditions require demand reductions. This MISO election qualification usually provides for a minimum of three to five possible events each season of four consecutive hours each.
11. APLD seeks a jurisdictional determination from the Commission holding that LMR BTMG falls within the exemption to siting pursuant to N.D.C.C. § 49-22-03(1). If the Commission issues a determination consistent with APLD’s request outlined in Section III of the Jurisdictional Determination, APLD would utilize LMR BTMG in all our North Dakota locations. For illustrative purposes, the Ellendale site has the following potential amounts of the following backup generators that could be qualified:

	Number of 3MW engines	Max possible certification for 4 hours
ELN-02	60	180 MW
ELN-03	96	288 MW
ELN-04	96	288 MW

Similar types of generation would be used at other sites in North Dakota. The only facility with backup electric generation currently installed, tested, and capable of operating presently is ELN-02.

12. The backup generators are diesel reciprocating internal combustion engines (RICE). These are also regulated by the North Dakota Department of Environmental Quality for the fuel storage as well as the air permit. In addition, to this jurisdictional determination, a modification of the air permits is also being pursued to allow for the engines to have up to 50 hours of annual run time which could occur any day or time for up to 4 hours per call. Due to the air permit restraints, we would initially only apply for 90 MW LMR capability even though we have 180 MW available. This is because EPA limits the operation of backup generation for grid support use to only 50 hours per year per engine. Each engine cannot provide the 64 hours under that permit constraint, so the entirety of the backup generation cannot be submitted for LMR.

Further your affiant says not.

Robert Dowd

Subscribed and sworn before me on April ____, 2026.

Notary Public